

LYNTUPY, Belarus

WMO: 266450

Lat: 55.0489N

Lon: 26.3069E

Elev: 212

StdP: 98.81

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.0	-17.5	-23.3	0.5	-20.7	-19.9	0.7	-17.2	7.3	1.0	6.5	0.1	1.0	30	0.543

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	28.0	19.1	26.2	18.3	24.5	17.4	20.6	25.7	19.5	24.2	18.5	22.8	2.7	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.8	13.9	22.8	17.7	13.0	21.5	16.8	12.3	20.5	60.1	25.8	56.3	24.1	53.0	22.8	23.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.2	5.4	4.7	-25.8	30.8	3.8	2.0	-28.5	32.3	-30.7	33.4	-32.8	34.5	-35.6	36.0
			-26.0	21.8	3.7	1.1	-28.7	22.6	-30.9	23.2	-33.0	23.8	-35.7	24.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.3	-5.0	-4.4	-0.3	6.6	11.7	15.2	17.8	16.6	11.5	6.0	1.4	-2.8
	DBStd	9.18	6.06	6.12	4.70	4.39	4.23	3.37	3.11	3.12	3.38	3.97	4.63	5.56
	HDD10.0	2153	464	403	321	119	29	1	0	0	23	134	259	397
	HDD18.3	4476	723	637	579	352	208	104	48	74	204	382	509	656
	CDD10.0	785	0	0	1	17	83	159	242	203	69	11	0	0
	CDD18.3	67	0	0	0	0	4	12	32	19	1	0	0	0
	CDH23.3	618	0	0	0	3	41	95	301	167	10	0	0	0
	CDH26.7	122	0	0	0	0	4	11	74	32	0	0	0	0
(14) Wind	WSAvg	2.2	2.6	2.4	2.4	2.1	2.0	2.0	1.7	1.7	1.8	2.3	2.5	2.6
(15) Precipitation	PrecAvg	695	49	43	44	41	63	74	79	73	62	62	51	53
	PrecMax	896	99	71	101	84	151	142	157	176	142	112	89	83
	PrecMin	526	6	20	12	10	13	27	2	8	16	10	4	21
	PrecStd	97	19	13	19	20	34	31	45	45	30	29	20	17
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.7	6.5	13.8	23.3	27.3	28.2	31.4	29.8	24.9	18.2	11.5	8.0
		MCWB	5.6	4.5	8.0	13.8	18.0	18.6	20.0	20.0	15.8	13.6	9.9	7.2
	2%	DB	4.3	4.7	10.4	19.8	24.1	26.2	28.9	27.1	21.6	15.0	9.6	6.2
		MCWB	3.6	3.3	6.1	11.6	16.0	18.2	20.1	18.6	15.3	12.4	8.5	5.4
	5%	DB	2.9	3.4	7.8	17.1	22.0	24.1	26.6	25.1	19.2	13.2	8.2	4.8
		MCWB	2.2	2.5	5.0	10.2	14.5	17.2	18.8	17.7	14.1	11.4	7.3	4.2
	10%	DB	1.7	2.3	5.7	14.7	20.0	21.9	24.7	23.1	17.4	11.6	7.0	3.3
		MCWB	1.2	1.6	3.7	9.1	13.5	16.1	18.2	17.1	13.6	10.2	6.3	2.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.7	5.1	9.0	14.5	19.1	20.7	22.5	21.6	17.4	14.4	10.3	7.4
		MCDB	6.3	6.2	11.8	21.6	25.3	25.6	28.2	28.2	21.8	16.6	10.9	7.8
	2%	WB	3.7	3.6	6.8	12.4	17.2	19.2	20.9	20.3	16.1	12.9	8.7	5.5
		MCDB	4.1	4.3	9.5	18.1	22.4	24.1	26.2	25.1	19.7	14.8	9.5	6.0
	5%	WB	2.3	2.6	5.3	11.0	15.7	18.1	19.8	18.9	15.0	11.6	7.4	4.2
		MCDB	2.8	3.3	7.5	15.5	20.5	22.0	24.8	22.5	18.0	12.8	8.0	4.8
	10%	WB	1.2	1.6	3.9	9.8	14.3	17.0	18.8	17.8	14.0	10.5	6.3	2.7
		MCDB	1.6	2.2	5.5	13.9	18.6	20.8	23.5	21.5	16.8	11.6	6.9	3.2
(35) Mean Daily Temperature Range	5% DB	MDBR	4.2	5.3	6.9	9.7	10.3	9.3	9.8	10.0	8.8	5.8	3.6	3.7
		MCDBR	3.5	4.5	9.7	14.3	13.7	12.7	13.4	13.4	12.1	8.3	4.6	3.6
	5% WB	MCWBR	3.4	3.7	6.4	7.2	6.5	5.8	5.6	5.7	6.8	5.7	3.8	3.5
		MCDWR	3.4	4.1	8.3	12.0	11.5	10.2	11.3	10.2	10.2	7.1	4.3	3.6
(40) Clear-Sky Solar Irradiance	taub		0.284	0.317	0.351	0.398	0.387	0.377	0.409	0.407	0.370	0.348	0.327	0.285
		taud	2.178	2.145	2.188	2.224	2.327	2.382	2.308	2.307	2.383	2.415	2.281	2.200
	Ebn at Noon		633	742	808	822	856	869	829	806	789	717	579	543
		Edh at Noon	60	90	110	122	117	112	119	112	91	70	56	48
(44) All-Sky Solar Radiation	RadAvg		0.58	1.41	2.75	4.04	5.22	5.54	5.17	4.34	2.93	1.41	0.48	0.35
	RadStd		0.12	0.26	0.43	0.47	0.52	0.47	0.53	0.39	0.27	0.28	0.08	0.08

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)		+0.43	N/A	N/A	N/A	N/A	+0.55	N/A	-157	N/A

Nomenclature: See separate page