

KYBARTAI, Lithuania

WMO: 267130

Lat: 54.650N

Lon: 22.800E

Elev: 59

StdP: 100.61

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.1	-15.0	-21.4	0.6	-19.1	-17.5	0.8	-14.7	11.4	2.3	10.3	1.2	2.0	90	0.562

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	29.0	20.5	27.1	19.1	25.4	18.4	21.5	27.3	20.3	25.6	19.3	24.1	3.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	14.4	24.5	18.4	13.3	22.8	17.4	12.5	21.7	62.7	27.5	58.5	25.6	55.0	24.5	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.0	8.5	7.3	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.7	-2.5	-0.6	1.1	7.9	12.4	15.7	18.4	17.7	12.7	8.5	2.4	-1.6
	DBStd	8.61	4.97	5.80	4.11	4.79	4.10	3.14	3.18	3.02	3.47	3.98	4.93	5.94
	HDD10.0	1760	387	298	278	95	22	1	0	0	15	74	231	359
	HDD18.3	3966	646	532	536	312	188	92	40	49	172	303	479	618
	CDD10.0	925	0	0	1	34	96	171	259	239	94	29	2	0
	CDD18.3	88	0	0	0	1	4	13	41	29	1	0	0	0
	CDH23.3	900	0	0	0	14	50	127	406	293	10	0	0	0
	CDH26.7	206	0	0	0	0	3	27	110	66	0	0	0	0
Wind	WSAvg	3.4	3.9	4.5	3.8	3.2	3.0	3.0	2.7	2.6	2.9	3.7	3.7	3.7
Precipitation	PrecAvg	614	42	37	35	35	48	69	85	70	53	52	45	42
	PrecMax	743	82	64	79	69	79	108	185	161	134	144	73	77
	PrecMin	467	15	10	7	5	17	16	11	4	22	2	17	15
	PrecStd	78	18	15	17	18	16	25	43	41	28	29	17	14
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.6	9.1	16.2	25.3	26.9	29.7	31.9	30.9	24.7	19.9	13.2	9.1
		MCWB	6.3	7.2	9.5	15.5	17.8	21.4	21.8	21.1	17.0	15.4	11.8	8.1
	2%	DB	5.3	7.9	11.4	22.2	24.7	27.1	29.6	28.4	21.7	17.4	11.7	7.6
		MCWB	4.4	6.1	8.3	14.0	16.8	20.3	21.0	19.5	15.9	14.0	10.1	6.5
	5%	DB	4.0	6.9	8.5	18.8	22.8	24.5	27.5	26.5	19.6	15.7	10.1	6.4
		MCWB	3.2	5.6	6.0	12.6	16.1	18.0	20.0	18.5	15.4	13.1	8.8	5.6
	10%	DB	3.0	5.7	6.5	16.0	20.6	22.6	25.5	24.7	18.1	14.1	8.7	5.2
		MCWB	2.3	4.6	4.9	11.7	14.9	17.5	19.2	17.9	14.7	12.1	7.7	4.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.5	7.7	10.0	16.6	19.5	23.0	23.6	22.2	18.3	16.2	12.0	8.4
		MCDB	7.2	8.7	13.6	23.3	25.3	28.8	29.5	28.7	22.1	18.6	13.1	9.0
	2%	WB	4.7	6.6	8.4	15.0	17.7	20.6	21.8	20.7	16.9	14.5	10.3	6.7
		MCDB	5.4	7.5	11.6	20.2	23.1	25.7	27.4	26.4	19.6	16.8	11.7	7.3
	5%	WB	3.3	5.6	6.4	13.2	16.4	19.2	20.7	19.6	16.0	13.4	8.9	5.6
		MCDB	3.9	6.6	8.1	18.1	21.7	23.4	26.2	24.5	19.1	15.1	10.0	6.3
	10%	WB	2.4	4.7	5.0	11.8	15.3	17.9	19.6	18.6	15.1	12.2	7.7	4.5
		MCDB	3.0	5.7	6.3	15.9	20.0	21.7	24.5	23.3	17.5	13.9	8.6	5.2
Mean Daily Temperature Range	5% DB	MDBR	4.2	5.1	6.4	9.0	11.1	9.5	10.5	10.7	8.2	6.4	4.5	4.1
		MCDBR	4.3	5.0	9.1	13.6	13.8	13.4	13.8	14.0	9.8	8.6	5.0	4.0
		MCWBR	3.8	4.0	6.2	6.9	7.5	7.2	6.6	6.2	5.5	5.5	4.2	3.7
	5% WB	MCDBR	4.3	4.7	8.2	12.3	12.6	12.0	12.3	11.5	8.7	7.7	5.0	4.1
		MCWBR	4.0	4.1	6.3	7.1	7.1	7.0	6.5	5.7	5.4	5.5	4.3	3.9
Clear-Sky Solar Irradiance	taub	0.300	0.331	0.368	0.409	0.397	0.391	0.427	0.421	0.382	0.358	0.340	0.300	
	taud	2.206	2.194	2.216	2.189	2.280	2.324	2.247	2.262	2.345	2.392	2.285	2.238	
	Ebn at Noon	623	734	795	811	847	856	813	792	777	708	572	541	
	Edh at Noon	61	88	108	127	123	119	126	118	95	73	58	49	
All-Sky Solar Radiation	RadAvg	0.58	1.32	2.58	4.09	5.35	5.56	5.16	4.33	3.04	1.51	0.56	0.38	
	RadStd	0.11	0.24	0.38	0.54	0.53	0.45	0.52	0.42	0.35	0.28	0.06	0.05	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)		+0.42	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+64	N/A

Nomenclature: See separate page