

SLUTSK, Belarus

WMO: 269510

Lat: 53.0537N

Lon: 27.5444E

Elev: 531

StdP: 14.42

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.7	0.8	-10.1	3.3	-4.6	-4.0	4.5	1.6	25.2	33.2	23.0	32.3	3.9	0	0.552

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.4	84.8	68.4	81.5	67.1	78.4	65.7	70.8	81.3	68.9	78.3	67.2	75.8	6.3	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.1	101.7	75.6	65.5	96.1	73.5	63.9	90.8	71.7	35.0	81.9	33.3	78.4	32.0	75.8	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
21.2	18.5	16.2	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-12.6	89.1	6.5	3.2	-17.3	91.4	-21.1	93.3	-24.8	95.1	-29.6	97.5
			-13.0	73.3	6.5	1.8	-17.6	74.5	-21.4	75.6	-25.0	76.6	-29.7	77.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	45.0	23.6	25.3	33.6	46.8	56.0	61.7	66.0	64.1	54.7	44.5	35.5	27.2	(6)
(7)		DBStd	17.06	10.99	10.81	8.76	7.78	7.66	6.29	5.67	5.87	6.36	7.38	8.61	10.23	(7)
(8)		HDD50	3572	820	691	509	149	30	1	0	27	202	436	707		(8)
(9)		HDD65	7494	1285	1111	972	545	294	139	55	89	313	635	884	1172	(9)
(10)		CDD50	1755	0	0	2	54	215	351	497	436	167	31	2	0	(10)
(11)		CDD65	206	0	0	0	1	14	40	88	60	3	0	0	0	(11)
(12)		CDH74	1833	0	0	0	9	147	323	786	528	40	0	0	0	(12)
(13)		CDH80	429	0	0	0	0	25	57	206	139	2	0	0	0	(13)
(14)	Wind	WSAvg	7.2	8.6	8.4	8.4	7.3	6.6	6.4	5.3	5.5	6.0	7.5	7.9	8.5	(14)
(15)	Precipitation	PrecAvg	24.9	1.7	1.4	1.5	1.5	2.5	3.1	3.4	2.4	2.0	1.9	1.8	1.7	(15)
(16)		PrecMax	33.5	2.8	3.1	3.0	3.6	4.5	8.4	8.8	7.4	5.4	6.8	3.5	2.8	(16)
(17)		PrecMin	18.9	0.2	0.7	0.6	0.2	1.1	0.8	0.3	0.2	0.2	0.1	0.3	0.7	(17)
(18)		PrecStd	4.3	0.7	0.6	0.6	0.7	1.1	1.7	2.0	1.7	1.2	1.5	0.7	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.7	45.5	59.3	74.9	83.3	85.6	89.6	90.6	78.9	69.2	55.5	46.8	(19)
(20)			MCWB	41.9	42.2	48.8	58.5	66.4	68.4	70.2	70.4	62.1	59.9	51.9	45.3	(20)
(21)		2%	DB	39.6	41.4	54.0	69.1	78.3	81.8	85.5	83.5	73.7	62.4	51.8	43.6	(21)
(22)			MCWB	38.1	39.3	45.7	55.1	64.0	67.6	68.7	67.8	61.3	56.2	49.7	42.4	(22)
(23)		5%	DB	37.4	38.9	49.0	64.6	73.8	78.1	81.9	79.7	69.7	58.4	48.8	41.2	(23)
(24)			MCWB	36.1	37.3	43.1	52.6	61.3	65.7	68.0	65.7	59.6	53.9	46.9	40.0	(24)
(25)		10%	DB	35.3	36.5	45.0	60.5	70.0	74.2	78.5	76.0	66.1	55.3	46.3	38.1	(25)
(26)			MCWB	34.2	35.1	41.0	50.4	58.8	63.7	66.7	64.6	57.5	52.1	44.8	37.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.1	42.8	50.1	60.3	68.3	71.8	73.4	72.9	64.8	61.3	53.0	45.6	(27)
(28)			MDCB	43.4	45.0	57.5	71.5	79.3	81.3	83.6	84.1	74.1	67.7	54.8	46.2	(28)
(29)		2%	WB	38.6	39.8	46.3	56.7	65.3	69.0	71.3	69.9	62.5	57.2	49.9	42.7	(29)
(30)			MDCB	39.5	41.2	51.9	65.8	76.1	78.2	82.1	80.1	71.1	60.5	51.7	43.5	(30)
(31)		5%	WB	36.2	37.5	43.8	54.1	63.0	67.2	69.4	68.0	60.6	54.6	47.2	40.2	(31)
(32)			MDCB	37.2	38.6	48.4	62.3	71.9	75.9	78.8	76.8	67.4	58.0	48.6	41.2	(32)
(33)		10%	WB	34.4	35.3	41.1	51.7	60.6	65.2	67.6	66.0	58.9	51.9	44.8	37.2	(33)
(34)			MDCB	35.2	36.3	44.8	58.1	67.7	72.5	76.2	72.8	64.7	55.0	46.1	38.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.7	8.9	12.0	17.0	18.5	17.4	18.4	19.0	17.0	12.3	7.3	7.0	(35)
(36)			MCDBR	5.8	8.3	18.0	24.1	24.0	22.1	23.3	24.3	22.9	17.2	10.6	7.0	(36)
(37)			MCWBR	5.5	6.9	11.4	12.5	12.0	10.4	9.9	10.3	12.1	11.1	8.3	6.5	(37)
(38)		5% WB	MCDBR	5.6	7.9	16.3	21.1	21.3	19.5	21.1	20.8	19.8	15.3	9.4	7.0	(38)
(39)			MCWBR	5.6	6.8	10.9	11.7	11.6	10.1	10.2	9.9	11.5	10.5	7.8	6.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.295	0.331	0.364	0.415	0.406	0.392	0.421	0.422	0.385	0.355	0.337	0.298	(40)	
(41)		taud	2.171	2.119	2.168	2.170	2.263	2.330	2.258	2.252	2.312	2.377	2.271	2.212	(41)	
(42)		Ebn at Noon	210	237	256	258	267	273	261	253	248	231	193	185	(42)	
(43)		Edh at Noon	22	31	37	42	40	38	40	38	32	24	20	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	229	478	898	1314	1671	1804	1697	1464	993	523	196	142	(44)	
(45)		RadStd	40	89	132	151	162	132	160	128	109	98	21	37	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) +1.80	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (9 neighbors)	+0.90	N/A	N/A	N/A	N/A	+1.53	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page