

SAKHUNYA, Russian Federation

WMO: 273730

Lat: 57.667N

Lon: 46.633E

Elev: 175

StdP: 99.24

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-28.3	-25.0	-31.2	0.2	-28.1	-27.6	0.3	-24.8	10.0	-6.5	9.3	-7.4	2.4	320	0.616

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	28.8	20.2	27.0	19.3	25.2	18.3	21.2	27.1	20.2	25.4	19.3	24.0	3.3	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.1	14.2	23.6	18.3	13.5	22.9	17.4	12.7	22.1	62.0	27.1	58.8	25.5	55.7	23.9	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.9	7.9	7.1	-30.7	31.1	4.2	1.9	-33.6	32.5	-36.1	33.5	-38.4	34.6	-41.4	35.9		
(5)			-30.8	22.8	4.1	1.2	-33.8	23.6	-36.2	24.3	-38.5	25.0	-41.5	25.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.6	-11.2	-10.2	-4.0	4.3	11.7	15.7	18.4	16.1	10.5	3.4	-3.5	-8.6	(6)
(7)		DBStd	11.70	7.29	6.93	4.65	5.05	5.08	4.39	3.78	4.16	4.29	4.39	5.60	7.20	(7)
(8)		HDD10.0	3123	657	564	433	182	42	6	1	3	44	209	404	578	(8)
(9)		HDD18.3	5471	916	798	692	421	211	102	47	95	237	463	654	836	(9)
(10)		CDD10.0	798	0	0	0	12	95	177	259	191	59	4	0	0	(10)
(11)		CDD18.3	104	0	0	0	0	6	23	48	26	2	0	0	0	(11)
(12)		CDH23.3	862	0	0	0	0	65	204	389	191	12	0	0	0	(12)
(13)		CDH26.7	197	0	0	0	0	9	43	93	51	1	0	0	0	(13)
(14)	Wind	WSAvg	3.4	3.9	4.0	3.9	3.6	3.4	3.0	2.6	2.8	2.9	3.5	3.7	3.9	(14)
(15)	Precipitation	PrecAvg	600	37	25	29	32	49	72	82	62	58	62	49	42	(15)
(16)		PrecMax	781	77	52	85	111	106	125	242	136	105	182	100	65	(16)
(17)		PrecMin	372	18	9	7	7	17	18	9	5	9	15	5	12	(17)
(18)		PrecStd	94	14	12	16	23	22	31	61	33	28	33	20	13	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.2	2.2	8.6	21.6	28.0	30.3	31.7	31.1	24.9	17.4	9.1	4.8	(19)
(20)			MCWB	0.7	0.9	4.4	12.3	17.8	20.7	21.1	21.0	16.1	11.6	7.9	4.6	(20)
(21)		2%	DB	0.4	0.8	5.1	18.3	25.1	27.7	29.0	27.6	22.0	13.4	6.2	2.2	(21)
(22)			MCWB	0.0	0.1	1.9	10.4	15.6	19.3	20.5	19.8	15.7	9.8	5.5	1.6	(22)
(23)		5%	DB	-0.2	0.1	3.4	15.0	22.7	25.7	27.3	25.2	19.5	11.1	4.4	0.7	(23)
(24)			MCWB	-0.6	-0.4	1.0	8.8	14.5	18.5	19.7	18.7	14.4	9.0	3.8	0.2	(24)
(25)		10%	DB	-1.5	-0.8	2.0	12.3	20.3	23.7	25.5	23.0	17.2	9.5	2.7	0.0	(25)
(26)			MCWB	-1.9	-1.4	0.3	7.4	13.1	17.3	19.0	17.5	13.4	8.2	2.1	-0.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.8	1.2	4.6	13.2	19.1	21.9	22.4	22.0	18.0	12.8	7.8	4.6	(27)
(28)			MCDWB	0.9	1.6	8.1	19.7	26.5	28.5	28.3	29.3	22.3	15.8	8.7	4.8	(28)
(29)		2%	WB	0.2	0.3	2.6	11.2	17.2	20.6	21.3	20.7	16.2	10.6	5.7	1.8	(29)
(30)			MCDWB	0.4	0.7	4.3	16.6	23.3	26.2	27.1	26.3	20.4	12.4	6.1	2.1	(30)
(31)		5%	WB	-0.6	-0.3	1.5	9.4	15.6	19.4	20.5	19.4	14.9	9.4	3.9	0.4	(31)
(32)			MCDWB	-0.3	0.1	2.9	14.6	20.7	24.2	25.8	24.0	18.6	10.8	4.2	0.7	(32)
(33)		10%	WB	-1.9	-1.4	0.5	7.6	14.1	18.2	19.6	18.3	13.6	8.2	2.2	-0.3	(33)
(34)			MCDWB	-1.6	-0.8	1.7	11.7	19.0	22.4	24.3	22.2	16.9	9.4	2.6	0.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.3	6.3	6.8	8.2	10.4	9.9	9.5	9.1	8.0	5.2	4.0	4.8	(35)
(36)			MCDBR	4.2	4.8	7.4	11.9	13.3	12.3	11.9	11.7	11.6	8.2	4.8	3.4	(36)
(37)			MCWBR	4.1	4.6	5.2	6.5	6.4	5.8	5.3	5.1	6.1	5.2	4.5	3.4	(37)
(38)		5% WB	MCDBR	4.1	4.5	6.1	11.0	11.8	10.8	10.6	10.5	7.0	4.6	3.6	(38)	
(39)			MCWBR	4.2	4.5	4.7	6.5	6.5	5.8	5.2	5.1	5.9	5.1	4.5	3.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.276	0.308	0.347	0.392	0.369	0.366	0.395	0.405	0.357	0.338	0.300	0.267	(40)	
(41)		taud	2.063	2.063	2.031	2.130	2.375	2.413	2.345	2.297	2.415	2.347	2.186	2.027	(41)	
(42)		Ebn at Noon	549	704	779	810	866	873	835	794	785	683	525	432	(42)	
(43)		Edh at Noon	56	89	121	130	109	107	112	110	84	68	50	43	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.47	1.26	2.68	3.98	5.30	5.65	5.61	4.28	2.53	1.10	0.41	0.27	(44)	
(45)		RadStd	0.07	0.28	0.31	0.39	0.39	0.41	0.53	0.47	0.33	0.17	0.07	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.51	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+98	N/A
(47) Regional (6 neighbors)		+0.52	N/A	N/A	N/A	N/A	N/A	N/A	-154	N/A	N/A

Nomenclature: See separate page