

TVER, Russian Federation

WMO: 274020

Lat: 56.830N

Lon: 35.752E

Elev: 146

StdP: 99.59

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.9	-21.6	-27.3	0.3	-24.8	-24.0	0.4	-21.4	8.8	-2.5	7.9	-3.4	0.8	100	0.549

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	29.8	19.5	27.7	19.0	25.8	18.2	20.9	27.1	20.0	25.7	19.1	24.4	2.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	13.9	23.3	18.0	13.2	22.4	17.1	12.4	21.4	61.1	27.2	57.9	25.9	54.8	24.7	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.9	7.0	6.0	-29.1	31.8	3.2	2.4	-31.4	33.5	-33.3	34.9	-35.1	36.2	-37.5	37.9		
			-29.2	22.5	3.2	1.6	-31.5	23.7	-33.4	24.7	-35.2	25.6	-37.5	26.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.5	-7.6	-7.3	-1.9	6.1	12.4	16.5	19.4	16.9	11.2	5.2	-0.9	-5.2	(6)
(7)		DBStd	10.70	6.99	7.12	4.88	4.70	4.86	3.77	3.30	3.57	3.68	4.22	5.35	6.65	(7)
(8)		HDD10.0	2550	545	483	370	137	31	1	0	1	29	156	328	471	(8)
(9)		HDD18.3	4816	803	717	628	368	193	79	27	72	216	406	577	729	(9)
(10)		CDD10.0	894	0	0	0	18	104	196	291	213	64	8	0	0	(10)
(11)		CDD18.3	119	0	0	0	0	8	26	59	26	1	0	0	0	(11)
(12)		CDH23.3	1087	0	0	0	3	93	230	512	240	8	0	0	0	(12)
(13)		CDH26.7	297	0	0	0	0	24	57	148	68	0	0	0	0	(13)
(14)	Wind	WSAvg	2.3	2.4	2.5	2.5	2.4	2.4	2.2	1.9	1.9	2.4	2.5	2.5	(14)	
(15)	Precipitation	PrecAvg	665	44	39	32	32	63	76	80	75	62	67	52	43	(15)
(16)		PrecMax	925	76	72	56	67	172	145	226	174	151	163	108	80	(16)
(17)		PrecMin	447	11	11	8	8	22	4	3	8	30	17	2	18	(17)
(18)		PrecStd	128	15	16	13	14	32	32	53	40	29	35	25	16	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.5	4.5	12.5	23.1	29.7	30.7	33.4	32.0	24.8	18.3	10.4	7.5	(19)
(20)		MCWB	3.6	2.9	7.3	13.5	18.7	19.6	21.2	20.2	17.4	13.3	9.0	6.7	(20)	
(21)		2%	DB	2.4	3.0	8.5	20.1	25.9	28.3	30.2	28.2	21.6	14.7	8.2	5.2	(21)
(22)		MCWB	1.6	1.6	4.4	11.4	16.8	19.0	20.0	19.2	15.7	11.6	7.0	4.5	(22)	
(23)		5%	DB	1.5	2.1	6.0	17.1	23.1	26.0	28.1	25.9	19.2	12.6	6.8	3.4	(23)
(24)		MCWB	0.8	0.9	3.1	10.1	15.1	17.9	19.4	18.4	14.5	10.6	5.9	2.6	(24)	
(25)		10%	DB	0.7	1.2	4.2	14.6	20.7	23.8	26.1	23.6	17.2	11.1	5.4	2.0	(25)
(26)		MCWB	0.1	0.4	1.9	8.9	13.7	17.0	18.7	17.3	13.8	9.5	4.6	1.3	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.8	3.4	7.6	14.1	20.3	21.3	22.7	21.6	18.5	14.1	9.4	6.7	(27)
(28)		MADB	4.2	4.1	12.1	22.0	28.0	27.8	29.2	28.3	22.6	16.5	10.1	7.1	(28)	
(29)		2%	WB	1.8	2.0	4.9	12.2	17.7	20.1	21.2	20.3	16.6	12.2	7.3	4.6	(29)
(30)		MADB	2.3	2.6	7.3	17.8	23.6	26.2	27.4	26.0	19.9	14.1	8.0	5.2	(30)	
(31)		5%	WB	0.9	1.2	3.4	10.8	16.2	19.0	20.3	19.1	15.3	10.9	6.0	2.7	(31)
(32)		MADB	1.4	1.8	5.3	15.9	21.5	24.1	25.9	24.4	18.4	12.5	6.6	3.2	(32)	
(33)		10%	WB	0.1	0.5	2.2	9.4	14.7	17.8	19.4	18.0	14.1	9.7	4.6	1.4	(33)
(34)		MADB	0.6	1.2	3.8	14.2	19.4	22.2	24.7	22.2	16.8	11.0	5.3	1.9	(34)	
(35)	Mean Daily Temperature Range	MDBR	5.2	6.5	7.6	9.7	10.4	9.5	9.9	9.5	8.5	6.0	4.2	4.3	(35)	
(36)		5% DB	MCDBR	3.5	4.6	9.6	13.9	13.7	13.0	13.2	13.3	12.0	8.6	5.2	3.5	(36)
(37)		MCWBR	3.6	3.9	6.5	7.0	6.1	5.8	5.2	5.4	6.5	5.7	4.6	3.5	(37)	
(38)		5% WB	MCDBR	3.5	4.2	8.0	12.1	12.3	11.2	11.2	11.4	10.3	7.4	4.7	3.4	(38)
(39)		MCWBR	3.7	3.9	5.7	6.7	6.1	5.8	5.2	5.3	6.1	5.3	4.4	3.3	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.283	0.322	0.341	0.397	0.386	0.371	0.408	0.411	0.369	0.346	0.317	0.278	(40)	
(41)		taud	2.116	2.073	2.148	2.192	2.336	2.398	2.311	2.292	2.384	2.373	2.240	2.125	(41)	
(42)		Ebn at Noon	575	699	802	812	851	870	824	793	777	690	537	473	(42)	
(43)		Edh at Noon	57	91	110	124	114	109	117	112	88	69	52	44	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.50	1.32	2.82	3.98	5.22	5.44	5.33	4.21	2.68	1.20	0.44	0.27	(44)	
(45)		RadStd	0.09	0.20	0.33	0.40	0.45	0.52	0.60	0.42	0.36	0.23	0.07	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-243	N/A	N/A
(47)	Regional (9 neighbors)	+0.69	N/A	N/A	N/A	N/A	N/A	-153	-223	N/A	N/A

Nomenclature: See separate page