

KOZ'MODEM'YANSK, Russian Federation

WMO: 274790

Lat: 56.333N

Lon: 46.583E

Elev: 352

StdP: 14.51

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.3	-9.5	-20.6	1.8	-14.8	-15.0	2.5	-8.7	18.8	20.1	17.6	18.7	3.6	320	0.531

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.3	85.3	68.7	82.2	68.0	79.3	66.5	71.2	81.4	69.6	79.3	68.0	76.9	5.0	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.6	102.9	76.4	66.1	97.4	74.8	64.6	92.2	73.5	35.2	81.6	33.8	79.2	32.5	77.0	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min		Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.8	15.0	13.5	DB	-19.6	89.1	6.6	3.4	-24.4	91.6	-28.3	93.6	-32.0	95.5	-36.8	98.0
			WB	-20.0	73.6	6.5	2.3	-24.6	75.3	-28.5	76.6	-32.1	77.9	-36.9	79.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	41.6	14.5	15.6	26.7	42.6	56.9	64.3	68.8	64.8	54.4	41.6	28.4	18.9	(6)	
(7)		DBStd	21.55	12.64	12.35	8.15	9.18	9.29	7.86	6.63	7.36	7.72	7.98	9.85	12.13	(7)	
(8)		HDD50	5018	1101	963	721	259	39	3	0	0	41	281	647	963	(8)	
(9)		HDD65	8909	1566	1383	1186	673	282	107	37	94	329	727	1097	1428	(9)	
(10)		CDD50	1954	0	0	0	36	253	432	582	460	172	19	0	0	(10)	
(11)		CDD65	370	0	0	0	0	31	86	154	89	10	0	0	0	(11)	
(12)		CDH74	2266	0	0	0	1	178	548	985	524	30	0	0	0	(12)	
(13)		CDH80	546	0	0	0	0	29	127	243	144	3	0	0	0	(13)	
(14)	Wind	WSAvg	6.5	6.9	6.9	6.9	6.3	6.4	5.7	5.0	5.4	6.0	7.2	7.3	7.3	(14)	
(15)	Precipitation	PrecAvg	23.8	1.7	1.5	1.5	1.3	1.6	2.7	2.8	2.3	2.2	2.1	2.0	1.9	(15)	
(16)		PrecMax	29.5	3.7	2.9	2.8	3.2	2.6	6.5	5.7	4.8	4.5	4.1	3.5	3.5	(16)	
(17)		PrecMin	17.0	0.7	0.6	0.2	0.3	0.6	0.6	0.5	0.0	0.5	0.1	0.6	0.7	(17)	
(18)		PrecStd	2.8	0.6	0.6	0.7	0.8	0.6	1.5	1.4	1.3	1.1	1.1	0.7	0.6	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.5	37.1	48.3	71.2	83.6	88.1	90.8	90.3	77.8	64.7	51.2	41.9	(19)	
(20)		MCWB	34.8	34.1	41.0	55.3	65.3	69.3	69.8	70.1	62.4	54.4	47.9	40.2	40.2	(20)	
(21)		2%	DB	34.6	35.4	42.7	65.7	78.9	83.5	85.4	83.8	73.0	59.4	46.0	37.7	(21)	
(22)		MCWB	33.2	33.5	36.7	51.6	62.6	68.0	69.2	68.9	61.0	52.0	43.6	36.1	36.1	(22)	
(23)		5%	DB	33.2	33.9	39.3	61.4	74.8	80.2	82.3	79.2	69.4	55.5	42.7	35.2	(23)	
(24)		MCWB	32.1	32.6	34.7	49.8	60.4	66.7	68.8	67.0	59.4	50.1	40.8	33.8	33.8	(24)	
(25)		10%	DB	31.4	32.2	36.9	57.0	70.9	76.7	79.6	76.0	65.7	52.5	39.4	33.6	(25)	
(26)		MCWB	30.3	31.0	33.7	47.5	58.0	64.5	67.5	65.4	57.6	48.5	37.8	32.4	32.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.1	35.2	42.0	56.1	67.3	72.3	73.8	72.5	64.8	56.1	47.9	40.5	(27)	
(28)		MADB	35.9	36.1	48.0	67.5	80.7	83.4	83.6	83.8	73.2	61.1	50.0	41.4	41.4	(28)	
(29)		2%	WB	33.6	33.8	37.5	53.2	64.3	69.9	71.5	70.5	62.3	53.1	44.2	36.3	(29)	
(30)		MADB	34.4	34.7	41.1	62.5	76.4	80.1	81.4	80.8	70.5	57.6	46.1	37.3	37.3	(30)	
(31)		5%	WB	32.2	32.7	35.7	50.8	61.8	68.0	70.1	68.5	60.2	50.7	40.9	34.1	(31)	
(32)		MADB	33.2	33.9	38.4	60.5	72.3	77.2	79.6	77.4	67.4	54.7	42.5	34.9	34.9	(32)	
(33)		10%	WB	30.2	31.0	34.0	47.8	59.7	66.0	68.6	66.5	58.3	48.7	37.9	32.5	(33)	
(34)		MADB	31.4	32.4	36.4	56.4	69.2	75.5	77.6	74.1	64.6	52.2	39.3	33.5	33.5	(34)	
(35)	Mean Daily Temperature Range	MDBR	9.2	10.4	10.6	13.1	14.7	13.7	13.3	13.0	11.0	8.1	6.7	8.0	8.0	(35)	
(36)		5% DB	MADB	7.1	7.8	11.6	18.9	18.4	16.9	16.3	16.6	15.8	12.2	8.6	6.7	6.7	(36)
(37)		MCWBR	7.1	7.4	8.1	9.9	8.9	7.9	7.2	7.3	8.1	7.9	7.8	6.2	6.2	(37)	
(38)		5% WB	MADB	7.1	7.5	10.2	18.0	17.2	15.5	14.3	15.2	14.1	11.2	8.1	6.6	6.6	(38)
(39)		MCWBR	7.0	7.3	8.0	10.2	9.1	8.1	7.4	7.6	8.2	8.3	7.8	6.6	6.6	(39)	
(40)		Clear-Sky Solar Irradiance	taub	0.286	0.318	0.355	0.404	0.381	0.376	0.404	0.425	0.371	0.350	0.313	0.282	0.282	(40)
(41)	taud		2.078	2.059	2.031	2.143	2.356	2.406	2.335	2.253	2.389	2.338	2.214	2.059	2.059	(41)	
(42)	Ebn at Noon		183	226	248	256	272	275	263	247	247	218	175	149	149	(42)	
(43)	Edh at Noon		19	30	40	42	36	35	36	37	28	23	17	16	16	(43)	
(44)	All-Sky Solar Radiation	RadAvg	180	455	925	1289	1725	1839	1813	1408	854	390	153	99	99	(44)	
(45)		RadStd	28	90	105	131	118	147	162	140	103	61	27	24	24	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		+1.10	N/A	N/A	N/A	N/A	N/A	-274	-355	N/A	N/A	
(47)	Regional (8 neighbors)		+1.01	N/A	N/A	N/A	N/A	-238	-320	N/A	N/A	(47)

Nomenclature: See separate page