

MOSKVA SHEREMETYEVO, Russian Federation

WMO: 275155

Lat: 55.973N

Lon: 37.415E

Elev: 622

StdP: 14.37

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.9	-4.4	-16.5	2.3	-10.4	-10.9	3.1	-4.4	22.3	25.6	20.4	24.5	5.9	70	0.631

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.9	85.9	66.6	82.4	65.3	78.9	64.5	69.2	78.9	67.4	77.3	66.0	76.0	9.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.1	98.5	73.1	64.3	92.4	71.7	62.6	86.8	69.9	33.6	78.7	32.3	76.9	31.1	76.1	76.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.7	18.5	16.6	-15.8	88.9	6.9	4.3	-20.7	92.0	-24.7	94.5	-28.6	96.9	-33.5	100.0		
			-16.1	71.8	6.8	1.9	-21.0	73.2	-25.0	74.3	-28.8	75.4	-33.8	76.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	42.1	18.5	19.1	28.5	43.2	55.0	61.6	66.7	63.0	53.0	41.6	30.6	22.6
	DBStd	19.27	11.82	11.96	8.68	8.66	8.73	7.13	6.24	6.65	7.15	7.76	9.48	11.49
	HDD50	4553	975	865	665	240	49	3	0	0	48	276	584	848
	HDD65	8589	1440	1285	1130	654	326	149	54	117	363	725	1033	1313
	CDD50	1670	0	0	0	36	204	351	518	405	138	17	1	0
	CDD65	230	0	0	0	0	16	47	107	57	3	0	0	0
	CDH74	2125	0	0	0	5	172	459	935	523	31	0	0	0
	CDH80	582	0	0	0	0	35	109	285	152	1	0	0	0
Wind	WSAvg	8.8	9.3	9.3	9.3	8.6	8.6	8.3	7.7	7.8	7.9	9.0	9.3	9.9
Precipitation	PrecAvg	26.2	1.9	1.5	1.4	1.3	2.2	2.8	3.1	2.9	2.6	2.6	2.0	1.8
	PrecMax	34.6	3.3	3.1	2.9	2.2	4.6	4.6	6.6	5.7	7.3	5.3	3.4	3.1
	PrecMin	17.2	0.6	0.3	0.6	0.5	0.7	0.4	0.5	0.5	0.6	0.6	0.1	0.6
	PrecStd	4.3	0.7	0.6	0.6	0.5	1.0	1.0	1.6	1.5	1.3	1.4	0.7	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.1	37.8	55.3	73.7	84.3	87.4	92.8	91.3	77.4	65.9	52.2	46.0
		MCWB	38.0	35.3	45.2	55.6	63.9	65.4	67.0	66.7	62.1	55.5	49.5	45.3
	2%	DB	35.8	36.1	48.0	68.2	78.8	82.8	86.2	84.0	73.3	60.4	47.8	41.0
		MCWB	34.8	34.4	39.8	52.7	62.0	64.9	67.2	66.1	60.6	54.1	46.3	40.0
	5%	DB	34.1	35.4	42.9	63.0	73.8	79.2	82.6	79.2	68.4	55.7	44.6	37.5
		MCWB	33.3	33.9	37.2	50.2	58.9	64.2	66.0	65.0	58.7	51.1	43.3	36.5
	10%	DB	32.4	33.9	39.3	58.8	70.1	75.4	79.0	75.5	64.6	52.2	41.3	35.3
		MCWB	31.5	32.8	35.4	47.7	57.2	62.2	65.4	63.4	57.2	48.8	40.2	34.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.7	36.7	45.3	57.1	66.0	70.4	72.8	70.2	64.8	57.6	50.5	44.6
		MCDB	38.1	37.2	53.5	71.9	79.6	81.4	83.9	81.5	73.1	61.6	52.5	45.0
	2%	WB	34.7	34.9	40.7	54.0	63.7	67.6	69.9	67.9	61.9	54.6	45.8	39.6
		MCDB	35.1	35.6	45.7	65.2	75.8	77.8	78.8	78.3	69.8	59.4	46.6	40.3
	5%	WB	33.1	33.6	37.8	51.5	61.4	65.7	68.0	66.3	59.9	52.2	43.1	36.5
		MCDB	33.7	34.3	41.0	60.9	71.2	75.9	77.3	77.1	66.6	55.9	43.8	37.1
	10%	WB	31.6	32.6	35.9	49.3	59.0	63.6	66.8	64.6	57.9	49.7	40.1	33.8
		MCDB	32.3	33.5	38.8	57.3	67.1	72.8	76.1	73.7	64.1	51.8	40.9	34.3
Mean Daily Temperature Range	5% DB	MDBR	9.0	11.1	13.1	17.2	19.1	18.2	17.9	17.7	15.1	10.7	7.5	7.8
		MCDBR	6.4	8.0	17.0	24.4	24.0	23.5	23.3	23.4	21.4	16.1	9.9	6.4
		MCWBR	6.7	7.6	11.2	12.3	10.7	9.9	8.4	9.4	10.9	10.7	8.9	6.4
	5% WB	MCDBR	6.5	7.0	13.7	22.1	20.8	20.5	19.2	20.2	18.5	14.4	8.3	6.3
		MCWBR	7.0	7.3	9.9	12.3	10.2	9.8	8.6	9.3	10.3	10.2	8.2	6.4
Clear-Sky Solar Irradiance	taub	0.292	0.335	0.349	0.421	0.402	0.387	0.433	0.438	0.388	0.358	0.323	0.287	
	taud	2.115	2.068	2.115	2.115	2.299	2.362	2.253	2.222	2.343	2.354	2.228	2.111	
	Ebn at Noon	186	221	253	251	266	272	255	244	241	217	175	155	
	Edh at Noon	19	30	37	43	38	36	40	38	30	23	18	15	
All-Sky Solar Radiation	RadAvg	181	451	937	1269	1662	1734	1705	1367	870	396	152	96	
	RadStd	36	62	93	115	153	167	183	144	115	70	26	28	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+1.49	N/A	N/A	N/A	N/A	N/A	-324	-455	N/A	N/A
Regional (10 neighbors)		+1.30	N/A	N/A	N/A	N/A	N/A	-265	-394	+198	N/A

Nomenclature: See separate page