

ALATYR, Russian Federation

WMO: 276790

Lat: 54.817N

Lon: 46.583E

Elev: 591

StdP: 14.38

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.8	-10.0	-20.4	1.8	-15.6	-14.8	2.5	-9.6	24.6	15.7	22.3	23.6	6.6	270	0.577

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.4	87.5	67.5	83.8	66.2	80.8	65.0	69.9	82.5	68.3	80.4	66.7	77.9	6.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.8	97.3	74.7	63.9	90.9	73.1	62.4	86.1	72.5	34.1	82.3	32.8	80.5	31.6	78.0	77.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
22.3	18.9	16.6	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-19.8	92.0	6.1	3.4	-24.2	94.4	-27.7	96.5	-31.2	98.4	-35.6	100.9
			-20.1	73.5	6.0	2.0	-24.4	74.9	-27.9	76.1	-31.3	77.3	-35.7	78.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	41.1	13.6	14.6	25.3	43.0	57.1	64.0	68.2	64.8	53.9	41.3	28.0	18.1	
	DBStd	21.84	12.36	12.21	8.47	9.69	9.30	7.80	6.50	7.37	7.94	8.33	9.73	12.22	
	HDD50	5165	1128	992	766	255	38	3	0	0	47	288	661	987	
	HDD65	9062	1593	1412	1231	661	276	112	41	95	344	734	1111	1452	
	CDD50	1930	0	0	0	44	258	422	565	459	163	19	0	0	
	CDD65	353	0	0	0	0	31	81	141	89	11	0	0	0	
	CDH74	2937	0	0	0	6	296	664	1148	737	86	0	0	0	
	CDH80	871	0	0	0	0	59	197	364	238	13	0	0	0	
Wind	WSAvg	7.6	8.5	8.6	8.4	7.9	7.6	6.9	5.9	6.2	6.5	7.8	8.1	8.8	
Precipitation	PrecAvg	18.5	1.2	0.9	1.1	1.1	1.4	2.3	2.1	2.1	2.0	1.6	1.5	1.3	
	PrecMax	24.6	2.2	2.1	3.0	2.7	2.3	5.0	4.7	4.3	5.7	2.8	2.9	2.5	
	PrecMin	11.4	0.4	0.2	0.1	0.1	0.3	0.4	0.2	0.4	0.3	0.6	0.4	0.4	
	PrecStd	3.3	0.4	0.5	0.6	0.7	0.5	1.2	1.0	1.1	1.4	0.6	0.6	0.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.5	36.1	48.3	74.4	85.4	90.9	93.3	93.4	81.9	66.4	50.8	40.0	
		MCWB	33.8	33.7	42.1	57.4	63.1	67.6	67.2	68.7	62.9	55.5	47.6	38.7	
	2%	DB	33.7	34.4	41.5	68.9	81.0	85.2	87.4	85.8	75.9	60.7	46.2	36.5	
		MCWB	32.6	32.9	37.1	54.3	62.2	66.1	67.9	67.7	61.4	52.0	44.0	35.1	
	5%	DB	32.2	33.1	37.9	63.7	77.3	81.4	83.8	81.6	71.1	56.2	42.5	34.6	
		MCWB	31.2	31.9	34.6	51.5	60.6	65.0	67.5	65.7	59.3	50.6	41.0	33.4	
	10%	DB	30.3	31.3	35.7	58.5	72.9	77.2	80.5	77.5	66.6	52.6	39.4	32.9	
		MCWB	29.2	30.2	33.2	48.9	58.4	63.3	66.3	64.2	57.3	48.3	37.9	31.8	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	34.5	34.3	42.7	58.8	66.2	70.5	73.2	71.4	66.4	56.5	48.2	38.7
			MCDB	35.1	35.1	47.3	71.9	81.7	83.5	83.7	84.2	76.8	62.4	50.2	39.5
2%		WB	32.8	33.3	37.8	55.6	63.5	68.3	70.5	68.9	62.6	53.6	44.4	35.3	
		MCDB	33.5	34.2	40.8	66.8	77.7	80.8	81.9	82.5	72.6	59.4	45.9	36.1	
5%		WB	31.3	32.0	35.1	52.6	61.6	66.7	68.9	67.2	60.1	51.0	41.1	33.6	
		MCDB	32.3	33.0	37.1	62.1	75.0	78.2	80.3	79.1	70.0	55.4	42.4	34.4	
10%		WB	29.2	30.1	33.6	49.5	59.5	64.8	67.2	65.2	57.9	48.8	38.0	31.9	
		MCDB	30.3	31.4	35.3	57.8	71.2	75.0	78.3	75.1	65.5	52.2	39.2	32.8	
Mean Daily Temperature Range	5% DB	MDBR	9.5	11.5	11.6	16.0	18.3	17.3	17.4	17.4	15.0	11.2	8.0	8.7	
		MCDBR	7.7	8.1	12.7	23.7	23.5	22.2	22.3	22.9	22.7	17.7	10.4	6.3	
		MCWBR	7.4	7.4	9.5	13.4	11.0	9.9	9.8	9.6	11.5	11.2	9.4	6.2	
	5% WB	MCDBR	7.4	7.7	10.7	22.3	22.0	19.7	19.1	20.3	20.9	15.7	9.4	6.1	
		MCWBR	7.5	7.4	8.7	13.6	11.4	10.3	10.2	10.1	11.6	11.0	9.1	6.2	
Clear-Sky Solar Irradiance	taub	0.285	0.318	0.353	0.411	0.386	0.380	0.399	0.421	0.372	0.349	0.316	0.287		
	taud	2.096	2.059	2.040	2.129	2.328	2.378	2.327	2.252	2.371	2.345	2.241	2.088		
	Ebn at Noon	197	233	253	256	272	275	266	251	250	226	188	166		
	Edh at Noon	21	31	40	43	37	36	37	38	29	24	18	17		
All-Sky Solar Radiation	RadAvg	237	539	1024	1310	1740	1839	1836	1453	915	436	180	132		
	RadStd	34	65	99	136	121	168	171	136	129	73	33	35		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	+1.04	N/A	N/A	N/A	N/A	N/A	N/A	-286	N/A	N/A

Nomenclature: See separate page