

SUKHINICHI, Russian Federation

WMO: 277070

Lat: 54.100N

Lon: 35.350E

Elev: 238

StdP: 98.50

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.4	-20.4	-25.9	0.4	-23.0	-22.9	0.5	-20.1	8.5	-2.1	7.6	-4.1	1.4	270	0.529

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.3	28.9	20.3	27.0	19.4	25.3	18.7	21.2	27.0	20.3	25.6	19.4	24.2	2.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.4	23.9	18.4	13.6	23.1	17.5	12.9	22.2	62.4	27.1	59.3	25.7	56.4	24.3	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.4	6.2	5.4	DB	-26.6	31.3	3.4	2.1	-29.1	32.8	-31.0	34.1	-32.9	35.2	-35.3	36.8	(4)
(5)			WB	-26.8	22.6	3.3	1.0	-29.2	23.3	-31.1	23.9	-33.0	24.4	-35.4	25.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.8	-7.0	-6.9	-1.7	7.0	12.8	16.5	19.2	17.2	11.8	5.8	-0.6	-5.1	(6)	
	DBStd	10.55	6.19	6.68	4.64	4.84	4.71	3.66	3.31	3.60	3.89	4.21	5.16	6.33	(7)	
	HDD10.0	2460	528	474	362	116	26	1	0	0	25	142	318	469	(8)	
	HDD18.3	4687	786	707	621	340	178	78	29	64	199	388	568	728	(9)	
	CDD10.0	933	0	0	0	26	113	197	285	223	78	11	0	0	(10)	
	CDD18.3	118	0	0	0	8	23	56	29	2	0	0	0	0	(11)	
	CDH23.3	887	0	0	0	3	61	154	412	241	16	0	0	0	(12)	
	CDH26.7	213	0	0	0	1	7	24	107	74	1	0	0	0	(13)	
(14) Wind	WSAvg	2.2	2.5	2.6	2.5	2.2	2.0	1.9	1.7	1.8	1.8	2.3	2.5	2.6	(14)	
(15) Precipitation	PrecAvg	645	42	36	36	38	64	70	79	64	59	62	49	44	(15)	
	PrecMax	868	79	70	77	69	128	126	156	151	155	122	87	106	(16)	
	PrecMin	453	10	13	10	5	18	30	23	4	7	9	1	14	(17)	
	PrecStd	91	15	14	17	19	29	28	40	38	29	33	20	22	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.2	3.9	12.1	22.9	27.6	29.1	32.3	32.8	25.4	19.5	11.3	7.4	(19)	
		MCWB	3.2	2.1	6.8	13.1	18.5	20.4	21.0	19.8	17.2	13.0	9.4	6.7	(20)	
	2%	DB	2.2	2.6	8.6	19.7	25.1	27.0	29.4	28.4	22.6	15.9	8.6	5.2	(21)	
		MCWB	1.4	1.5	4.6	11.6	17.3	19.4	20.4	20.3	16.1	13.0	7.4	4.4	(22)	
	5%	DB	1.1	1.7	6.1	17.1	22.9	25.1	27.4	25.7	19.9	13.5	7.2	3.0	(23)	
		MCWB	0.5	0.8	3.1	10.5	15.7	18.5	20.0	18.9	14.8	11.1	6.3	2.5	(24)	
	10%	DB	0.2	1.0	4.2	14.8	20.9	23.2	25.5	23.5	17.9	11.7	5.7	1.5	(25)	
		MCWB	-0.3	0.4	2.1	9.3	14.4	17.7	19.4	17.7	13.9	9.8	5.0	1.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.6	3.0	7.3	13.9	19.7	21.6	22.4	22.0	18.2	14.9	10.0	6.8	(27)	
		MCDB	4.1	3.6	11.7	21.0	26.3	27.4	28.6	28.0	23.7	17.6	11.0	7.3	(28)	
	2%	WB	1.6	1.8	5.1	12.3	17.9	20.3	21.4	20.7	16.7	13.2	7.7	4.5	(29)	
		MCDB	2.0	2.2	7.9	17.9	23.6	25.5	27.4	26.6	20.9	15.4	8.2	5.1	(30)	
	5%	WB	0.6	1.1	3.6	11.2	16.5	19.3	20.6	19.6	15.5	11.5	6.5	2.5	(31)	
		MCDB	1.0	1.5	5.5	15.8	21.6	23.9	26.0	24.9	18.8	13.4	7.1	2.9	(32)	
	10%	WB	-0.2	0.4	2.4	9.9	15.3	18.2	19.8	18.4	14.3	10.1	5.0	1.1	(33)	
		MCDB	0.2	0.9	3.9	14.0	20.0	22.4	24.5	22.7	17.3	11.5	5.6	1.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.8	5.9	6.7	8.7	9.6	9.0	9.3	9.4	8.4	6.3	4.1	4.2	(35)	
		MCDBR	3.6	4.2	8.8	12.0	12.2	11.3	11.6	12.2	11.2	9.1	5.6	4.2	(36)	
	5% WB	MCWBR	3.6	3.8	5.8	6.0	6.0	5.7	4.9	5.5	5.8	6.0	4.8	3.9	(37)	
		MCWBR	3.4	4.1	7.7	10.7	10.8	10.3	10.5	11.2	10.0	8.2	4.9	4.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.288	0.324	0.346	0.414	0.390	0.378	0.413	0.424	0.382	0.351	0.326	0.291	(40)	
		taud	2.129	2.062	2.117	2.134	2.308	2.362	2.286	2.243	2.330	2.371	2.247	2.143	(41)	
	Ebn at Noon		641	737	817	807	856	870	829	792	780	720	596	550	(42)	
		Edh at Noon	67	100	119	135	120	115	122	120	97	75	61	54	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.71	1.65	3.08	4.02	5.40	5.67	5.44	4.53	2.98	1.44	0.57	0.42	(44)	
	RadStd		0.15	0.22	0.41	0.31	0.38	0.48	0.49	0.51	0.34	0.26	0.12	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.64	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+109	N/A
(47) Regional (7 neighbors)		+0.66	N/A	N/A	N/A	N/A	N/A	N/A	-197	+93	N/A

Nomenclature: See separate page