

RYAZAN, Russian Federation

WMO: 277300

Lat: 54.6514N

Lon: 39.5884E

Elev: 515

StdP: 14.42

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.2	-5.6	-16.0	2.3	-10.5	-10.6	3.2	-4.5	17.9	25.8	16.1	26.7	3.1	20	0.528

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.5	87.0	67.7	83.2	66.2	80.0	64.9	70.1	81.8	68.4	79.4	66.8	76.8	5.3	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.4	99.1	74.9	64.7	93.3	72.7	63.1	88.0	71.4	34.3	81.7	32.9	79.7	31.7	76.9	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
14.5	12.8	11.5	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-17.3	90.7	7.4	5.3	-22.6	94.5	-27.0	97.6	-31.2	100.5	-36.6	104.4
			-17.6	73.1	7.4	2.2	-22.9	74.7	-27.2	76.0	-31.3	77.3	-36.7	78.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	42.6	17.8	18.8	28.3	44.4	56.8	62.8	67.6	64.0	53.7	42.5	30.4	22.0	(6)
(7)		DBStd	19.96	11.87	12.04	8.52	9.26	9.03	7.10	6.45	7.30	7.62	7.82	9.60	11.33	(7)
(8)		HDD50	4560	998	874	674	219	37	2	0	0	46	256	587	867	(8)
(9)		HDD65	8483	1463	1294	1138	617	283	125	45	106	345	698	1037	1332	(9)
(10)		CDD50	1851	0	0	0	52	248	387	547	435	158	23	1	0	(10)
(11)		CDD65	298	0	0	0	0	29	60	127	75	7	0	0	0	(11)
(12)		CDH74	2589	0	0	0	6	260	507	1076	696	44	0	0	0	(12)
(13)		CDH80	762	0	0	0	1	53	126	337	242	3	0	0	0	(13)
(14)	Wind	WSAvg	5.3	6.0	6.2	6.1	5.6	5.1	4.6	4.1	4.1	4.3	5.4	5.9	6.1	(14)
(15)	Precipitation	PrecAvg	24.2	1.9	1.5	1.1	1.8	1.4	2.7	3.1	2.2	2.2	2.6	1.9	1.8	(15)
(16)		PrecMax	32.6	3.8	3.4	2.4	3.2	4.2	5.5	6.5	5.2	7.1	6.2	3.6	3.5	(16)
(17)		PrecMin	17.2	0.9	0.5	0.2	0.6	0.2	0.4	0.5	0.3	0.3	0.8	0.2	0.6	(17)
(18)		PrecStd	3.6	0.7	0.6	0.6	0.8	0.9	1.4	1.5	1.3	1.6	1.3	0.8	0.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.3	37.7	53.9	73.9	85.1	88.4	93.3	93.8	79.1	67.3	53.3	43.9	(19)
MCWB			36.0	35.4	45.4	55.8	64.7	66.0	68.4	68.9	62.1	56.7	50.5	42.2	(20)	
2%		DB	35.6	36.0	46.7	68.4	80.6	83.5	87.4	86.2	73.7	60.9	47.9	40.1	(21)	
		MCWB	34.2	34.1	38.9	53.5	62.1	65.9	68.1	67.9	60.8	54.2	45.6	38.9	(22)	
5%		DB	34.1	34.8	42.0	64.2	76.4	80.0	83.5	81.0	69.9	56.6	44.8	36.9	(23)	
		MCWB	32.9	33.2	37.0	51.0	60.7	64.4	67.0	65.6	58.8	51.7	42.8	35.5	(24)	
10%		DB	32.8	33.6	38.6	59.9	72.1	76.2	79.9	76.8	65.9	53.2	41.8	34.5	(25)	
		MCWB	31.7	32.4	35.2	49.1	57.9	63.3	66.2	63.9	57.2	49.6	39.9	33.3	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.6	36.2	46.0	57.5	66.4	70.6	72.9	71.5	65.3	58.3	50.1	42.4	(27)
MCDWB			37.5	37.1	54.1	70.4	81.5	82.6	84.0	84.0	73.4	63.8	53.1	43.2	(28)	
2%		WB	34.4	34.7	40.3	54.8	63.7	68.3	70.7	69.2	62.4	55.2	46.1	39.0	(29)	
		MCDWB	35.1	35.5	44.9	65.6	77.0	79.3	82.0	81.7	71.1	59.5	47.6	40.0	(30)	
5%		WB	33.1	33.5	37.5	52.6	61.8	66.4	69.1	67.4	60.4	52.4	43.0	35.8	(31)	
		MCDWB	34.0	34.3	40.9	62.1	73.7	76.8	79.8	78.8	67.3	55.9	44.5	36.6	(32)	
10%		WB	31.7	32.5	35.6	50.1	59.8	64.5	67.5	65.4	58.2	49.9	40.0	33.5	(33)	
		MCDWB	32.8	33.6	38.2	58.7	69.7	72.9	77.1	75.0	64.5	53.0	41.4	34.2	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.2	10.3	11.7	15.2	18.1	17.2	17.5	15.6	11.0	7.6	8.2	(35)	
MCDBR			7.1	7.7	14.9	20.9	22.2	22.2	22.9	23.5	21.0	16.3	10.8	6.9	(36)	
MCWBR			7.0	7.1	9.5	10.2	9.2	8.9	8.0	8.7	10.0	10.5	9.2	6.7	(37)	
5% WB		MCDWB	6.8	7.2	12.2	18.9	21.0	19.3	19.5	20.3	17.6	14.6	9.6	7.0	(38)	
		MCWBR	6.8	6.9	8.4	10.1	9.6	9.3	8.5	8.9	9.8	10.5	9.0	7.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.290	0.331	0.352	0.420	0.391	0.384	0.422	0.436	0.383	0.359	0.325	0.292	(40)	
(41)		taud	2.113	2.040	2.088	2.109	2.312	2.351	2.265	2.209	2.336	2.329	2.227	2.121	(41)	
(42)		Ebn at Noon	197	227	255	253	271	274	259	246	246	222	184	167	(42)	
(43)		Edh at Noon	21	32	38	44	38	37	39	39	30	24	19	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	232	530	1019	1300	1757	1798	1777	1455	922	443	181	124	(44)	
(45)		RadStd	46	65	127	102	150	187	164	158	116	68	33	36	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	+1.44	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	+1.31	N/A	N/A	N/A	N/A	N/A	-248	-398	+205	N/A

Nomenclature: See separate page