

RYAZAN, Russian Federation

WMO: 277300

Lat: 54.6514N

Lon: 39.5884E

Elev: 157

StdP: 99.45

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.0	-20.9	-26.7	0.3	-23.6	-23.6	0.5	-20.3	8.0	-3.4	7.2	-3.0	1.4	20	0.528

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	30.6	19.8	28.4	19.0	26.7	18.3	21.2	27.7	20.2	26.3	19.4	24.9	2.4	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.1	14.2	23.8	18.2	13.3	22.6	17.3	12.6	21.9	61.9	27.6	58.7	26.5	55.7	25.0	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(4)
(4) 6.5	5.7	5.1	DB	-27.4	32.6	4.1	2.9	-30.4	34.7	-32.8	36.4	-35.1	38.1	-38.1	40.2	(4)
(5)			WB	-27.6	22.9	4.1	1.2	-30.5	23.7	-32.9	24.5	-35.2	25.1	-38.1	26.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.9	-7.9	-7.3	-2.1	6.9	13.8	17.1	19.8	17.8	12.1	5.8	-0.9	-5.5	(6)	
	DBStd	11.09	6.59	6.69	4.73	5.14	5.02	3.94	3.58	4.06	4.23	4.34	5.33	6.30	(7)	
	HDD10.0	2533	554	486	374	122	21	1	0	0	26	142	326	482	(8)	
	HDD18.3	4713	813	719	632	343	157	69	25	59	192	388	576	740	(9)	
	CDD10.0	1028	0	0	0	29	138	215	304	242	88	13	1	0	(10)	
	CDD18.3	166	0	0	0	0	16	33	71	42	4	0	0	0	(11)	
	CDH23.3	1438	0	0	0	3	144	282	598	387	24	0	0	0	(12)	
	CDH26.7	423	0	0	0	1	29	70	187	134	2	0	0	0	(13)	
(14) Wind	WSAvg	2.4	2.7	2.8	2.7	2.5	2.3	2.1	1.8	1.8	1.9	2.4	2.7	2.7	(14)	
(15) Precipitation	PrecAvg	615	48	37	28	45	36	69	80	57	57	65	48	45	(15)	
	PrecMax	828	97	87	61	82	107	139	165	132	180	157	92	90	(16)	
	PrecMin	436	24	12	4	16	6	10	12	7	8	21	6	15	(17)	
	PrecStd	92	17	15	16	21	24	35	39	34	40	34	21	20	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.5	3.2	12.2	23.3	29.5	31.3	34.1	34.3	26.2	19.6	11.8	6.6	(19)	
		MCWB	2.2	1.9	7.5	13.2	18.2	18.9	20.2	20.5	16.7	13.7	10.3	5.7	(20)	
	2%	DB	2.0	2.2	8.2	20.2	27.0	28.6	30.8	30.1	23.2	16.0	8.8	4.5	(21)	
		MCWB	1.2	1.2	3.8	11.9	16.7	18.8	20.1	19.9	16.0	12.3	7.5	3.8	(22)	
	5%	DB	1.2	1.5	5.5	17.9	24.6	26.7	28.6	27.2	21.0	13.7	7.1	2.7	(23)	
		MCWB	0.5	0.7	2.8	10.6	15.9	18.0	19.4	18.7	14.9	10.9	6.0	1.9	(24)	
	10%	DB	0.4	0.9	3.7	15.5	22.3	24.5	26.6	24.9	18.8	11.8	5.4	1.4	(25)	
		MCWB	-0.2	0.2	1.8	9.5	14.4	17.4	19.0	17.7	14.0	9.8	4.4	0.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.6	2.4	7.8	14.1	19.1	21.4	22.7	21.9	18.5	14.6	10.1	5.8	(27)	
		MCDB	3.1	2.8	12.3	21.3	27.5	28.1	28.9	28.9	23.0	17.7	11.7	6.2	(28)	
	2%	WB	1.3	1.5	4.6	12.7	17.6	20.1	21.5	20.7	16.9	12.9	7.8	3.9	(29)	
		MCDB	1.7	1.9	7.2	18.7	25.0	26.3	27.8	27.6	21.7	15.3	8.7	4.4	(30)	
	5%	WB	0.6	0.8	3.1	11.4	16.6	19.1	20.6	19.7	15.8	11.3	6.1	2.1	(31)	
		MCDB	1.1	1.3	4.9	16.7	23.2	24.9	26.6	26.0	19.6	13.3	6.9	2.5	(32)	
	10%	WB	-0.2	0.3	2.0	10.0	15.4	18.0	19.7	18.5	14.5	9.9	4.5	0.8	(33)	
		MCDB	0.4	0.9	3.4	14.8	20.9	22.7	25.0	23.9	18.0	11.6	5.2	1.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.1	5.7	6.5	8.4	10.1	9.5	9.7	9.7	8.6	6.1	4.2	4.5	(35)	
		MCDBR	4.0	4.3	8.3	11.6	12.4	12.3	12.7	13.1	11.6	9.1	6.0	3.8	(36)	
	5% WB	MCWBR	3.9	3.9	5.3	5.6	5.1	5.0	4.5	4.8	5.6	5.8	5.1	3.7	(37)	
		MCWBR	3.8	4.0	6.8	10.5	11.7	10.7	10.8	11.3	9.8	8.1	5.4	3.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.290	0.331	0.352	0.420	0.391	0.384	0.422	0.436	0.383	0.359	0.325	0.292	(40)	
		taud	2.113	2.040	2.088	2.109	2.312	2.351	2.265	2.209	2.336	2.329	2.227	2.121	(41)	
	Ebn at Noon		622	717	804	798	854	863	818	777	775	700	581	528	(42)	
		Edh at Noon	66	101	121	138	119	116	124	124	96	77	60	53	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.73	1.67	3.21	4.10	5.54	5.67	5.60	4.59	2.91	1.40	0.57	0.39	(44)	
	RadStd		0.14	0.21	0.40	0.32	0.47	0.59	0.52	0.50	0.37	0.21	0.10	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.80	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		+0.73	N/A	N/A	N/A	N/A	N/A	-138	-221	+114	N/A

Nomenclature: See separate page