

PAVELETS, Russian Federation

WMO: 278230

Lat: 53.7840N

Lon: 39.2379E

Elev: 686

StdP: 14.34

Time Zone: 3.00 (E03)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.5	-5.4	-16.3	2.3	-10.2	-10.8	3.2	-5.0	23.3	25.0	21.2	26.5	3.3	0	0.532

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.0	85.8	66.8	82.9	65.1	79.8	64.1	69.6	81.2	67.7	78.3	66.0	75.7	4.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.7	97.3	74.6	63.8	91.0	72.3	62.1	85.6	70.7	34.0	81.7	32.4	78.5	31.1	75.7	76.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.7	17.0	14.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			-16.6	72.4	3.6	3.4	-19.2	74.9	-21.3	76.8	-23.4	78.7	-26.0	81.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	42.0	17.4	20.9	27.6	43.8	55.8	63.1	67.8	62.6	52.7	40.4	29.0	21.7	
	DBStd	19.66	11.92	10.32	8.87	8.55	8.67	7.53	5.81	6.53	7.28	8.40	10.20	10.69	
	HDD50	4666	1011	815	695	222	44	1	0	0	55	314	632	877	
	HDD65	8657	1476	1235	1160	636	302	128	36	124	373	764	1081	1342	
	CDD50	1747	0	0	0	35	224	394	553	391	135	15	0	0	
	CDD65	265	0	0	0	0	17	71	124	50	3	0	0	0	
	CDH74	2347	0	0	0	0	164	631	1084	450	18	0	0	0	
	CDH80	610	0	0	0	0	25	160	322	103	0	0	0	0	
Wind	WSAvg	5.4	7.1	7.3	6.7	5.3	5.1	4.1	3.5	3.4	3.9	5.3	6.5	7.0	
Precipitation	PrecAvg	21.3	1.4	1.1	1.1	1.5	1.8	2.3	3.0	2.3	2.0	1.7	1.8	1.7	
	PrecMax	28.8	3.6	2.2	2.1	3.4	3.7	5.1	6.4	4.3	4.4	3.4	3.6	3.3	
	PrecMin	14.6	0.2	0.0	0.3	0.2	0.2	0.3	0.2	0.3	0.2	0.4	0.6	0.4	
	PrecStd	3.7	0.8	0.6	0.5	0.7	0.9	1.3	1.6	1.2	1.1	0.9	0.8	0.8	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.9	37.9	52.1	71.5	82.8	88.4	89.9	87.0	78.7	66.2	52.1	42.9	
		MCWB	34.0	35.9	45.2	53.4	61.2	65.9	68.0	66.9	59.7	54.0	49.0	41.9	
	2%	DB	34.6	35.5	45.5	66.4	78.5	84.4	86.6	82.9	73.2	59.5	47.6	37.7	
		MCWB	33.2	34.2	39.7	51.7	60.0	64.6	67.4	65.5	59.9	53.7	45.6	36.5	
	5%	DB	33.5	34.1	41.8	62.5	74.2	81.4	83.8	79.0	68.7	55.7	44.1	35.0	
		MCWB	32.4	32.8	37.4	49.7	57.4	64.3	66.8	64.0	57.2	51.3	42.4	33.8	
	10%	DB	32.4	33.2	38.2	58.3	71.0	77.6	80.3	75.4	64.9	52.5	40.9	33.3	
		MCWB	31.5	32.1	35.0	47.8	56.5	63.2	65.6	62.9	55.7	48.9	39.5	32.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	34.9	36.4	45.8	56.1	63.9	71.7	73.2	70.2	63.6	58.1	49.7	41.9
			MCDB	35.2	37.3	51.2	65.1	75.7	82.9	84.1	81.5	74.5	61.3	51.6	42.5
2%		WB	33.6	34.4	40.9	53.3	61.7	68.4	70.6	67.5	61.1	54.6	45.8	36.8	
		MCDB	34.2	35.1	44.3	62.2	73.5	79.4	82.2	78.7	69.3	57.3	47.4	37.5	
5%		WB	32.7	33.2	37.8	51.1	60.0	66.2	68.4	65.5	58.8	52.2	42.6	34.1	
		MCDB	33.4	33.9	41.1	60.8	71.6	77.4	79.3	75.5	65.6	55.9	43.9	34.7	
10%		WB	31.4	32.3	35.2	48.8	58.1	64.1	67.0	63.9	57.0	49.0	39.5	32.6	
		MCDB	32.4	33.1	37.6	57.5	68.4	74.7	76.8	73.2	63.2	52.3	40.7	33.3	
Mean Daily Temperature Range	5% DB	MDBR	10.1	10.6	12.0	16.5	18.9	18.2	18.0	18.2	15.6	12.1	8.3	8.6	
		MCDBR	6.8	7.8	15.7	23.4	23.4	22.8	23.2	23.6	21.3	16.8	11.1	7.1	
		MCWBR	6.7	7.3	10.8	12.3	10.1	9.1	8.0	9.6	10.2	11.1	9.9	6.7	
	5% WB	MCDBR	7.2	7.2	14.2	20.8	20.2	21.0	18.8	20.6	17.7	14.8	10.9	6.6	
		MCWBR	7.4	7.0	10.3	11.9	9.9	9.8	8.7	10.0	9.9	11.1	10.0	6.4	
Clear-Sky Solar Irradiance	taub	0.290	0.331	0.352	0.424	0.390	0.382	0.416	0.435	0.382	0.356	0.326	0.294		
	taud	2.115	2.035	2.087	2.096	2.311	2.350	2.272	2.205	2.334	2.336	2.235	2.133		
	Ebn at Noon	204	231	257	253	272	275	262	248	248	226	191	175		
	Edh at Noon	22	33	39	45	38	37	39	40	31	25	20	18		
All-Sky Solar Radiation	RadAvg	268	583	1071	1332	1782	1834	1801	1495	967	475	203	146		
	RadStd	51	61	134	113	150	196	167	152	121	72	38	43		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (5 neighbors)	+1.44	N/A	N/A	N/A	N/A	N/A	-239	-376	+238	N/A	

Nomenclature: See separate page