

GLAZOV, Russian Federation

WMO: 282140

Lat: 58.133N

Lon: 52.583E

Elev: 170

StdP: 99.30

Time Zone: 4.00 (E04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-31.5	-27.8	-34.4	0.1	-31.3	-30.6	0.2	-27.7	10.4	-5.0	9.3	-4.8	0.9	270	0.616

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	29.0	20.1	27.1	19.1	25.3	18.1	21.2	27.4	20.1	25.7	19.0	23.8	2.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.0	14.1	24.2	18.0	13.2	22.9	17.0	12.4	21.9	62.1	27.7	58.4	25.7	54.7	23.8	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.7	7.5	6.7	DB	-35.2	31.4	3.3	1.9	-37.6	32.8	-39.5	33.9	-41.4	35.0	-43.8	36.4	(4)
(5)			WB	-35.3	22.7	3.3	1.3	-37.6	23.7	-39.6	24.4	-41.4	25.2	-43.8	26.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.5	-13.3	-12.2	-5.4	2.9	10.9	15.6	17.9	15.5	9.9	3.0	-5.0	-10.7	(6)	
	DBStd	12.40	7.88	7.68	4.91	4.89	5.15	4.19	3.78	4.27	4.19	4.48	6.50	7.73	(7)	
	HDD10.0	3467	722	621	476	219	53	5	1	4	53	222	449	643	(8)	
	HDD18.3	5862	980	854	734	464	233	102	54	109	253	476	699	901	(9)	
	CDD10.0	736	0	0	0	6	82	173	247	176	50	3	0	0	(10)	
	CDD18.3	88	0	0	0	0	4	20	42	22	1	0	0	0	(11)	
	CDH23.3	874	0	0	0	1	64	185	421	196	8	0	0	0	(12)	
	CDH26.7	209	0	0	0	0	9	34	109	56	1	0	0	0	(13)	
	WSAvg	2.9	3.2	3.3	3.5	3.2	3.0	2.5	1.9	2.2	2.5	3.2	3.3	3.3	(14)	
(15) Precipitation	PrecAvg	633	38	27	36	37	50	77	63	78	63	67	49	44	(15)	
	PrecMax	740	72	51	70	81	91	133	171	200	155	131	111	73	(16)	
	PrecMin	507	15	10	11	6	19	20	16	18	11	21	13	21	(17)	
	PrecStd	64	13	10	16	20	21	33	36	41	31	25	22	14	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.1	1.5	7.1	20.5	27.9	30.0	31.5	31.3	24.1	17.0	9.2	2.6	(19)	
		MCWB	0.3	0.3	3.3	12.3	17.4	20.8	20.6	20.6	16.0	11.2	7.7	2.2	(20)	
	2%	DB	0.1	0.6	4.3	16.0	25.1	27.4	29.4	27.9	21.1	13.3	6.0	1.3	(21)	
		MCWB	-0.3	0.0	1.5	9.8	15.0	19.5	20.3	19.9	15.4	9.6	5.2	0.7	(22)	
	5%	DB	-1.0	-0.2	2.5	12.9	22.7	25.5	27.7	25.3	18.7	10.9	3.7	0.4	(23)	
		MCWB	-1.5	-0.8	0.6	7.9	13.8	18.2	19.6	18.7	13.9	8.5	2.9	0.0	(24)	
	10%	DB	-2.7	-1.8	1.2	10.2	20.2	23.4	25.7	22.9	16.6	9.3	1.8	-0.9	(25)	
		MCWB	-3.2	-2.5	-0.1	6.0	12.6	17.1	18.8	17.4	12.9	7.8	1.1	-1.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.7	0.8	3.5	12.9	18.6	22.0	22.3	21.9	17.3	12.3	8.0	2.3	(27)	
		MCDB	0.9	1.1	6.4	19.1	25.6	27.9	28.4	28.8	21.9	15.0	8.6	2.5	(28)	
	2%	WB	-0.2	0.2	1.9	10.4	16.3	20.4	21.4	20.6	15.7	10.2	5.3	0.8	(29)	
		MCDB	0.2	0.6	3.4	15.2	23.1	26.2	27.5	26.7	20.1	12.4	6.1	1.1	(30)	
	5%	WB	-1.5	-0.9	1.0	8.2	14.9	19.1	20.5	19.1	14.5	8.9	3.1	0.0	(31)	
		MCDB	-1.1	-0.2	2.2	12.4	20.2	24.0	26.2	24.1	17.9	10.5	3.7	0.4	(32)	
	10%	WB	-3.2	-2.5	0.1	6.4	13.5	17.8	19.5	17.9	13.2	7.7	1.3	-1.5	(33)	
		MCDB	-2.7	-1.8	1.2	9.8	18.9	22.4	24.5	22.1	16.0	9.2	1.7	-0.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.6	7.5	8.1	8.7	10.7	10.0	10.5	9.4	8.0	5.3	4.4	5.6	(35)	
		MCDBR	5.4	5.3	8.1	12.9	14.6	12.7	13.9	12.8	11.7	9.0	4.4	3.6	(36)	
	5% WB	MCWBR	5.3	5.2	6.1	7.2	6.7	6.1	6.0	5.7	6.5	6.1	4.1	3.7	(37)	
		MCWBR	5.4	5.6	6.0	11.7	12.7	11.5	12.3	11.6	10.6	8.1	4.4	3.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.284	0.312	0.364	0.392	0.382	0.375	0.398	0.410	0.367	0.341	0.301	0.274	(40)	
		taud	2.018	2.030	1.955	2.093	2.328	2.389	2.332	2.279	2.367	2.298	2.126	1.992	(41)	
	Ebn at Noon		512	685	749	806	851	862	829	786	766	665	496	393	(42)	
		Edh at Noon	57	90	130	134	114	109	113	112	88	70	51	43	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.49	1.34	2.58	3.91	5.12	5.53	5.53	4.13	2.43	1.06	0.41	0.28	(44)	
	RadStd		0.08	0.27	0.35	0.51	0.57	0.43	0.57	0.38	0.32	0.16	0.07	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% DP	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.68	N/A	N/A	N/A	N/A	N/A	N/A	-201	N/A	N/A
(47) Regional (9 neighbors)		+0.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page