

TOBOLSK, Russian Federation

WMO: 282750

Lat: 58.150N

Lon: 68.250E

Elev: 47

StdP: 100.76

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-35.4	-32.6	-38.1	0.1	-35.3	-35.4	0.1	-32.5	8.2	-10.0	7.4	-11.9	1.1	320	0.618

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	28.8	19.8	27.1	19.2	25.4	18.2	21.2	26.9	20.1	25.4	19.2	24.0	2.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	14.0	24.1	18.2	13.2	22.9	17.2	12.4	22.0	61.7	27.1	58.0	25.4	54.8	24.1	23.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.6	6.6	6.0	-39.0	31.7	3.5	1.0	-41.5	32.4	-43.6	33.0	-45.5	33.6	-48.1	34.3		
(5)			-39.1	22.6	3.5	0.8	-41.6	23.1	-43.6	23.6	-45.6	24.0	-48.1	24.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	1.1	-18.2	-15.4	-6.6	2.4	10.4	16.5	18.4	15.2	9.4	2.8	-8.3	-14.9	(6)
(7)		DBStd	14.12	8.05	7.68	6.01	5.81	5.39	4.50	3.61	3.86	4.24	4.93	7.87	8.64	(7)
(8)		HDD10.0	4020	873	712	515	234	63	5	0	3	62	228	551	773	(8)
(9)		HDD18.3	6406	1132	945	773	479	249	87	46	112	269	483	801	1032	(9)
(10)		CDD10.0	756	0	0	0	6	76	200	261	166	43	4	0	0	(10)
(11)		CDD18.3	100	0	0	0	0	4	32	48	16	1	0	0	0	(11)
(12)		CDH23.3	881	0	0	0	1	72	289	379	130	9	0	0	0	(12)
(13)		CDH26.7	186	0	0	0	0	10	72	79	24	1	0	0	0	(13)
(14)	Wind	WSAvg	2.7	2.6	2.6	3.1	3.1	2.6	2.2	2.1	2.4	2.7	2.8	2.7	(14)	
(15)	Precipitation	PrecAvg	475	22	16	18	24	42	66	65	73	49	40	36	27	(15)
(16)		PrecMax	746	41	32	56	63	104	163	234	195	96	102	76	65	(16)
(17)		PrecMin	332	2	0	1	0	4	16	8	4	8	0	3	0	(17)
(18)		PrecStd	74	11	8	12	14	20	36	35	42	22	22	16	13	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.4	3.0	7.6	21.7	28.4	31.0	30.6	29.2	24.5	18.2	6.9	2.4	(19)
(20)			MCWB	0.4	0.7	3.3	12.7	15.9	20.3	21.4	20.5	15.7	10.9	4.6	0.9	(20)
(21)		2%	DB	-1.5	0.9	4.8	17.2	25.5	28.7	28.8	26.8	21.4	14.9	4.2	0.5	(21)
(22)			MCWB	-2.3	-0.6	1.5	10.6	15.2	19.6	20.4	19.6	14.9	9.5	2.9	-0.3	(22)
(23)		5%	DB	-4.0	-1.6	3.1	13.8	23.2	26.7	27.2	24.6	18.6	12.0	2.5	-1.4	(23)
(24)			MCWB	-4.8	-2.8	0.4	8.2	14.2	18.8	19.8	18.4	13.4	8.2	1.4	-2.3	(24)
(25)		10%	DB	-6.5	-4.1	1.6	11.0	20.4	24.6	25.5	22.2	16.1	9.8	1.0	-3.6	(25)
(26)			MCWB	-7.3	-5.3	-0.4	6.5	12.7	17.9	18.8	17.1	12.1	7.0	0.0	-4.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.4	1.0	3.7	13.3	17.6	22.2	22.6	21.8	16.9	11.7	4.8	1.3	(27)
(28)			MCDWB	1.4	2.3	6.8	19.6	25.3	28.8	28.8	27.8	22.5	16.1	6.1	2.1	(28)
(29)		2%	WB	-2.3	-0.5	1.9	10.8	16.1	20.6	21.5	20.1	15.3	10.2	2.9	-0.2	(29)
(30)			MCDWB	-1.6	1.0	4.2	16.7	24.0	26.7	27.2	25.2	20.2	13.9	3.9	0.7	(30)
(31)		5%	WB	-4.8	-2.7	0.8	8.7	14.7	19.6	20.5	18.9	13.9	8.7	1.4	-2.3	(31)
(32)			MCDWB	-4.1	-1.6	2.6	13.3	21.7	25.3	25.6	23.5	17.7	11.7	2.3	-1.5	(32)
(33)		10%	WB	-7.3	-5.2	-0.3	6.6	13.3	18.4	19.6	17.7	12.5	7.2	0.2	-4.3	(33)
(34)			MCDWB	-6.6	-4.1	1.5	10.6	19.6	23.6	24.2	21.3	15.6	9.6	0.9	-3.6	(34)
(35)	Mean Daily Temperature Range	MDBR		8.0	10.0	10.2	9.8	10.9	9.7	9.5	9.1	8.3	6.7	6.5	7.6	(35)
(36)		5% DB	MCDBR	7.8	8.6	9.7	14.2	15.4	13.4	12.2	12.8	12.6	11.2	6.1	6.6	(36)
(37)			MCWBR	7.5	7.7	7.2	8.5	7.5	5.8	5.2	6.2	6.7	6.7	5.4	6.3	(37)
(38)		5% WB	MCDBR	7.6	8.3	8.3	13.7	13.9	12.0	10.9	11.6	11.6	10.6	5.9	6.6	(38)
(39)			MCWBR	7.4	7.5	6.7	8.4	7.4	5.7	5.1	6.0	6.6	6.6	5.4	6.4	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.278	0.312	0.371	0.410	0.404	0.408	0.417	0.426	0.377	0.346	0.304	0.275	(40)
(41)		taud		2.016	2.014	1.931	2.054	2.255	2.308	2.288	2.223	2.324	2.254	2.089	1.969	(41)
(42)		Ebn at Noon		520	683	739	786	828	829	811	768	753	653	483	385	(42)
(43)		Edh at Noon		57	92	133	140	123	119	118	118	91	73	53	43	(43)
(44)	All-Sky Solar Radiation	RadAvg		0.63	1.59	3.06	4.35	5.13	5.60	5.32	4.02	2.55	1.26	0.56	0.36	(44)
(45)		RadStd		0.05	0.12	0.20	0.41	0.38	0.40	0.51	0.35	0.27	0.17	0.10	0.05	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page