

NOZHOVKA, Russian Federation

WMO: 283190

Lat: 57.083N

Lon: 54.750E

Elev: 131

StdP: 99.76

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-29.6	-26.4	-32.9	0.2	-29.3	-29.6	0.2	-26.2	8.1	-7.5	7.3	-7.6	1.2	270	0.568

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	29.9	20.8	28.0	19.7	26.2	18.7	21.6	28.1	20.6	26.5	19.6	24.8	2.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	14.4	24.7	18.5	13.5	23.6	17.5	12.7	22.7	63.4	28.3	59.9	26.5	56.6	24.9	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	7.4	6.4	5.5	DB	-33.5	32.0	3.7	1.8	-36.1	33.3	-38.3	34.4	-40.3	35.4	-43.0	36.7
(5)				WB	-33.6	23.3	3.7	2.0	-36.2	24.7	-38.4	25.9	-40.4	27.1	-43.1	28.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.4	-12.7	-11.5	-4.3	4.0	11.8	16.7	19.1	16.8	10.9	3.9	-4.3	-10.3	(6)
(7)		DBStd	12.52	7.48	7.03	4.73	5.08	5.00	4.30	3.96	4.19	4.40	4.55	6.37	7.38	(7)
(8)		HDD10.0	3281	703	603	444	192	40	4	0	1	40	196	428	631	(8)
(9)		HDD18.3	5579	961	836	702	431	208	81	40	82	225	446	678	889	(9)
(10)		CDD10.0	881	0	0	0	11	96	204	283	211	68	8	0	0	(10)
(11)		CDD18.3	136	0	0	0	0	6	31	64	33	3	0	0	0	(11)
(12)		CDH23.3	1185	0	0	0	1	68	262	577	258	19	0	0	0	(12)
(13)		CDH26.7	314	0	0	0	0	9	60	167	76	2	0	0	0	(13)
(14)	Wind	WSAvg	2.3	2.3	2.4	2.6	2.3	2.4	2.2	1.8	1.9	2.1	2.5	2.6	2.4	(14)
(15)	Precipitation	PrecAvg	564	37	27	29	32	48	65	59	68	58	57	47	39	(15)
(16)		PrecMax	717	67	47	52	62	83	150	133	132	135	98	81	64	(16)
(17)		PrecMin	409	6	10	2	1	14	17	22	12	10	16	6	20	(17)
(18)		PrecStd	72	14	12	13	17	21	28	25	29	28	21	20	14	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.2	1.8	8.0	22.1	28.2	30.9	32.2	32.1	26.3	18.1	9.1	2.3	(19)
(20)		MCWB	0.5	0.7	3.8	13.6	16.7	20.8	21.8	21.5	16.1	11.6	7.7	1.4	1.4	(20)
(21)		2%	DB	0.2	0.8	5.1	18.2	25.2	28.4	30.3	28.6	22.3	15.2	6.6	1.2	(21)
(22)		MCWB	-0.5	0.0	2.1	11.0	15.4	19.5	21.2	20.2	15.2	10.2	5.6	0.4	0.4	(22)
(23)		5%	DB	-1.0	-0.1	3.2	14.5	23.0	26.4	28.6	26.0	19.8	12.7	4.5	0.4	(23)
(24)		MCWB	-1.7	-0.8	1.1	8.8	14.7	18.9	20.5	18.9	14.4	9.3	3.6	-0.2	-0.2	(24)
(25)		10%	DB	-2.6	-1.8	1.7	11.6	20.7	24.4	26.8	23.7	17.5	10.4	2.5	-1.0	(25)
(26)		MCWB	-3.3	-2.7	0.2	7.0	13.3	17.8	19.4	18.2	13.4	8.2	1.6	-1.7	-1.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.7	1.0	4.5	14.2	18.3	22.0	23.1	22.5	17.6	12.8	7.7	1.7	(27)
(28)		MCDWB	1.1	1.4	7.2	21.0	24.9	28.8	30.0	29.2	22.5	16.0	8.6	2.1	2.1	(28)
(29)		2%	WB	-0.3	0.2	2.6	11.5	16.5	20.5	22.0	21.0	16.0	11.0	5.7	0.6	(29)
(30)		MCDWB	0.2	0.7	4.3	17.0	23.2	26.6	28.5	27.1	20.3	14.4	6.6	1.1	1.1	(30)
(31)		5%	WB	-1.6	-0.9	1.5	9.3	15.4	19.4	21.1	19.6	15.0	9.6	3.6	-0.3	(31)
(32)		MCDWB	-1.0	-0.2	2.8	13.9	21.6	25.2	27.2	24.7	18.8	12.0	4.5	0.3	0.3	(32)
(33)		10%	WB	-3.4	-2.6	0.5	7.4	14.1	18.4	20.2	18.5	13.9	8.4	1.8	-1.6	(33)
(34)		MCDWB	-2.7	-1.8	1.7	11.3	19.4	23.4	25.6	22.8	17.4	10.4	2.4	-1.1	-1.1	(34)
(35)	Mean Daily Temperature Range	MDBR	6.2	7.0	7.5	8.7	10.5	9.5	9.8	8.7	7.3	5.1	4.2	5.5	(35)	
(36)		5% DB	MCDBR	5.4	5.2	7.6	12.9	13.8	12.2	12.6	12.0	10.3	8.9	4.3	3.8	(36)
(37)		MCWBR	5.4	4.9	5.5	7.2	6.7	5.5	5.1	5.0	5.3	5.2	3.9	4.0	(37)	
(38)		5% WB	MCDBR	5.6	5.1	6.3	11.7	12.4	11.3	11.4	11.1	9.3	7.9	4.2	4.0	(38)
(39)		MCWBR	5.6	5.0	5.0	7.0	6.8	5.9	5.0	5.3	5.2	5.2	4.1	4.2	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.295	0.319	0.375	0.405	0.393	0.390	0.410	0.430	0.377	0.352	0.311	0.288	(40)	
(41)		taud	2.008	2.013	1.936	2.083	2.294	2.360	2.311	2.228	2.346	2.270	2.110	1.982	(41)	
(42)		Ebn at Noon	527	692	746	798	843	851	821	771	763	666	511	414	(42)	
(43)		Edh at Noon	63	96	136	138	119	113	117	119	91	75	57	49	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.61	1.53	2.90	4.21	5.28	5.60	5.62	4.25	2.57	1.11	0.48	0.33	(44)	
(45)		RadStd	0.09	0.22	0.32	0.51	0.56	0.49	0.61	0.38	0.29	0.19	0.10	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page