

TYUMEN, Russian Federation

WMO: 283670

Lat: 57.117N

Lon: 65.433E

Elev: 102

StdP: 100.11

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-32.2	-29.4	-35.1	0.1	-32.1	-32.3	0.2	-29.2	6.3	-8.1	5.6	-8.9	1.3	330	0.582

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	29.7	19.7	28.0	19.0	26.3	18.2	21.2	27.5	20.3	26.0	19.3	24.5	2.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	14.0	24.0	18.1	13.2	23.2	17.2	12.5	22.1	61.9	27.6	58.7	25.9	55.4	24.6	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.3	5.5	4.9	DB	-34.7	32.4	3.1	1.2	-36.9	33.3	-38.8	34.0	-40.5	34.7	-42.8	35.6	(4)
(5)			WB	-34.8	23.0	3.1	1.5	-37.0	24.1	-38.9	25.0	-40.6	25.8	-42.9	26.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.3	-15.7	-13.1	-4.8	4.2	11.6	16.8	18.4	16.1	10.1	3.0	-6.7	-12.8	(6)	
	DBStd	13.32	7.31	7.20	5.19	5.51	5.34	4.56	3.90	4.19	4.44	4.92	7.49	7.62	(7)	
	HDD10.0	3628	798	646	460	187	46	4	1	2	53	222	501	708	(8)	
	HDD18.3	5967	1057	879	718	426	216	82	49	97	251	475	751	966	(9)	
	CDD10.0	825	0	0	0	12	96	207	261	190	55	4	0	0	(10)	
	CDD18.3	123	0	0	0	0	8	35	51	27	2	0	0	0	(11)	
	CDH23.3	1191	0	0	0	3	117	361	461	229	21	0	0	0	(12)	
	CDH26.7	299	0	0	0	0	22	101	114	61	2	0	0	0	(13)	
(14) Wind	WSAvg	2.4	2.2	2.3	2.6	2.7	2.6	2.3	2.0	2.0	2.2	2.4	2.5	2.4	(14)	
(15) Precipitation	PrecAvg	470	23	16	14	26	41	61	88	60	47	37	31	26	(15)	
	PrecMax	664	82	38	41	59	145	160	194	170	175	94	67	52	(16)	
	PrecMin	330	4	1	1	1	7	10	13	7	10	8	1	0	(17)	
	PrecStd	66	15	9	9	16	24	34	43	31	34	21	16	14	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.5	3.4	9.2	22.8	29.1	31.6	31.7	30.9	26.0	18.4	7.6	2.7	(19)	
		MCWB	0.4	0.6	4.3	12.4	15.9	20.4	20.9	21.0	15.9	11.1	4.9	1.2	(20)	
	2%	DB	-0.9	1.3	5.7	18.5	26.5	29.5	29.4	28.2	22.7	15.0	5.3	0.8	(21)	
		MCWB	-2.1	-0.5	1.8	10.5	15.1	19.2	20.2	19.9	15.0	9.7	3.8	-0.3	(22)	
	5%	DB	-2.9	-0.8	3.7	15.3	24.0	27.5	27.8	25.8	19.8	12.1	3.6	-0.9	(23)	
		MCWB	-3.8	-2.4	0.7	8.7	14.0	18.5	19.9	18.8	13.8	8.2	2.3	-1.8	(24)	
	10%	DB	-5.5	-2.9	2.3	12.6	21.5	25.3	26.0	23.4	17.2	9.8	1.9	-2.9	(25)	
		MCWB	-6.2	-4.3	-0.1	7.2	12.9	17.8	19.0	17.7	12.5	7.1	0.7	-3.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.4	1.2	4.5	13.2	18.5	22.2	22.4	21.9	17.7	11.8	5.7	1.2	(27)	
		MCDB	1.5	2.7	8.3	20.5	25.7	29.3	28.6	28.8	23.3	16.7	7.4	2.2	(28)	
	2%	WB	-2.0	-0.4	2.4	11.1	16.2	20.5	21.3	20.8	15.8	10.2	4.0	-0.2	(29)	
		MCDB	-1.1	1.2	4.8	17.7	23.6	26.9	27.5	26.6	20.6	14.3	5.2	0.8	(30)	
	5%	WB	-3.8	-2.2	1.2	9.2	14.9	19.3	20.5	19.5	14.4	8.6	2.4	-1.8	(31)	
		MCDB	-2.9	-0.9	3.3	14.5	22.3	25.5	26.3	24.3	18.7	11.4	3.5	-1.0	(32)	
	10%	WB	-6.2	-4.2	0.1	7.5	13.6	18.2	19.7	18.3	13.0	7.3	0.8	-3.7	(33)	
		MCDB	-5.5	-2.9	2.1	12.1	20.4	24.1	24.9	22.7	16.8	9.8	1.7	-2.9	(34)	
(35) Mean Daily Temperature Range	MDBR		7.2	9.0	9.1	9.3	11.1	10.4	9.7	9.2	8.4	6.8	6.0	6.6	(35)	
	5% DB	MCDBR	6.6	7.8	9.3	13.3	15.1	13.5	12.4	12.7	12.4	11.2	5.8	6.0	(36)	
		MCWBR	6.2	6.5	6.5	7.3	6.7	5.6	5.0	5.6	6.2	6.5	5.0	5.5	(37)	
	5% WB	MCDBR	6.6	7.1	8.5	12.3	13.6	11.8	11.1	11.5	11.2	9.9	5.5	6.2	(38)	
		MCWBR	6.3	6.1	6.4	7.2	6.9	5.7	5.0	5.6	6.0	6.5	5.1	5.8	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.281	0.311	0.368	0.409	0.406	0.404	0.420	0.429	0.381	0.348	0.305	0.279	(40)	
	taud		2.039	2.034	1.953	2.095	2.236	2.311	2.267	2.213	2.308	2.266	2.129	1.998	(41)	
	Ebn at Noon		554	705	755	795	829	836	811	771	756	670	523	429	(42)	
	Edh at Noon		60	93	133	136	126	119	122	120	95	75	55	47	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.71	1.70	3.20	4.45	5.21	5.70	5.48	4.21	2.66	1.35	0.66	0.43	(44)	
	RadStd		0.05	0.12	0.18	0.35	0.45	0.45	0.49	0.41	0.27	0.22	0.09	0.05	(45)	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (7 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page