

TEVRIZ, Russian Federation

WMO: 283830

Lat: 57.517N

Lon: 72.400E

Elev: 219

StdP: 14.58

Time Zone: 6.00 (E06)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-32.9	-27.7	-38.0	0.6	-32.9	-32.9	0.9	-27.7	18.4	12.9	16.5	13.2	2.4	70	0.635

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.4	83.5	67.9	80.7	66.4	77.7	64.8	70.3	79.8	68.4	77.4	66.6	74.9	6.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.8	99.5	75.6	65.1	93.5	73.1	63.3	87.9	71.0	34.4	80.3	32.8	77.4	31.4	75.2	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.4	16.1	14.2	DB	-37.8	88.2	6.7	2.5	-42.7	89.9	-46.6	91.4	-50.4	92.8	-55.3	94.6	(4)
(5)			WB	-38.0	72.4	6.7	2.0	-42.8	73.8	-46.7	74.9	-50.4	76.0	-55.3	77.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	33.7	-1.6	4.1	20.0	36.6	51.0	61.5	64.3	59.5	49.1	35.8	17.2	4.7	(6)
(7)		DBStd	25.56	15.17	13.72	11.20	10.39	9.97	8.41	6.73	7.04	7.65	9.18	14.65	15.28	(7)
(8)		HDD50	7305	1601	1284	931	414	114	13	0	6	109	445	984	1404	(8)
(9)		HDD65	11612	2066	1704	1396	853	444	162	98	201	480	905	1434	1869	(9)
(10)		CDD50	1342	0	0	0	11	145	356	444	300	81	5	0	0	(10)
(11)		CDD65	174	0	0	0	0	10	56	77	29	2	0	0	0	(11)
(12)		CDH74	1577	0	0	0	2	160	517	634	248	16	0	0	0	(12)
(13)		CDH80	311	0	0	0	0	31	113	124	43	0	0	0	0	(13)
(14)	Wind	WSAvg	6.5	6.0	6.2	7.6	7.8	7.3	6.0	5.1	5.5	6.2	7.0	7.2	6.8	(14)
(15)	Precipitation	PrecAvg	20.3	1.0	0.7	0.9	1.2	1.6	2.7	3.0	2.8	2.0	1.7	1.5	1.3	(15)
(16)		PrecMax	28.8	1.9	1.4	2.2	2.9	3.6	7.0	9.8	5.6	4.2	3.8	2.4	2.4	(16)
(17)		PrecMin	12.5	0.1	0.0	0.0	0.1	0.1	0.9	1.1	0.8	0.7	0.2	0.3	0.4	(17)
(18)		PrecStd	4.1	0.5	0.3	0.5	0.7	0.8	1.3	2.0	1.0	0.9	0.9	0.6	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.7	36.3	45.7	69.2	83.4	86.5	87.0	85.0	76.3	62.1	43.3	35.1	(19)
(20)			MCWB	31.3	32.9	37.5	52.7	61.5	67.4	71.2	69.4	59.5	51.3	40.2	33.6	(20)
(21)		2%	DB	28.8	31.6	40.5	62.3	78.2	83.3	83.1	79.9	70.3	56.4	39.7	32.4	(21)
(22)			MCWB	27.4	29.4	34.6	49.4	59.0	67.2	69.1	67.2	58.3	48.4	37.5	31.1	(22)
(23)		5%	DB	24.9	28.2	37.2	56.7	74.0	80.0	80.6	76.4	65.5	52.3	36.5	28.9	(23)
(24)			MCWB	23.7	26.6	32.9	46.0	57.1	65.9	67.6	65.6	56.1	45.8	34.8	27.6	(24)
(25)		10%	DB	20.5	24.2	34.6	52.2	69.0	76.4	77.5	72.6	61.8	48.6	33.9	25.0	(25)
(26)			MCWB	19.4	22.4	31.2	43.7	54.8	64.1	66.2	63.5	54.0	43.9	32.6	23.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	31.5	33.1	38.3	54.4	63.6	72.6	73.4	71.1	62.0	52.8	40.8	34.2	(27)
(28)			MCD B	32.5	35.7	44.2	66.1	79.2	82.7	83.5	81.1	71.5	59.5	42.5	34.9	(28)
(29)		2%	WB	27.7	29.6	35.5	50.5	60.5	69.2	71.0	68.6	59.4	49.3	37.8	31.1	(29)
(30)			MCD B	28.8	31.4	39.1	60.8	74.1	79.1	80.5	77.6	67.9	54.5	39.3	32.2	(30)
(31)		5%	WB	23.8	26.7	33.6	47.2	58.3	67.2	69.0	66.6	57.1	46.8	34.8	27.6	(31)
(32)			MCD B	24.9	28.2	36.7	55.5	71.3	76.6	77.8	74.5	63.6	50.9	36.2	28.7	(32)
(33)		10%	WB	19.5	22.5	31.4	44.0	55.9	65.3	67.3	64.5	54.9	44.4	32.7	23.8	(33)
(34)			MCD B	20.4	24.2	34.4	51.3	67.0	74.2	75.5	71.1	60.5	48.5	33.8	24.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.7	16.8	17.2	17.0	20.1	18.6	17.4	17.1	15.5	11.6	11.0	13.0	(35)
(36)			MCDBR	11.8	14.1	15.5	23.4	27.3	24.3	22.7	23.1	21.7	18.4	9.9	11.2	(36)
(37)			MCWBR	11.3	12.9	11.1	13.6	12.2	10.9	10.3	11.4	11.5	11.6	9.1	10.7	(37)
(38)		5% WB	MCD BR	11.4	13.5	14.0	21.9	24.4	21.7	20.4	20.5	18.8	16.3	9.3	11.5	(38)
(39)			MCWBR	11.2	12.7	10.9	13.9	12.6	11.1	10.2	10.8	11.3	11.3	8.9	11.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.276	0.312	0.370	0.409	0.403	0.409	0.427	0.422	0.374	0.349	0.307	0.277	(40)	
(41)		taud	2.019	2.009	1.926	2.046	2.249	2.304	2.252	2.238	2.331	2.236	2.075	1.964	(41)	
(42)		Ebn at Noon	173	220	237	251	263	264	255	246	242	208	158	129	(42)	
(43)		Edh at Noon	19	30	43	45	39	38	39	37	29	24	18	15	(43)	
(44)	All-Sky Solar Radiation	RadAvg	217	535	985	1412	1624	1762	1662	1283	835	411	185	128	(44)	
(45)		RadStd	22	41	75	121	131	141	141	115	85	53	34	17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page