

ASZKINO, Russian Federation

WMO: 285220

Lat: 56.110N

Lon: 56.574E

Elev: 207

StdP: 98.87

Time Zone: 5.00 (E05)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-31.1	-27.7	-34.3	0.2	-31.1	-30.4	0.2	-27.5	10.5	-4.5	10.0	-2.9	1.4	90	0.638

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	30.0	18.9	28.1	18.7	26.2	17.9	20.6	27.0	19.8	26.1	18.9	24.6	3.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.4	13.6	23.1	17.6	12.9	22.3	16.7	12.2	21.7	60.2	27.0	57.5	26.1	54.5	24.5	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.7	8.7	7.7		-35.7	32.1	3.9	2.3	-38.5	33.7	-40.8	35.1	-43.1	36.3	-45.9	38.0	
				DB												
				WB	-35.8	22.2	3.9	0.8	-38.6	22.8	-40.9	23.3	-43.1	23.8	-45.9	24.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.1	-14.1	-12.2	-5.0	4.0	12.1	16.2	18.0	16.9	10.9	3.5	-4.0	-10.5	(6)
(7)		DBStd	12.64	7.64	6.43	5.13	4.85	4.88	4.58	3.85	4.30	4.32	4.65	6.04	7.41	(7)
(8)		HDD10.0	3372	747	621	465	192	34	7	1	3	39	207	421	636	(8)
(9)		HDD18.3	5691	1006	854	723	432	199	92	53	79	227	461	671	894	(9)
(10)		CDD10.0	840	0	0	0	11	100	193	248	218	65	5	0	0	(10)
(11)		CDD18.3	116	0	0	0	0	7	28	43	36	2	0	0	0	(11)
(12)		CDH23.3	1224	0	0	0	3	96	284	456	366	20	0	0	0	(12)
(13)		CDH26.7	338	0	0	0	0	12	71	128	125	2	0	0	0	(13)
(14)	Wind	WSAvg	3.3	3.3	3.3	3.8	3.6	3.5	3.3	2.8	2.8	3.0	3.5	3.7	3.5	(14)
(15)	Precipitation	PrecAvg	637	41	33	29	28	40	71	69	64	53	64	51	44	(15)
(16)		PrecMax	769	82	74	62	59	82	152	166	139	110	117	102	75	(16)
(17)		PrecMin	481	7	6	3	2	10	24	5	14	19	11	17	6	(17)
(18)		PrecStd	89	16	16	18	17	20	38	42	37	27	30	26	19	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.0	1.3	7.7	22.7	28.3	31.2	32.8	33.0	26.0	18.0	9.7	1.6	(19)
(20)		MCWB	0.1	0.0	3.5	12.3	17.5	19.9	19.7	18.8	15.0	10.1	7.8	-0.1	-0.1	(20)
(21)		2%	DB	-0.3	0.2	5.1	18.2	26.0	28.8	29.7	30.1	22.7	14.9	7.0	0.7	(21)
(22)		MCWB	-1.2	-0.6	2.0	10.7	15.8	18.6	19.3	18.8	14.7	9.1	6.0	-0.1	-0.1	(22)
(23)		5%	DB	-1.8	-1.3	3.2	14.7	23.8	26.6	27.8	27.4	20.0	12.3	5.0	0.1	(23)
(24)		MCWB	-2.5	-2.4	1.0	8.7	14.9	18.2	19.0	18.7	13.8	8.1	4.2	-0.6	-0.6	(24)
(25)		10%	DB	-3.9	-3.2	1.6	11.4	21.5	24.5	26.0	24.8	17.7	10.3	2.8	-1.2	(25)
(26)		MCWB	-4.6	-4.3	0.0	7.0	13.5	17.4	18.4	17.8	13.0	7.6	1.9	-2.2	-2.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.3	0.5	4.2	13.1	18.5	21.0	21.7	21.2	17.2	11.6	8.2	0.7	(27)
(28)		MCDWB	0.6	1.1	6.5	21.0	24.9	27.4	27.5	28.0	22.5	15.3	10.0	0.9	0.9	(28)
(29)		2%	WB	-1.1	-0.5	2.4	11.2	16.8	20.0	20.8	20.1	15.7	10.0	6.1	0.2	(29)
(30)		MCDWB	-0.5	0.1	4.4	17.4	23.9	26.0	27.0	26.9	20.2	13.4	7.1	0.6	0.6	(30)
(31)		5%	WB	-2.5	-2.3	1.2	9.2	15.5	19.1	20.0	19.2	14.6	8.7	4.1	-0.5	(31)
(32)		MCDWB	-1.8	-1.5	2.7	13.7	22.6	25.0	26.4	25.7	18.5	11.5	5.0	0.1	0.1	(32)
(33)		10%	WB	-4.5	-4.2	0.2	7.4	14.3	18.1	19.1	18.3	13.5	7.6	2.0	-2.0	(33)
(34)		MCDWB	-3.8	-3.3	1.6	11.3	20.2	23.5	24.5	23.8	17.1	10.2	2.7	-1.3	-1.3	(34)
(35)	Mean Daily Temperature Range	MDBR	6.6	8.1	8.0	8.4	11.7	10.7	10.5	10.4	8.4	5.9	4.5	5.5	(35)	
(36)		5% DB	MCDBR	4.6	6.2	8.5	13.0	14.9	13.4	14.2	14.6	12.1	10.7	5.1	3.6	(36)
(37)		MCWBR	4.3	5.3	6.0	7.0	7.0	5.4	5.4	5.4	5.9	6.5	4.1	3.5	(37)	
(38)		5% WB	MCDBR	4.6	5.3	6.6	11.6	13.8	11.6	12.3	12.7	10.1	9.1	4.5	3.7	(38)
(39)		MCWBR	4.5	5.0	5.0	6.5	7.0	5.7	5.3	5.5	5.4	6.0	3.9	3.7	3.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.294	0.318	0.372	0.407	0.398	0.391	0.412	0.431	0.379	0.354	0.314	0.292	(40)	
(41)		taud	2.017	2.022	1.934	2.065	2.261	2.340	2.289	2.210	2.323	2.260	2.124	1.985	(41)	
(42)		Ebn at Noon	560	711	758	801	841	852	823	774	767	677	539	447	(42)	
(43)		Edh at Noon	66	98	138	142	124	116	120	122	95	78	60	53	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.69	1.65	3.01	4.22	5.17	5.52	5.52	4.25	2.63	1.17	0.55	0.40	(44)	
(45)		RadStd	0.10	0.22	0.29	0.52	0.54	0.59	0.59	0.44	0.24	0.24	0.12	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page