

NAZYVAEVSK, Russian Federation

WMO: 285880

Lat: 55.567N

Lon: 71.367E

Elev: 414

StdP: 14.48

Time Zone: 6.00 (E06)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-29.0	-23.8	-34.1	0.8	-28.5	-29.0	1.1	-23.5	18.8	11.9	17.2	9.2	4.1	140	0.645

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.2	85.1	66.7	81.9	65.2	78.9	63.8	68.9	80.7	67.3	78.3	65.7	75.9	8.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.9	93.5	73.3	63.3	88.3	72.1	61.6	83.1	70.9	33.3	80.9	32.0	78.2	30.7	76.1	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.3	17.8	15.8	-32.9	91.0	6.3	3.8	-37.5	93.7	-41.2	95.9	-44.7	98.1	-49.3	100.8
			-34.1	71.8	6.2	2.0	-38.6	73.2	-42.2	74.4	-45.7	75.5	-50.2	76.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	35.6	0.1	5.0	20.7	39.9	54.0	63.4	65.1	61.0	50.9	38.5	20.8	6.2
	DBStd	25.35	13.70	12.86	10.61	10.37	9.55	8.04	6.78	7.24	7.98	8.81	13.05	14.14
	HDD50	6810	1547	1259	908	331	72	7	0	4	83	366	876	1357
	HDD65	10949	2012	1679	1373	754	357	121	87	167	430	821	1326	1822
	CDD50	1568	0	0	0	28	195	411	469	345	110	10	0	0
	CDD65	231	0	0	0	0	15	75	92	43	6	0	0	0
	CDH74	2081	0	0	0	10	210	706	742	353	60	0	0	0
	CDH80	520	0	0	0	0	48	206	175	81	10	0	0	0
Wind	WSAvg	7.6	6.9	7.1	8.6	8.8	8.8	7.2	6.8	6.8	7.2	7.6	8.1	7.4
Precipitation	PrecAvg	15.8	0.6	0.5	0.6	0.9	1.3	2.3	2.9	2.3	1.4	1.1	1.1	0.8
	PrecMax	23.3	1.2	1.2	1.5	1.9	2.2	6.7	5.6	5.7	2.6	2.1	2.0	1.6
	PrecMin	11.1	0.0	0.0	0.0	0.2	0.0	0.7	0.5	0.8	0.3	0.2	0.2	0.3
	PrecStd	2.9	0.4	0.2	0.4	0.5	0.6	1.3	1.5	1.1	0.6	0.5	0.5	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.9	34.9	46.2	74.4	85.1	89.5	89.2	86.5	81.0	64.5	45.0	35.3
		MCWB	30.5	31.7	38.1	58.7	62.6	67.5	69.5	67.7	62.0	51.3	41.4	33.0
	2%	DB	28.5	30.8	39.6	66.2	79.5	85.3	84.2	81.7	73.5	60.1	41.2	32.1
		MCWB	26.9	28.6	34.6	52.0	59.8	66.4	67.2	65.6	58.4	49.7	39.1	30.4
	5%	DB	25.0	28.0	36.7	61.4	75.4	81.7	81.0	77.7	68.2	55.4	38.5	28.2
		MCWB	23.7	26.4	33.2	49.6	58.1	65.2	66.3	63.6	56.8	47.0	35.9	26.3
	10%	DB	21.0	23.9	34.2	56.1	70.7	77.7	78.0	74.0	64.1	51.5	35.1	24.8
		MCWB	19.8	22.3	31.4	46.6	55.8	63.7	64.9	62.3	54.2	45.3	33.1	23.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.5	32.0	38.9	58.5	64.3	70.3	71.0	69.9	63.5	53.9	41.9	33.1
		MCDB	31.9	34.7	45.0	73.0	82.4	84.0	82.2	80.8	78.3	60.7	43.3	34.5
	2%	WB	27.1	28.8	35.5	53.4	61.4	68.4	69.2	67.4	60.4	50.8	39.3	30.6
		MCDB	28.6	30.6	38.8	63.2	75.7	81.8	80.5	77.6	70.2	57.8	41.5	32.4
	5%	WB	23.7	26.2	33.5	50.1	59.2	66.6	67.7	65.6	57.8	48.2	36.0	26.7
		MCDB	24.9	28.0	36.2	60.7	72.0	78.4	78.1	75.1	66.6	54.6	38.0	28.1
	10%	WB	19.8	22.3	31.6	47.1	57.0	64.7	66.1	63.6	55.3	45.6	33.4	23.3
		MCDB	21.0	23.8	34.3	55.4	69.1	75.0	76.0	71.9	63.2	51.3	35.0	24.7
Mean Daily Temperature Range	5% DB	MDBR	13.0	15.1	15.1	16.3	19.5	18.2	17.2	16.9	16.1	12.6	10.1	12.5
		MCDBR	12.3	12.1	13.3	24.7	26.2	24.5	22.1	23.5	22.8	20.6	10.1	12.0
		MCWBR	12.0	11.1	10.2	14.1	12.2	10.1	8.9	10.4	11.8	12.4	8.6	11.3
	5% WB	MCDBR	12.4	12.1	12.5	23.5	23.9	21.6	19.1	20.0	20.7	18.6	9.5	12.1
		MCWBR	12.0	11.1	10.1	14.2	12.6	9.8	9.1	10.2	11.5	12.0	8.5	11.6
Clear-Sky Solar Irradiance	taub	0.280	0.313	0.369	0.413	0.404	0.405	0.429	0.431	0.374	0.354	0.317	0.284	
	taud	2.047	2.023	1.939	2.090	2.231	2.293	2.223	2.185	2.313	2.223	2.095	1.999	
	Ebn at Noon	191	230	243	253	266	266	256	246	246	216	173	153	
	Edh at Noon	21	31	44	44	41	39	41	40	30	26	20	17	
All-Sky Solar Radiation	RadAvg	286	622	1115	1468	1757	1872	1753	1385	947	482	237	181	
	RadStd	22	32	82	112	125	130	129	121	87	65	35	24	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page