

NAZYVAEVSK, Russian Federation

WMO: 285880

Lat: 55.567N

Lon: 71.367E

Elev: 126

StdP: 99.82

Time Zone: 6.00 (E06)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-33.9	-31.0	-36.7	0.1	-33.6	-33.9	0.2	-30.8	8.4	-11.2	7.7	-12.7	1.8	140	0.645

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	29.5	19.3	27.7	18.4	26.1	17.7	20.5	27.0	19.6	25.7	18.7	24.4	3.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.3	13.4	23.0	17.4	12.6	22.3	16.4	11.9	21.6	59.6	27.2	56.6	25.7	53.6	24.5	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.1	8.0	7.1	DB	-36.1	32.8	3.5	2.1	-38.6	34.3	-40.7	35.5	-42.6	36.7	-45.2	38.2	(4)
(5)			WB	-36.7	22.1	3.4	1.1	-39.2	22.9	-41.2	23.5	-43.1	24.2	-45.6	25.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.0	-17.7	-15.0	-6.3	4.4	12.2	17.5	18.4	16.1	10.5	3.6	-6.2	-14.3		
	DBStd	14.08	7.61	7.14	5.90	5.76	5.31	4.46	3.77	4.02	4.43	4.89	7.25	7.86		
	HDD10.0	3783	859	699	504	184	40	4	0	2	46	203	487	754		
	HDD18.3	6083	1118	933	763	419	198	67	48	93	239	456	737	1012		
	CDD10.0	871	0	0	0	16	108	228	261	192	61	6	0	0		
	CDD18.3	128	0	0	0	0	8	42	51	24	3	0	0	0		
	CDH23.3	1156	0	0	0	6	117	392	412	196	33	0	0	0		
	CDH26.7	289	0	0	0	0	27	114	97	45	6	0	0	0		
(14) Wind	WSAvg	3.4	3.1	3.2	3.9	3.9	3.9	3.2	3.0	3.0	3.2	3.4	3.6	3.3		
(15) Precipitation	PrecAvg	401	16	12	15	23	33	59	73	59	35	28	27	21		
	PrecMax	592	31	30	38	48	56	170	143	144	66	53	51	41		
	PrecMin	282	1	1	0	4	1	17	13	21	8	4	5	7		
	PrecStd	73	9	6	10	13	15	32	38	28	16	13	12	10		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.1	1.6	7.9	23.6	29.5	31.9	31.8	30.3	27.2	18.1	7.2	1.9		
		MCWB	-0.9	-0.2	3.4	14.8	17.0	19.7	20.8	19.8	16.7	10.7	5.2	0.6		
	2%	DB	-2.0	-0.7	4.2	19.0	26.4	29.6	29.0	27.6	23.1	15.6	5.1	0.1		
		MCWB	-2.8	-1.9	1.5	11.1	15.5	19.1	19.6	18.7	14.7	9.8	3.9	-0.9		
	5%	DB	-3.9	-2.2	2.6	16.3	24.1	27.6	27.2	25.4	20.1	13.0	3.6	-2.1		
		MCWB	-4.6	-3.1	0.7	9.8	14.5	18.5	19.0	17.5	13.8	8.4	2.2	-3.2		
	10%	DB	-6.1	-4.5	1.2	13.4	21.5	25.4	25.6	23.3	17.9	10.8	1.7	-4.0		
		MCWB	-6.8	-5.4	-0.3	8.1	13.2	17.6	18.3	16.8	12.3	7.4	0.6	-4.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.8	0.0	3.8	14.7	18.0	21.3	21.6	21.1	17.5	12.2	5.5	0.6		
		MCDB	0.0	1.5	7.2	22.8	28.0	28.9	27.9	27.1	25.7	15.9	6.3	1.4		
	2%	WB	-2.7	-1.8	1.9	11.9	16.4	20.2	20.7	19.7	15.8	10.5	4.1	-0.8		
		MCDB	-1.9	-0.8	3.8	17.3	24.3	27.6	27.0	25.3	21.2	14.3	5.3	0.2		
	5%	WB	-4.6	-3.2	0.8	10.1	15.1	19.2	19.8	18.6	14.3	9.0	2.2	-3.0		
		MCDB	-3.9	-2.2	2.4	16.0	22.2	25.8	25.6	24.0	19.2	12.6	3.3	-2.2		
	10%	WB	-6.8	-5.4	-0.2	8.4	13.9	18.2	18.9	17.6	13.0	7.6	0.8	-4.8		
		MCDB	-6.1	-4.6	1.3	13.0	20.6	23.9	24.4	22.1	17.3	10.7	1.7	-4.0		
(35) Mean Daily Temperature Range	MDBR		7.2	8.4	8.4	9.1	10.8	10.1	9.5	9.4	9.0	7.0	5.6	7.0		
	5% DB	MCDBR	6.8	6.7	7.4	13.7	14.5	13.6	12.3	13.1	12.7	11.4	5.6	6.6		
		MCWBR	6.6	6.2	5.7	7.8	6.8	5.6	5.0	5.8	6.6	6.9	4.8	6.3		
	5% WB	MCDBR	6.9	6.7	7.0	13.0	13.3	12.0	10.6	11.1	11.5	10.3	5.3	6.7		
		MCWBR	6.7	6.2	5.6	7.9	7.0	5.4	5.1	5.6	6.4	6.6	4.7	6.4		
(40) Clear-Sky Solar Irradiance	taub		0.280	0.313	0.369	0.413	0.404	0.405	0.429	0.431	0.374	0.354	0.317	0.284		
	taud		2.047	2.023	1.939	2.090	2.231	2.293	2.223	2.185	2.313	2.223	2.095	1.999		
	Ebn at Noon		602	726	767	799	837	840	808	775	777	680	544	482		
	Edh at Noon		66	99	139	139	128	122	129	126	96	82	63	55		
(44) All-Sky Solar Radiation	RadAvg		0.90	1.96	3.52	4.63	5.54	5.90	5.53	4.37	2.98	1.52	0.75	0.57		
	RadStd		0.07	0.10	0.26	0.35	0.39	0.41	0.41	0.38	0.27	0.21	0.11	0.08		

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days					
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)			
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)		
(47)	Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)		

Nomenclature: See separate page