

ABAKAN, Russian Federation

WMO: 287854

Lat: 53.740N

Lon: 91.385E

Elev: 253

StdP: 98.32

Time Zone: 7.00 (E07)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-35.9	-33.0	-39.2	0.1	-35.4	-36.2	0.1	-32.7	10.1	-7.2	9.1	-8.1	0.5	190	0.615

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.6	31.2	19.1	29.8	18.7	27.9	17.8	20.8	28.2	19.8	26.8	19.0	25.5	3.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	13.5	23.1	17.2	12.6	22.3	16.2	11.9	21.8	60.6	28.4	57.5	26.9	54.7	25.5	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.0	8.6	7.5	-36.5	34.4	3.9	2.1	-39.3	36.0	-41.6	37.2	-43.9	38.5	-46.7	40.0		
(5)			-36.6	23.3	4.3	2.2	-39.7	24.9	-42.2	26.2	-44.6	27.5	-47.8	29.1		

Monthly Climatic Design Conditions

		Annual														
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	2.6	-18.5	-15.4	-4.3	5.1	11.7	18.8	20.5	17.9	11.2	3.1	-6.0	-14.4	(6)
(7)		DBStd	14.66	8.45	8.76	6.77	5.04	4.90	3.65	3.05	3.32	4.15	4.80	6.73	7.98	(7)
(8)		HDD10.0	3724	884	710	442	158	39	1	0	0	34	219	481	756	(8)
(9)		HDD18.3	5927	1143	943	700	396	210	38	13	48	218	473	731	1014	(9)
(10)		CDD10.0	1013	0	0	0	12	93	266	324	245	69	4	0	0	(10)
(11)		CDD18.3	174	0	0	0	0	5	53	79	35	2	0	0	0	(11)
(12)		CDH23.3	1939	0	0	0	8	132	609	756	387	47	0	0	0	(12)
(13)		CDH26.7	622	0	0	0	2	31	197	257	122	13	0	0	0	(13)
(14)	Wind	WSAvg	2.7	1.8	2.0	3.0	3.6	3.6	2.9	2.5	2.4	2.7	2.8	2.8	2.3	(14)
(15)	Precipitation	PrecAvg	330	7	6	6	15	30	61	68	63	35	18	12	10	(15)
(16)		PrecMax	532	16	21	22	34	66	163	131	138	82	54	37	21	(16)
(17)		PrecMin	237	1	1	2	1	10	22	22	23	6	4	2	4	(17)
(18)		PrecStd	59	5	4	5	8	15	28	22	31	16	10	8	4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.2	4.0	13.9	24.0	29.9	33.0	34.2	33.0	28.9	19.0	9.9	2.9	(19)
(20)		MCWB	1.4	0.6	6.3	11.7	16.4	18.6	20.3	20.5	16.8	10.8	5.7	0.5		(20)
(21)		2%	DB	-0.1	1.2	10.0	20.2	27.0	30.9	31.9	29.9	23.9	15.2	7.1	0.2	(21)
(22)		MCWB	-2.2	-1.2	4.8	10.4	14.7	18.7	19.5	19.7	15.5	9.6	3.6	-1.9		(22)
(23)		5%	DB	-3.0	-0.8	7.1	17.2	24.1	29.0	29.9	27.8	21.0	12.9	5.0	-1.1	(23)
(24)		MCWB	-4.6	-2.6	2.8	9.1	13.6	17.8	19.1	18.5	14.3	8.0	2.3	-2.9		(24)
(25)		10%	DB	-6.0	-2.9	4.9	14.8	21.2	27.0	27.8	25.1	18.8	10.2	2.9	-3.0	(25)
(26)		MCWB	-7.3	-4.6	1.3	7.9	12.4	17.4	18.4	17.4	13.0	6.4	0.7	-4.6		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.7	0.8	7.4	12.8	18.4	21.3	22.4	22.1	18.0	11.8	6.1	0.6	(27)
(28)		MADB	3.3	3.1	13.1	22.2	28.0	29.3	31.0	30.3	26.6	17.6	8.7	2.4		(28)
(29)		2%	WB	-2.3	-0.9	4.9	11.1	16.1	20.0	20.9	20.3	16.1	10.0	4.1	-1.5	(29)
(30)		MADB	-0.5	1.0	9.3	18.7	23.4	27.7	28.2	27.3	21.8	14.9	6.8	0.3		(30)
(31)		5%	WB	-4.6	-2.7	3.1	9.7	14.6	19.1	20.0	19.2	14.8	8.4	2.3	-3.1	(31)
(32)		MADB	-3.0	-0.8	6.7	16.7	22.2	26.3	27.0	25.5	19.9	12.1	4.7	-1.4		(32)
(33)		10%	WB	-7.4	-4.6	1.4	8.0	13.2	18.1	19.3	18.1	13.5	6.9	0.5	-4.6	(33)
(34)		MADB	-6.1	-2.9	4.4	13.7	19.8	24.9	25.8	23.7	17.8	9.8	2.5	-3.0		(34)
(35)	Mean Daily Temperature Range	MDBR	9.4	11.2	11.8	13.0	13.2	12.8	11.6	12.0	11.6	10.0	7.9	8.5		(35)
(36)		5% DB	MADB	9.7	11.3	14.0	18.5	18.4	16.6	15.2	16.3	16.2	13.6	9.5	8.1	(36)
(37)		MCWBR	8.4	9.3	9.4	10.2	9.0	6.7	5.5	7.2	8.6	8.4	6.8	6.8		(37)
(38)		5% WB	MADB	9.7	11.3	13.0	17.3	15.6	14.1	12.9	14.4	14.5	13.3	9.3	8.2	(38)
(39)		MCWBR	8.6	9.4	9.1	10.1	8.4	6.3	5.5	7.0	7.9	7.9	8.5	7.0	7.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.280	0.315	0.363	0.404	0.411	0.403	0.415	0.401	0.362	0.344	0.318	0.284	(40)	
(41)		taud	2.065	2.021	1.999	2.151	2.189	2.317	2.304	2.314	2.358	2.284	2.128	2.017	(41)	
(42)		Ebn at Noon	651	749	793	819	835	847	828	817	805	723	594	546	(42)	
(43)		Edh at Noon	72	105	135	133	135	121	120	112	95	81	68	62	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.00	2.04	3.52	4.50	5.33	6.09	5.51	4.62	3.25	1.80	0.90	0.65	(44)	
(45)		RadStd	0.07	0.14	0.28	0.24	0.52	0.50	0.34	0.35	0.30	0.16	0.10	0.06	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page