

BUZULUK, Russian Federation

WMO: 289090

Lat: 52.8094N

Lon: 52.2278E

Elev: 262

StdP: 14.56

Time Zone: 5.00 (E05)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.7	-14.7	-26.3	1.3	-20.6	-19.9	1.9	-14.4	20.0	20.2	18.2	19.1	2.5	330	0.546

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.9	92.8	67.6	89.1	66.8	85.9	65.7	70.6	85.7	69.1	83.8	67.7	81.5	6.3	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.9	96.4	75.2	64.4	91.3	74.5	62.8	86.2	73.7	34.6	85.6	33.4	84.0	32.2	81.5	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.0	15.6	13.6	-26.3	97.2	6.2	3.6	-30.8	99.8	-34.4	101.9	-37.9	104.0	-42.5	106.6
			-26.5	73.9	6.2	3.1	-31.0	76.1	-34.6	77.9	-38.1	79.6	-42.6	81.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	42.0	11.3	12.9	24.6	45.0	59.2	67.1	70.4	68.3	56.6	42.5	28.4	16.2	
	DBStd	23.82	13.09	12.82	9.98	10.62	8.65	8.21	6.48	7.90	8.52	8.61	10.91	13.28	
	HDD50	5260	1199	1040	787	220	21	1	0	0	31	264	648	1049	
	HDD65	8933	1664	1460	1252	602	222	71	23	55	275	698	1097	1514	
	CDD50	2352	0	0	0	71	305	514	633	567	229	32	1	0	
	CDD65	548	0	0	0	2	41	133	191	157	24	0	0	0	
	CDH74	6254	0	0	0	43	564	1540	2126	1696	284	1	0	0	
	CDH80	2449	0	0	0	3	155	630	859	723	79	0	0	0	
Wind	WSAvg	5.9	6.3	6.6	6.5	7.0	6.1	5.3	5.1	4.9	4.8	5.6	6.1	6.2	
Precipitation	PrecAvg	20.4	1.8	1.4	1.4	1.4	1.5	2.2	1.9	1.6	1.5	1.9	1.9	1.9	
	PrecMax	27.5	3.7	2.2	2.4	3.5	4.6	5.1	3.7	3.4	4.5	3.5	4.7	3.8	
	PrecMin	12.8	0.5	0.5	0.3	0.2	0.3	0.4	0.2	0.4	0.2	0.6	0.6	0.6	
	PrecStd	3.9	0.6	0.4	0.6	0.8	1.0	1.4	1.0	0.8	0.9	0.8	1.0	0.7	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.1	35.8	53.3	79.4	88.0	96.0	96.3	97.1	87.7	70.6	52.9	37.5	
		MCWB	33.9	33.5	45.3	57.8	63.5	68.0	68.4	67.6	63.3	54.7	50.0	35.8	
	2%	DB	33.5	34.2	43.2	73.4	84.3	91.4	91.8	92.6	81.6	65.2	47.2	35.2	
		MCWB	32.5	32.8	38.6	55.2	62.3	67.1	68.2	67.2	61.1	52.0	44.4	33.9	
	5%	DB	32.0	32.8	39.0	68.2	80.7	87.2	88.3	87.8	76.4	60.3	43.9	34.0	
		MCWB	31.2	31.7	35.6	52.8	61.2	66.0	67.7	66.3	59.4	50.1	41.5	32.8	
	10%	DB	29.5	30.5	36.3	62.7	76.2	82.9	84.9	83.4	71.3	55.8	40.5	32.7	
		MCWB	28.4	29.2	33.9	50.1	59.0	64.9	66.6	65.3	57.3	48.0	38.6	31.6	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	34.6	34.2	45.8	59.3	66.6	72.0	72.9	71.4	65.9	58.0	50.1	36.4
			MCDB	35.1	35.2	52.2	75.8	81.8	87.6	87.4	88.2	81.1	64.3	52.6	37.0
2%		WB	32.7	33.1	39.0	56.5	64.2	69.5	71.1	69.3	62.9	54.1	44.9	34.2	
		MCDB	33.4	34.0	43.0	70.8	79.8	85.8	85.4	85.6	76.8	62.3	46.6	34.8	
5%		WB	31.2	31.7	36.1	53.7	62.1	68.0	69.8	67.9	60.8	51.1	41.8	33.1	
		MCDB	32.1	32.8	38.4	66.7	77.7	82.6	83.4	83.0	72.9	58.3	43.6	33.9	
10%		WB	28.5	29.3	34.2	50.7	60.1	66.3	68.3	66.3	58.6	48.9	38.9	31.6	
		MCDB	29.6	30.5	36.1	61.3	74.4	79.7	81.2	80.6	69.2	54.8	40.5	32.7	
Mean Daily Temperature Range	5% DB	MDBR	12.0	14.2	14.4	18.4	22.1	21.9	21.9	22.1	21.0	14.9	9.3	10.8	
		MCDBR	9.0	9.4	13.3	26.2	28.3	27.3	27.4	27.5	27.9	23.0	11.0	7.3	
		MCWBR	9.3	9.1	9.6	12.3	11.9	9.9	9.3	9.3	12.6	13.1	9.3	7.2	
	5% WB	MCDBR	8.8	9.4	12.2	24.3	26.3	23.6	23.2	24.4	24.8	19.9	9.9	7.3	
		MCWBR	9.0	9.2	9.3	12.3	12.3	10.0	9.0	9.6	12.1	12.8	9.0	7.2	
Clear-Sky Solar Irradiance	taub	0.301	0.325	0.373	0.429	0.406	0.401	0.408	0.427	0.382	0.351	0.328	0.301		
	taud	2.062	2.033	1.983	2.083	2.270	2.340	2.316	2.248	2.338	2.334	2.239	2.083		
	Ebn at Noon	203	238	250	253	268	270	266	252	250	232	197	178		
	Edh at Noon	24	34	44	46	40	38	38	38	31	25	21	20		
All-Sky Solar Radiation	RadAvg	324	679	1124	1421	1800	1957	1923	1588	1065	541	239	194		
	RadStd	45	55	128	152	141	208	165	134	147	95	42	47		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	+1.58	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page