

NOVYY VASYUGAN, Russian Federation

WMO: 292030

Lat: 58.5822N

Lon: 76.5095E

Elev: 80

StdP: 100.37

Time Zone: 7.00 (E07)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-38.2	-35.3	-41.1	0.1	-37.7	-38.2	0.1	-35.4	7.2	-9.6	6.4	-10.2	1.1	340	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	29.6	18.7	27.8	18.0	25.9	17.2	20.3	26.4	19.3	25.1	18.5	23.8	3.2	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.2	13.3	22.5	17.3	12.4	21.5	16.4	11.8	20.9	58.8	26.3	55.4	25.4	52.8	23.3	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.5	6.6	5.9	DB	-41.6	31.4	3.7	0.6	-44.2	31.8	-46.4	32.2	-48.5	32.5	-51.2	33.0	(4)
(5)			WB	-41.4	21.6	3.3	1.6	-43.8	22.8	-45.7	23.8	-47.6	24.7	-49.9	25.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	0.5	-18.9	-15.2	-6.4	2.7	8.4	16.8	18.6	15.5	8.8	0.2	-10.8	-15.2	(6)
(7)		DBStd	14.44	8.31	8.38	6.74	4.72	5.58	5.00	3.56	3.67	4.65	5.48	8.79	9.35	(7)
(8)		HDD10.0	4234	896	707	509	222	101	9	0	2	77	305	625	780	(8)
(9)		HDD18.3	6634	1154	940	768	469	313	86	41	103	287	561	875	1038	(9)
(10)		CDD10.0	751	0	0	0	4	51	213	266	173	42	2	0	0	(10)
(11)		CDD18.3	108	0	0	0	0	4	39	49	15	1	0	0	0	(11)
(12)		CDH23.3	1081	0	0	0	0	57	424	466	127	6	0	0	0	(12)
(13)		CDH26.7	276	0	0	0	0	9	119	127	21	0	0	0	0	(13)
(14)	Wind	WSAvg	2.9	2.6	2.7	3.2	3.3	3.6	2.7	2.5	2.7	3.0	2.9	2.7	(14)	
(15)	Precipitation	PrecAvg	730	46	35	45	43	57	74	76	84	60	70	77	62	(15)
(16)		PrecMax	930	82	59	97	83	131	159	125	148	100	122	116	129	(16)
(17)		PrecMin	536	8	5	9	7	26	30	26	33	15	31	24	22	(17)
(18)		PrecStd	95	19	14	21	16	24	27	26	28	19	25	22	23	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-1.9	2.0	7.5	18.2	28.0	31.5	33.4	29.1	24.2	17.1	4.0	0.1	(19)
(20)			MCWB	-2.3	-0.1	2.1	10.3	14.2	18.8	21.6	19.2	14.9	10.3	3.8	-0.5	(20)
(21)		2%	DB	-3.5	0.4	4.9	15.3	24.8	29.8	29.6	26.4	21.0	12.6	1.6	-0.9	(21)
(22)			MCWB	-4.1	-0.9	0.8	8.7	13.9	18.4	19.1	18.1	14.3	8.1	1.0	-1.4	(22)
(23)		5%	DB	-5.2	-1.3	3.1	12.7	21.8	27.9	27.8	24.5	18.4	10.1	0.7	-2.3	(23)
(24)			MCWB	-5.7	-2.2	0.2	7.3	12.6	18.0	18.5	17.4	13.1	7.4	0.0	-2.9	(24)
(25)		10%	DB	-7.3	-4.4	1.7	10.8	18.3	25.9	25.9	22.7	15.9	7.8	-0.1	-4.2	(25)
(26)			MCWB	-7.8	-5.4	-0.2	5.8	11.1	17.1	17.6	16.9	11.6	5.5	-0.7	-4.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-2.3	0.6	2.9	11.9	16.0	21.1	22.7	20.4	16.3	10.9	3.6	-0.5	(27)
(28)			MCDWB	-2.2	1.6	6.3	16.3	24.0	27.5	29.5	25.9	21.4	16.4	3.9	-0.3	(28)
(29)		2%	WB	-4.0	-0.8	1.5	9.4	14.5	19.7	21.1	19.3	14.8	9.1	1.3	-1.4	(29)
(30)			MCDWB	-3.6	0.2	3.5	14.2	22.2	26.7	27.3	24.7	19.7	12.4	1.6	-1.0	(30)
(31)		5%	WB	-5.7	-2.2	0.7	7.7	13.1	18.9	19.7	18.4	13.6	7.3	0.2	-2.9	(31)
(32)			MCDWB	-5.1	-1.1	2.4	12.3	20.5	25.9	25.3	22.9	17.7	9.9	0.6	-2.3	(32)
(33)		10%	WB	-7.8	-5.3	0.0	6.1	11.7	17.9	18.7	17.4	12.2	5.7	-0.7	-4.6	(33)
(34)			MCDWB	-7.3	-4.3	1.8	10.3	18.4	24.0	23.6	21.1	15.6	7.8	-0.2	-4.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.8	9.0	9.7	9.4	10.4	11.0	10.9	9.7	8.1	6.0	7.2	6.7	(35)
(36)			MCDBR	6.9	5.9	9.6	12.8	14.9	14.2	14.0	13.2	11.6	9.0	4.4	5.7	(36)
(37)			MCWBR	6.7	5.1	6.8	7.9	7.0	5.4	5.6	6.1	5.9	5.6	4.4	5.7	(37)
(38)		5% WB	MCDWB	6.8	5.6	7.5	11.2	13.2	11.7	12.1	10.9	10.2	8.2	4.6	5.5	(38)
(39)			MCWBR	6.7	5.0	5.8	7.3	7.2	5.2	5.8	5.4	5.6	5.5	4.6	5.5	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.274	0.310	0.364	0.394	0.394	0.410	0.439	0.415	0.366	0.340	0.297	0.272	(40)
(41)		taud		2.009	2.017	1.946	2.068	2.281	2.311	2.214	2.266	2.359	2.273	2.077	1.955	(41)
(42)		Ebn at Noon		511	678	744	801	836	827	787	778	763	657	476	365	(42)
(43)		Edh at Noon		55	90	130	137	119	118	127	113	88	71	51	42	(43)
(44)	All-Sky Solar Radiation	RadAvg		0.60	1.56	2.96	4.24	4.90	5.53	5.04	3.77	2.44	1.19	0.51	0.34	(44)
(45)		RadStd		0.07	0.13	0.22	0.44	0.51	0.55	0.45	0.40	0.30	0.11	0.10	0.05	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page