

KANSK, Russian Federation

WMO: 295810

Lat: 56.2017N

Lon: 95.6483E

Elev: 666

StdP: 14.35

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -41.2	(c) -35.4	(d) -45.7	(e) 0.4	(f) -40.9	(g) -40.3	(h) 0.6	(i) -35.3	(j) 25.4	(k) 15.2	(l) 22.8	(m) 12.5	(n) 1.3	(o) 120	(p) 0.612

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.1	85.4	67.4	82.0	65.9	78.9	64.8	70.0	80.7	68.1	78.5	66.3	76.0	5.1	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.2	99.0	75.4	64.4	92.8	73.1	62.6	86.9	71.6	34.5	80.7	32.9	78.5	31.5	76.1	80.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	18.1	15.4	-42.9	91.0	7.0	3.3	-47.9	93.4	-52.0	95.3	-56.0	97.2	-61.1	99.5
			-41.5	73.4	7.4	2.2	-46.8	75.0	-51.2	76.2	-55.3	77.4	-60.7	79.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	32.4	-5.5	1.4	18.3	36.4	49.3	62.5	66.5	61.1	47.8	33.9	14.7	0.2		
	DBStd	27.52	18.00	15.65	13.12	8.80	8.97	7.17	5.22	6.41	7.57	9.54	15.33	17.66		
	HDD50	7846	1721	1361	982	412	127	4	0	4	130	501	1059	1545		
	HDD65	12088	2186	1781	1447	857	491	129	45	154	516	963	1509	2010		
	CDD50	1416	0	0	0	5	106	379	511	347	65	3	0	0		
	CDD65	183	0	0	0	0	5	54	91	32	1	0	0	0		
	CDH74	2011	0	0	0	3	93	712	817	356	30	0	0	0		
	CDH80	496	0	0	0	0	15	202	190	84	5	0	0	0		
	WSAvg	5.4	4.8	5.1	6.1	7.2	6.8	4.7	4.0	3.9	4.8	6.3	6.0	5.3		
	PrecAvg	12.3	0.4	0.4	0.3	0.5	1.1	1.5	2.4	2.1	1.3	0.9	0.6	0.6		
(15) Precipitation	PrecMax	17.4	1.2	1.2	0.9	1.6	2.5	2.8	5.7	4.8	2.7	2.7	1.2	1.3		
	PrecMin	8.6	0.0	0.0	0.0	0.0	0.0	0.5	0.4	0.3	0.2	0.1	0.1	0.0		
	PrecStd	2.6	0.3	0.2	0.2	0.4	0.6	0.6	1.3	1.0	0.7	0.5	0.3	0.3		
	PrecStd	2.6	0.3	0.2	0.2	0.4	0.6	0.6	1.3	1.0	0.7	0.5	0.3	0.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.8	36.1	48.5	68.6	82.1	89.5	89.1	87.1	77.9	62.0	48.8	36.8		
		MCWB	31.3	30.9	39.5	50.1	60.3	66.7	70.3	69.1	61.8	49.3	42.1	32.1		
	2%	DB	29.9	32.1	42.9	61.4	76.5	85.3	85.0	82.0	70.8	55.9	42.3	31.0		
		MCWB	27.0	28.4	36.4	47.4	57.9	65.6	68.6	66.7	58.5	46.9	37.2	28.0		
	5%	DB	25.3	28.6	39.3	56.5	71.5	81.7	81.7	78.0	65.4	51.3	37.7	27.7		
		MCWB	23.0	25.5	33.8	44.8	54.8	64.6	67.2	65.2	56.0	44.5	34.0	25.4		
	10%	DB	20.7	24.0	35.9	51.8	66.7	78.0	78.8	74.2	60.6	47.3	34.3	24.0		
		MCWB	18.7	21.6	31.5	42.6	52.6	63.3	66.1	63.2	53.4	42.0	31.5	21.9		
	0.4%	WB	31.1	31.3	40.4	52.1	63.0	70.3	73.9	71.7	63.9	51.2	42.4	31.9		
		MCDB	34.6	35.1	47.2	64.0	76.6	82.0	84.6	83.3	74.4	59.1	48.1	36.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	27.0	28.6	36.8	48.7	59.4	68.2	70.8	68.6	59.7	48.1	37.7	28.2		
		MCDB	29.6	31.8	42.2	59.5	73.0	80.4	81.2	79.5	69.0	53.8	41.4	31.1		
	5%	WB	23.1	25.6	34.2	45.7	56.7	66.3	68.9	66.2	56.7	45.5	34.4	25.5		
		MCDB	25.3	28.5	38.7	55.5	69.1	78.1	78.7	75.5	63.6	51.1	37.6	27.8		
	10%	WB	18.7	21.6	31.7	42.6	53.9	64.5	67.3	64.2	54.1	42.3	31.6	22.0		
		MCDB	20.7	24.0	35.6	51.5	65.0	76.0	76.4	72.5	59.8	46.8	34.2	24.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	15.6	18.5	20.3	18.5	20.7	21.3	19.1	19.3	18.2	15.5	14.1	15.1		
		MCDBR	15.0	18.1	21.5	28.0	29.5	29.4	24.5	26.4	28.9	23.6	14.9	15.4		
		MCWBR	13.3	15.3	15.6	16.0	14.3	12.5	10.8	13.1	16.2	15.0	11.4	13.7		
		MCDBR	15.0	18.4	20.6	25.8	25.6	24.3	20.8	24.3	24.8	22.6	13.8	15.2		
	5% WB	MCWBR	13.5	15.8	15.5	15.8	13.5	11.7	10.8	12.9	14.4	15.0	11.1	13.6		
		MCWBR	13.5	15.8	15.5	15.8	13.5	11.7	10.8	12.9	14.4	15.0	11.1	13.6		
(40) Clear-Sky Solar Irradiance	taub		0.280	0.313	0.354	0.389	0.411	0.414	0.430	0.409	0.365	0.345	0.310	0.279		
	taud		2.014	2.001	1.974	2.141	2.193	2.273	2.250	2.274	2.352	2.253	2.077	1.970		
	Ebn at Noon		183	226	247	261	262	263	255	253	249	217	169	146		
	Edh at Noon		21	31	42	42	42	39	40	36	29	25	20	17		
(44) All-Sky Solar Radiation	RadAvg		249	568	1015	1389	1596	1887	1728	1395	882	475	237	151		
	RadStd		26	33	62	79	152	156	120	112	105	38	32	17		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page