

TAYSHET, Russian Federation

WMO: 295940

Lat: 55.9495N

Lon: 98.0107E

Elev: 1007

StdP: 14.17

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-35.4	-29.8	-40.0	0.6	-35.2	-34.5	0.8	-29.7	19.8	14.2	17.3	13.2	1.0	120	0.601

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.6	84.6	66.7	81.3	65.3	78.2	63.9	69.4	79.8	67.5	77.4	65.8	75.1	5.6	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.8	98.8	74.8	63.9	92.5	72.8	62.1	86.6	70.7	34.3	80.5	32.7	77.6	31.3	75.1	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.5	14.1	12.1	DB	-39.2	90.5	7.6	3.1	-44.6	92.8	-49.1	94.6	-53.3	96.4	-58.8	98.6
			WB	-38.9	73.4	7.6	2.3	-44.4	75.0	-48.8	76.3	-53.0	77.6	-58.5	79.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	33.5	-1.7	5.5	20.9	36.9	49.4	61.9	65.7	60.7	47.7	34.5	15.3	3.1	(6)
(7)		DBStd	25.81	15.54	14.03	11.97	8.72	9.16	7.34	5.15	6.39	7.69	9.60	15.01	16.32	(7)
(8)		HDD50	7405	1603	1245	902	401	129	5	0	5	135	484	1042	1454	(8)
(9)		HDD65	11667	2068	1665	1367	843	489	142	53	162	520	947	1492	1919	(9)
(10)		CDD50	1372	0	0	0	8	109	361	488	337	66	3	0	0	(10)
(11)		CDD65	159	0	0	0	0	5	49	76	28	1	0	0	0	(11)
(12)		CDH74	1779	0	0	0	4	110	625	700	317	23	0	0	0	(12)
(13)		CDH80	415	0	0	0	0	22	164	159	67	3	0	0	0	(13)
(14)	Wind	WSAvg	4.9	4.3	4.3	5.4	6.2	6.1	4.7	4.1	4.1	4.5	5.1	5.1	4.6	(14)
(15)	Precipitation	PrecAvg	16.8	0.7	0.6	0.5	0.9	1.5	1.7	3.0	2.8	1.8	1.4	1.1	0.9	(15)
(16)		PrecMax	25.1	2.2	1.2	0.9	2.6	2.7	3.7	8.8	7.5	3.9	3.6	1.9	2.2	(16)
(17)		PrecMin	11.4	0.1	0.1	0.1	0.1	0.2	0.2	0.6	0.3	0.4	0.3	0.2	0.3	(17)
(18)		PrecStd	3.3	0.4	0.3	0.2	0.5	0.7	0.9	1.9	1.5	1.0	0.8	0.5	0.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.7	37.0	50.3	68.2	82.6	88.8	88.3	86.5	77.2	62.3	49.4	35.9	(19)
MCWB			30.1	30.9	39.5	50.0	60.1	67.0	70.3	67.9	61.9	49.1	42.2	31.2	(20)	
2%		DB	28.4	32.6	44.6	61.6	76.8	84.5	84.3	81.1	71.0	56.2	42.8	30.5	(21)	
		MCWB	25.6	28.6	36.0	46.9	56.9	65.4	67.9	66.4	57.9	47.2	37.0	27.5	(22)	
5%		DB	24.1	29.3	40.7	56.4	71.9	81.2	81.0	77.4	65.2	51.9	37.9	27.5	(23)	
		MCWB	21.9	26.1	34.0	44.3	54.7	63.9	66.7	64.4	55.0	44.4	33.8	25.3	(24)	
10%		DB	20.0	25.2	36.9	51.6	67.0	77.3	77.9	73.6	60.3	47.7	34.2	24.1	(25)	
		MCWB	18.1	22.5	31.1	41.7	52.1	62.6	65.5	62.7	52.6	41.9	31.4	22.1	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.6	32.1	40.2	51.6	62.1	71.0	72.7	70.4	63.8	51.0	42.7	31.5	(27)
MCDWB			33.4	35.7	48.1	65.0	79.5	83.6	84.3	81.3	74.6	58.7	48.8	34.5	(28)	
2%		WB	26.1	29.0	36.7	48.2	59.0	67.7	70.2	67.8	58.8	47.9	37.8	28.0	(29)	
		MCDWB	28.3	32.2	43.6	59.3	73.9	79.0	80.3	78.8	68.7	55.0	42.2	30.4	(30)	
5%		WB	22.0	26.1	34.2	45.0	56.0	65.7	68.4	65.6	56.1	45.1	34.2	25.3	(31)	
		MCDWB	24.0	29.2	39.8	55.3	69.4	77.3	77.7	75.3	63.2	51.0	37.7	27.4	(32)	
10%		WB	18.0	22.4	31.7	41.9	53.2	63.8	66.7	63.5	53.6	42.3	31.5	22.2	(33)	
		MCDWB	19.9	25.2	36.4	50.9	65.1	75.0	75.3	71.9	59.4	47.1	34.0	24.0	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	14.6	18.1	19.1	17.1	20.5	20.7	18.6	18.3	16.8	14.4	12.9	13.4	(35)
MCDBR			15.7	18.5	22.0	26.4	30.2	28.1	25.0	26.3	26.5	22.6	13.9	13.7	(36)	
MCWBR			13.8	15.1	15.5	14.9	14.9	11.9	11.4	12.8	14.4	14.2	10.4	12.2	(37)	
5% WB		MCDBR	15.5	17.9	19.9	24.1	26.4	23.8	21.1	23.2	23.3	20.8	13.7	13.6	(38)	
		MCWBR	13.8	15.2	14.7	14.7	13.7	11.2	11.1	12.5	13.4	14.0	10.9	12.3	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.282	0.315	0.352	0.385	0.411	0.414	0.430	0.409	0.359	0.344	0.311	0.282	(40)	
(41)		taud	2.015	1.999	1.995	2.165	2.191	2.271	2.255	2.281	2.383	2.267	2.101	1.972	(41)	
(42)		Ebn at Noon	185	226	250	263	263	263	256	253	252	220	172	148	(42)	
(43)		Edh at Noon	21	32	41	41	42	40	39	36	28	25	19	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	260	571	1009	1408	1611	1877	1705	1397	904	482	245	162	(44)	
(45)		RadStd	26	35	58	76	148	135	128	99	103	44	33	21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page