

TAYSHET, Russian Federation

WMO: 295940

Lat: 55.9495N

Lon: 98.0107E

Elev: 307

StdP: 97.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-37.4	-34.3	-40.0	0.1	-37.3	-36.9	0.1	-34.3	8.8	-9.9	7.7	-10.5	0.5	120	0.601

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	29.2	19.3	27.4	18.5	25.7	17.7	20.8	26.5	19.7	25.2	18.8	24.0	2.5	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.8	14.1	23.8	17.7	13.2	22.6	16.7	12.4	21.5	61.8	26.9	58.1	25.3	54.8	23.9	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.4	6.3	5.4	-39.6	32.5	4.2	1.7	-42.6	33.8	-45.0	34.8	-47.4	35.8	-50.5	37.0		
(5)			-39.4	23.0	4.2	1.3	-42.4	23.9	-44.9	24.6	-47.2	25.3	-50.3	26.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	0.8	-18.7	-14.7	-6.2	2.7	9.7	16.6	18.7	15.9	8.7	1.4	-9.3	-16.1	(6)
(7)		DBStd	14.34	8.63	7.79	6.65	4.85	5.09	4.08	2.86	3.55	4.27	5.34	8.34	9.07	(7)
(8)		HDD10.0	4114	891	692	501	223	72	3	0	3	75	269	579	808	(8)
(9)		HDD18.3	6482	1149	925	759	468	272	79	29	90	289	526	829	1066	(9)
(10)		CDD10.0	762	0	0	0	4	61	201	271	187	37	2	0	0	(10)
(11)		CDD18.3	88	0	0	0	0	3	27	42	16	1	0	0	0	(11)
(12)		CDH23.3	988	0	0	0	2	61	347	389	176	13	0	0	0	(12)
(13)		CDH26.7	231	0	0	0	0	12	91	88	37	2	0	0	0	(13)
(14)	Wind	WSAvg	2.2	1.9	1.9	2.4	2.8	2.7	2.1	1.8	1.8	2.0	2.3	2.3	2.1	(14)
(15)	Precipitation	PrecAvg	427	19	14	12	23	38	44	77	70	45	35	27	23	(15)
(16)		PrecMax	638	55	31	24	65	69	95	223	191	100	92	49	56	(16)
(17)		PrecMin	290	3	2	2	3	5	4	14	7	9	7	5	7	(17)
(18)		PrecStd	85	11	8	6	13	17	22	47	37	25	20	12	11	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.9	2.8	10.1	20.1	28.1	31.6	31.3	30.3	25.1	16.8	9.6	2.2	(19)
(20)			MCWB	-1.1	-0.6	4.2	10.0	15.6	19.4	21.3	19.9	16.6	9.5	5.6	-0.4	(20)
(21)		2%	DB	-2.0	0.4	7.0	16.4	24.9	29.2	29.0	27.3	21.7	13.4	6.0	-0.8	(21)
(22)			MCWB	-3.5	-1.9	2.2	8.3	13.9	18.6	19.9	19.1	14.4	8.5	2.8	-2.5	(22)
(23)		5%	DB	-4.4	-1.5	4.8	13.6	22.2	27.3	27.2	25.2	18.5	11.1	3.3	-2.5	(23)
(24)			MCWB	-5.6	-3.3	1.1	6.8	12.6	17.7	19.3	18.0	12.8	6.9	1.0	-3.7	(24)
(25)		10%	DB	-6.7	-3.8	2.7	10.9	19.4	25.2	25.5	23.1	15.7	8.7	1.2	-4.4	(25)
(26)			MCWB	-7.7	-5.3	-0.5	5.4	11.2	17.0	18.6	17.1	11.5	5.5	-0.4	-5.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.8	0.1	4.6	10.9	16.7	21.7	22.6	21.3	17.6	10.6	6.0	-0.3	(27)
(28)			MCDWB	0.8	2.1	9.0	18.3	26.4	28.7	29.0	27.4	23.6	14.8	9.3	1.4	(28)
(29)		2%	WB	-3.3	-1.7	2.6	9.0	15.0	19.9	21.2	19.9	14.9	8.8	3.2	-2.2	(29)
(30)			MCDWB	-2.1	0.1	6.5	15.2	23.3	26.1	26.8	26.0	20.4	12.8	5.7	-0.9	(30)
(31)		5%	WB	-5.5	-3.3	1.2	7.2	13.4	18.7	20.2	18.7	13.4	7.3	1.2	-3.7	(31)
(32)			MCDWB	-4.4	-1.5	4.3	13.0	20.8	25.2	25.4	24.1	17.3	10.6	3.2	-2.5	(32)
(33)		10%	WB	-7.8	-5.3	-0.2	5.5	11.8	17.7	19.3	17.5	12.0	5.7	-0.3	-5.5	(33)
(34)			MCDWB	-6.7	-3.8	2.4	10.5	18.4	23.9	24.0	22.2	15.2	8.4	1.1	-4.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.1	10.0	10.6	9.5	11.4	11.5	10.3	10.2	9.3	8.0	7.2	7.4	(35)
(36)			MCDBR	8.7	10.3	12.2	14.7	16.8	15.6	13.9	14.6	14.7	12.6	7.7	7.6	(36)
(37)			MCWBR	7.7	8.4	8.6	8.3	8.3	6.6	6.3	7.1	8.0	7.9	5.8	6.8	(37)
(38)		5% WB	MCDWR	8.6	10.0	11.1	13.4	14.6	13.2	11.7	12.9	11.6	7.6	7.5	(38)	
(39)			MCWBR	7.6	8.5	8.2	8.1	7.6	6.2	6.2	6.9	7.4	7.8	6.1	6.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.282	0.315	0.352	0.385	0.411	0.414	0.430	0.409	0.359	0.344	0.311	0.282	(40)	
(41)		taud	2.015	1.999	1.995	2.165	2.191	2.271	2.255	2.281	2.383	2.267	2.101	1.972	(41)	
(42)		Ebn at Noon	582	713	787	828	828	830	807	798	794	692	543	465	(42)	
(43)		Edh at Noon	66	100	130	128	133	125	124	114	89	78	61	54	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.82	1.80	3.18	4.44	5.08	5.92	5.37	4.41	2.85	1.52	0.77	0.51	(44)	
(45)		RadStd	0.08	0.11	0.18	0.24	0.47	0.43	0.41	0.31	0.33	0.14	0.10	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page