

AGINSKOYE, Russian Federation

WMO: 296760

Lat: 55.2702N

Lon: 94.8999E

Elev: 1106

StdP: 14.12

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-40.9	-33.8	-44.7	0.4	-40.1	-37.8	0.7	-33.1	19.0	15.2	16.6	18.9	1.1	0	0.598

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.4	82.9	66.2	79.8	64.7	76.8	63.6	69.2	78.4	67.3	76.2	65.5	73.7	4.0	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.1	100.3	73.2	64.1	93.4	71.4	62.3	87.4	69.9	34.1	78.8	32.5	76.4	31.1	73.8	79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.5	13.2	11.2	DB	-42.9	88.5	8.2	2.2	-48.8	90.0	-53.6	91.3	-58.2	92.5	-64.2	94.0	(4)
(5)			WB	-42.5	73.1	7.5	1.8	-47.8	74.4	-52.2	75.5	-56.4	76.5	-61.8	77.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	33.0	-1.4	5.2	21.0	36.3	47.5	60.1	63.8	59.0	46.7	34.5	17.2	4.5	(6)
(7)		DBStd	25.19	17.98	16.20	13.15	8.84	8.34	6.72	4.86	6.03	7.40	9.77	15.06	17.51	(7)
(8)		HDD50	7356	1594	1254	900	417	151	7	0	5	148	486	983	1411	(8)
(9)		HDD65	11764	2059	1674	1365	860	544	173	81	203	549	947	1433	1876	(9)
(10)		CDD50	1151	0	0	0	7	73	309	427	283	49	3	0	0	(10)
(11)		CDD65	85	0	0	0	0	1	25	43	16	0	0	0	0	(11)
(12)		CDH74	1254	0	0	0	5	61	478	439	230	41	0	0	0	(12)
(13)		CDH80	237	0	0	0	1	6	106	76	40	8	0	0	0	(13)
(14)	Wind	WSAvg	3.8	3.2	3.6	4.3	5.1	5.1	3.5	2.8	2.9	3.5	4.2	4.0	3.6	(14)
(15)	Precipitation	PrecAvg	19.5	0.5	0.5	0.5	1.1	1.7	3.0	3.3	3.7	2.2	1.3	1.0	0.8	(15)
(16)		PrecMax	25.1	0.7	1.1	1.3	2.0	3.4	5.1	8.0	9.3	6.4	2.6	1.9	1.8	(16)
(17)		PrecMin	11.6	0.2	0.1	0.1	0.2	0.3	0.9	0.6	1.7	0.2	0.4	0.6	0.2	(17)
(18)		PrecStd	3.2	0.2	0.3	0.3	0.5	0.7	1.1	1.8	1.6	1.1	0.5	0.4	0.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.5	41.0	54.6	71.4	80.7	87.0	86.2	84.8	79.9	65.1	52.0	41.0	(19)
MCWB			32.9	33.4	41.7	51.7	58.7	65.9	69.5	68.8	61.0	52.1	42.7	33.3	(20)	
2%		DB	33.9	35.9	47.8	63.1	75.4	83.3	82.0	79.6	70.5	58.4	46.8	34.6	(21)	
		MCWB	29.1	30.3	38.2	47.6	56.9	65.1	67.6	65.9	57.5	48.5	39.4	29.2	(22)	
5%		DB	29.4	32.7	43.2	57.6	70.9	79.8	79.0	76.1	65.1	53.3	41.9	31.2	(23)	
		MCWB	25.8	28.2	35.8	45.0	54.7	64.0	66.3	64.2	54.6	45.0	36.0	27.0	(24)	
10%		DB	24.5	28.6	38.8	52.8	65.8	75.9	76.0	72.4	60.1	49.0	37.6	28.0	(25)	
		MCWB	21.7	25.0	33.1	42.9	52.9	62.3	65.1	62.4	52.7	42.4	33.1	24.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	34.1	34.2	43.0	52.8	62.4	70.7	72.8	70.2	63.0	53.7	44.3	33.9	(27)
MCD B			37.3	39.7	52.7	66.4	74.2	80.2	81.0	80.5	73.4	62.1	50.4	40.1	(28)	
2%		WB	29.4	30.9	39.1	49.1	58.9	68.1	69.8	67.8	58.9	49.4	39.9	29.6	(29)	
		MCD B	33.8	35.4	46.6	61.1	72.5	78.7	78.2	77.3	67.9	57.1	45.7	34.3	(30)	
5%		WB	25.9	28.2	36.3	45.8	56.4	66.0	67.9	65.5	56.1	45.9	36.3	27.3	(31)	
		MCD B	29.3	32.4	42.6	56.1	68.3	76.1	76.2	73.9	63.3	52.4	41.4	31.1	(32)	
10%		WB	21.8	25.0	33.4	43.0	53.5	63.8	66.2	63.2	53.5	42.8	33.2	24.5	(33)	
		MCD B	24.8	28.7	38.4	52.4	63.7	73.1	73.5	70.6	59.1	48.5	37.2	27.9	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	19.6	22.0	22.6	20.6	22.3	22.9	19.4	20.2	20.2	17.2	16.7	17.6	(35)
MCDBR			18.8	20.6	27.4	31.7	34.0	32.2	26.2	28.5	32.2	27.8	19.7	18.9	(36)	
MCWBR			15.3	16.3	18.6	18.1	17.6	15.1	13.0	15.2	18.5	17.3	14.1	15.4	(37)	
5% WB		MCD BR	18.6	19.4	24.9	28.7	28.4	25.5	21.9	25.7	27.7	25.9	18.8	18.8	(38)	
		MCWBR	15.4	15.7	17.5	17.5	16.0	13.4	12.4	14.9	17.0	16.6	14.1	15.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.272	0.308	0.351	0.391	0.409	0.402	0.420	0.402	0.360	0.339	0.306	0.276	(40)	
taud		2.063	2.040	2.025	2.153	2.194	2.318	2.287	2.308	2.374	2.284	2.115	2.001	(41)		
Ebn at Noon		198	234	252	262	264	268	259	257	253	225	181	160	(42)		
Edh at Noon		21	31	41	42	42	38	38	36	29	25	20	18	(43)		
(44)	All-Sky Solar Radiation	RadAvg	271	587	1035	1369	1549	1846	1654	1357	892	497	258	171	(44)	
(45)		RadStd	27	39	76	75	163	169	135	118	107	40	30	16	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	-0.97	N/A	N/A	N/A	N/A	
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page