

AGINSKOYE, Russian Federation

WMO: 296760

Lat: 55.2702N

Lon: 94.8999E

Elev: 337

StdP: 97.34

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-40.5	-36.6	-42.6	0.1	-40.1	-38.8	0.1	-36.2	8.5	-9.3	7.4	-7.3	0.5	0	0.598

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	28.3	19.0	26.6	18.2	24.9	17.6	20.7	25.8	19.6	24.6	18.6	23.2	1.8	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.0	14.3	22.9	17.8	13.3	21.9	16.8	12.5	21.1	61.5	26.0	57.8	24.6	54.5	23.2	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.9	5.9	5.0	-41.6	31.4	4.6	1.2	-44.9	32.2	-47.6	32.9	-50.1	33.6	-53.4	34.5		
			-41.4	22.8	4.2	1.0	-44.4	23.6	-46.8	24.1	-49.1	24.7	-52.1	25.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	0.6	-18.6	-14.9	-6.1	2.4	8.6	15.6	17.6	15.0	8.2	1.4	-8.2	-15.3
	DBStd	14.00	9.99	9.00	7.31	4.91	4.64	3.73	2.70	3.35	4.11	5.43	8.37	9.73
	HDD10.0	4087	886	697	500	232	84	4	0	3	82	270	546	784
	HDD18.3	6536	1144	930	758	478	302	96	45	113	305	526	796	1042
	CDD10.0	639	0	0	0	4	41	172	237	157	27	2	0	0
	CDD18.3	47	0	0	0	0	1	14	24	9	0	0	0	0
	CDH23.3	697	0	0	0	3	34	266	244	128	23	0	0	0
	CDH26.7	132	0	0	0	1	3	59	42	22	4	0	0	0
Wind	WSAvg	1.7	1.4	1.6	1.9	2.3	2.3	1.6	1.3	1.3	1.6	1.9	1.8	1.6
Precipitation	PrecAvg	495	12	12	13	27	44	75	84	95	56	32	25	21
	PrecMax	638	19	28	34	51	87	129	204	236	163	66	48	46
	PrecMin	295	5	3	3	4	8	23	15	42	6	11	15	5
	PrecStd	82	4	7	7	13	19	27	45	41	29	13	9	10
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.2	5.0	12.5	21.9	27.0	30.6	30.1	29.3	26.6	18.4	11.1	5.0
		MCWB	0.5	0.8	5.4	11.0	14.8	18.9	20.8	20.4	16.1	11.2	6.0	0.7
	2%	DB	1.1	2.2	8.8	17.3	24.1	28.5	27.8	26.4	21.4	14.7	8.2	1.5
		MCWB	-1.6	-1.0	3.4	8.7	13.8	18.4	19.8	18.8	14.2	9.2	4.1	-1.5
	5%	DB	-1.4	0.4	6.2	14.2	21.6	26.6	26.1	24.5	18.4	11.8	5.5	-0.4
		MCWB	-3.4	-2.1	2.1	7.2	12.6	17.8	19.0	17.9	12.6	7.2	2.2	-2.8
	10%	DB	-4.2	-1.9	3.8	11.5	18.8	24.4	24.4	22.4	15.6	9.4	3.1	-2.2
		MCWB	-5.7	-3.9	0.6	6.1	11.6	16.8	18.4	16.9	11.5	5.8	0.6	-4.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.2	1.2	6.1	11.5	16.9	21.5	22.6	21.2	17.2	12.1	6.8	1.0
		MCDB	2.9	4.3	11.5	19.1	23.4	26.8	27.2	27.0	23.0	16.7	10.2	4.5
	2%	WB	-1.5	-0.6	3.9	9.5	14.9	20.1	21.0	19.9	15.0	9.7	4.4	-1.3
		MCDB	1.0	1.9	8.1	16.2	22.5	25.9	25.7	25.2	20.0	14.0	7.6	1.3
	5%	WB	-3.4	-2.1	2.4	7.7	13.5	18.9	19.9	18.6	13.4	7.7	2.4	-2.6
		MCDB	-1.5	0.2	5.9	13.4	20.2	24.5	24.6	23.3	17.4	11.3	5.2	-0.5
	10%	WB	-5.7	-3.9	0.8	6.1	11.9	17.7	19.0	17.3	12.0	6.0	0.7	-4.2
		MCDB	-4.0	-1.8	3.6	11.3	17.6	22.8	23.0	21.5	15.1	9.2	2.9	-2.3
Mean Daily Temperature Range	5% DB	MDBR	10.9	12.2	12.6	11.4	12.4	12.7	10.8	11.2	11.2	9.6	9.3	9.8
		MCDBR	10.4	11.5	15.2	17.6	18.9	17.9	14.6	15.8	17.9	15.4	10.9	10.5
		MCWBR	8.5	9.0	10.3	10.0	9.8	8.4	7.2	8.4	10.3	9.6	7.8	8.5
	5% WB	MCDBR	10.3	10.8	13.8	16.0	15.8	14.2	12.2	14.3	15.4	14.4	10.5	10.4
		MCWBR	8.6	8.7	9.7	9.7	8.9	7.5	6.9	8.3	9.4	9.2	7.8	8.7
Clear-Sky Solar Irradiance	taub	0.272	0.308	0.351	0.391	0.409	0.402	0.420	0.402	0.360	0.339	0.306	0.276	
	taud	2.063	2.040	2.025	2.153	2.194	2.318	2.287	2.308	2.374	2.284	2.115	2.001	
	Ebn at Noon	625	739	796	825	832	844	818	809	798	710	571	505	
	Edh at Noon	66	98	128	131	133	119	121	112	91	78	63	56	
All-Sky Solar Radiation	RadAvg	0.85	1.85	3.26	4.32	4.88	5.82	5.21	4.28	2.81	1.57	0.81	0.54	
	RadStd	0.09	0.12	0.24	0.24	0.52	0.53	0.42	0.37	0.34	0.12	0.10	0.05	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	-0.54	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page