

NENASTNAYA PRIISKOVOYE, Russian Federation

WMO: 297520

Lat: 54.6581N

Lon: 88.6798E

Elev: 1188

StdP: 87.84

Time Zone: 7.00 (E07)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-29.6	-27.3	-32.7	0.2	-27.8	-30.6	0.3	-25.6	13.3	-16.9	12.2	-15.3	3.5	250	0.725

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.7	22.9	14.8	21.2	14.2	19.6	13.5	16.0	20.9	15.1	19.7	14.3	18.3	1.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.1	11.6	17.6	13.3	11.0	16.8	12.6	10.5	16.3	49.1	20.9	46.5	19.8	44.1	18.4	18.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.7	9.5	8.3	DB	-31.3	26.0	3.6	2.0	-33.9	27.4	-36.0	28.6	-38.0	29.7	-40.6	31.2	(4)
(5)			WB	-31.5	17.7	3.5	1.0	-34.0	18.4	-36.1	19.0	-38.1	19.6	-40.6	20.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.0	-15.2	-13.5	-6.8	0.1	3.7	12.5	13.7	12.0	5.6	-1.7	-10.4	-13.0	(6)	
	DBStd	11.62	6.10	6.42	5.72	5.68	5.35	4.72	3.33	3.66	5.38	6.25	6.47	6.39	(7)	
	HDD10.0	4362	781	658	519	301	206	31	7	20	152	364	611	712	(8)	
	HDD18.3	7067	1039	891	778	548	453	181	148	198	381	619	861	970	(9)	
	CDD10.0	346	0	0	0	2	12	104	121	82	22	3	0	0	(10)	
	CDD18.3	10	0	0	0	0	0	4	4	2	1	0	0	0	(11)	
	CDH23.3	38	0	0	0	0	0	15	15	6	2	0	0	0	(12)	
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0	(13)	
	WSAvg	3.4	4.4	4.0	4.1	3.5	3.0	2.1	1.8	2.0	2.7	3.7	5.0	4.9	(14)	
(15) Precipitation	PrecAvg	1496	99	83	108	120	120	117	113	127	133	174	160	143	(15)	
	PrecMax	1813	255	187	242	299	278	198	183	312	242	297	261	265	(16)	
	PrecMin	1166	11	9	41	38	24	48	61	35	21	83	102	47	(17)	
	PrecStd	181	54	41	51	54	63	38	32	55	53	54	43	61	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.2	1.2	11.2	17.2	19.8	25.4	25.4	24.1	21.9	15.5	6.3	0.9	(19)	
		MCWB	-3.9	-1.8	3.6	9.2	10.3	16.0	16.3	15.1	12.2	7.6	2.5	-2.7	(20)	
	2%	DB	-3.5	-1.8	7.0	13.0	16.5	23.0	22.5	21.5	18.6	12.6	2.9	-1.4	(21)	
		MCWB	-5.8	-4.7	1.4	6.7	8.7	14.7	15.1	14.4	10.9	5.7	-0.6	-4.3	(22)	
	5%	DB	-5.4	-3.5	3.7	10.5	14.1	21.2	20.7	19.6	15.8	10.4	0.3	-3.3	(23)	
		MCWB	-7.5	-5.8	-0.2	4.9	7.6	14.1	14.7	13.9	9.7	5.1	-1.9	-5.5	(24)	
	10%	DB	-7.2	-5.3	1.1	8.3	12.1	19.5	18.8	17.6	13.2	7.3	-2.1	-4.9	(25)	
		MCWB	-8.6	-7.0	-2.1	3.9	6.3	13.2	14.0	13.0	8.4	3.7	-3.8	-6.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-3.1	-1.1	4.5	9.3	11.6	17.2	17.2	16.8	13.5	8.6	4.2	-2.0	(27)	
		MCDB	-1.2	1.0	10.6	16.8	17.3	23.3	22.2	21.0	20.8	13.2	6.2	0.1	(28)	
	2%	WB	-5.6	-4.2	2.0	7.1	9.8	15.7	16.0	15.3	11.6	6.9	0.0	-3.8	(29)	
		MCDB	-3.6	-2.5	6.5	11.8	15.0	21.2	20.9	19.5	17.0	11.3	2.0	-2.3	(30)	
	5%	WB	-7.4	-5.6	0.0	5.6	8.5	14.8	15.2	14.4	10.3	5.4	-1.6	-5.1	(31)	
		MCDB	-5.8	-3.9	3.1	9.5	12.4	19.7	19.5	18.2	14.4	9.2	0.5	-3.5	(32)	
	10%	WB	-8.7	-6.9	-1.8	4.2	7.2	13.9	14.4	13.6	9.1	3.9	-3.6	-6.5	(33)	
		MCDB	-7.2	-5.2	1.0	7.8	11.3	18.3	18.1	17.0	12.2	7.2	-2.5	-4.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.9	7.9	8.8	8.1	7.1	7.6	6.7	6.6	6.5	5.5	6.0	5.9	(35)	
		MCDBR	8.8	9.9	12.6	10.6	9.0	9.8	8.9	9.4	9.9	8.1	6.8	7.2	(36)	
	5% WB	MCWBR	7.0	7.9	8.8	6.6	5.1	5.0	4.4	4.5	5.1	4.6	5.0	5.7	(37)	
		MCWBR	8.4	9.6	11.6	10.3	8.3	8.7	7.7	7.7	8.7	7.6	6.4	6.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.245	0.278	0.320	0.356	0.364	0.361	0.376	0.364	0.332	0.312	0.274	0.246	(40)	
		taud	2.104	2.085	2.022	2.108	2.276	2.389	2.351	2.365	2.413	2.307	2.092	2.027	(41)	
	Ebn at Noon		694	795	838	862	879	886	862	851	835	755	630	583	(42)	
		Edh at Noon	64	95	128	137	123	111	114	106	88	76	65	55	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.90	1.88	3.26	4.46	5.06	5.72	5.08	4.24	2.90	1.56	0.82	0.57	(44)	
	RadStd		0.11	0.18	0.26	0.26	0.62	0.55	0.35	0.41	0.34	0.17	0.12	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page