

VERKHNYAYA GUTARA, Russian Federation

WMO: 297890

Lat: 54.2129N

Lon: 96.9693E

Elev: 3228

StdP: 13.06

Time Zone: 8.00 (E08)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-33.8	-29.4	-36.3	0.8	-33.3	-31.8	1.0	-29.4	11.3	9.6	9.8	11.9	0.3	200	0.679

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.1	79.8	60.6	76.1	59.6	72.4	58.2	63.7	74.4	61.9	71.9	60.1	69.3	2.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.1	87.6	67.1	58.3	82.1	65.0	56.5	76.7	63.2	30.8	74.4	29.4	71.8	28.1	69.5	69.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.5	7.7	6.3	-38.9	87.4	6.4	3.0	-43.5	89.6	-47.2	91.4	-50.8	93.1	-55.4	95.3		
(5)			-39.0	66.9	6.3	1.8	-43.5	68.2	-47.2	69.3	-50.8	70.3	-55.4	71.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	29.3	-2.2	3.4	17.7	31.5	41.5	54.0	58.5	54.8	44.0	29.9	13.6	3.0		
	DBStd	23.04	12.42	12.36	10.96	9.82	7.31	6.85	4.84	5.82	7.16	9.50	12.58	13.33		
	HDD50	8200	1619	1305	1001	555	278	39	3	21	207	623	1093	1456		
	HDD65	13048	2084	1725	1466	1004	730	333	205	319	630	1088	1543	1921		
	CDD50	635	0	0	0	0	13	159	267	169	27	0	0	0		
	CDD65	8	0	0	0	0	0	2	4	2	0	0	0	0		
	CDH74	542	0	0	0	0	13	196	187	128	18	0	0	0		
	CDH80	95	0	0	0	0	0	35	31	27	2	0	0	0		
(14) Wind	WSAvg	1.8	1.4	1.7	2.2	2.3	2.5	1.7	1.3	1.2	1.7	1.8	1.7	1.7		
(15) Precipitation	PrecAvg	20.4	0.2	0.2	0.3	1.2	1.9	3.0	5.6	4.2	2.2	0.9	0.4	0.2		
	PrecMax	31.6	0.7	2.2	1.0	3.3	5.2	5.0	10.5	8.9	6.5	1.8	0.8	0.7		
	PrecMin	15.2	0.0	0.0	0.0	0.4	0.2	1.0	2.7	1.2	0.4	0.2	0.0	0.0		
	PrecStd	3.2	0.1	0.4	0.2	0.7	0.9	1.1	1.8	1.7	1.1	0.4	0.2	0.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.8	37.5	51.5	65.8	75.7	84.6	83.9	84.2	76.8	61.5	44.8	35.8		
		MCWB	26.6	30.3	38.8	46.4	54.3	61.0	63.2	62.2	56.6	45.8	36.9	29.4		
	2%	DB	26.8	31.5	45.9	58.4	69.9	79.3	78.8	77.5	69.6	54.6	39.8	29.0		
		MCWB	22.7	25.9	36.3	43.3	50.9	59.0	62.6	60.3	54.0	42.9	33.3	24.2		
	5%	DB	22.0	27.2	40.7	53.5	64.4	75.5	75.2	72.1	63.9	48.7	35.5	25.5		
		MCWB	18.6	23.0	32.8	40.7	48.0	58.1	61.6	59.1	50.9	39.7	31.1	21.7		
	10%	DB	16.9	22.9	36.2	48.7	58.9	71.0	71.2	67.5	58.3	43.7	30.9	22.4		
		MCWB	14.4	19.7	29.9	38.5	45.5	56.5	60.0	57.5	48.9	36.7	26.9	19.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.5	30.6	40.3	47.6	55.2	64.5	66.5	64.6	58.7	46.8	37.3	30.4		
		MCDB	31.5	36.8	50.2	61.7	73.4	77.3	76.0	75.9	71.3	59.6	44.0	35.0		
	2%	WB	22.8	26.2	36.3	44.1	51.9	61.8	64.4	62.6	55.1	43.6	34.1	24.8		
		MCDB	26.8	30.8	45.5	56.0	67.1	73.0	74.9	73.6	66.4	53.5	39.0	27.8		
	5%	WB	18.6	23.2	33.1	41.4	48.8	59.9	62.7	60.3	52.4	40.5	30.9	21.9		
		MCDB	21.8	27.2	40.1	52.2	61.8	71.4	72.4	70.1	61.3	48.2	35.5	25.3		
	10%	WB	14.4	19.7	30.0	39.0	46.3	58.0	61.0	58.1	49.4	37.2	27.3	19.4		
		MCDB	16.7	23.0	35.8	48.3	57.7	68.8	69.6	66.4	57.2	43.2	30.5	22.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	23.8	27.9	28.5	24.1	24.3	25.9	22.1	21.7	24.2	21.7	20.4	20.3		
		MCDBR	26.4	29.7	32.7	33.9	38.6	37.3	31.7	33.0	36.8	31.3	21.6	20.8		
		MCWBR	22.6	24.3	23.4	19.1	20.0	18.1	16.3	16.7	20.1	18.8	15.7	17.2		
	5% WB	MCDBR	25.9	28.7	31.2	29.8	34.6	30.0	26.2	28.1	31.9	30.0	20.7	20.8		
		MCWBR	22.3	23.4	22.4	17.4	18.6	15.8	14.7	15.5	18.0	18.3	15.3	17.5		
(40) Clear-Sky Solar Irradiance	taub		0.255	0.289	0.331	0.371	0.389	0.380	0.391	0.371	0.332	0.309	0.283	0.257		
	taud		2.112	2.088	2.059	2.104	2.179	2.351	2.350	2.373	2.432	2.325	2.126	2.049		
	Ebn at Noon		219	249	263	269	271	275	270	268	266	243	201	185		
	Edh at Noon		21	30	40	44	43	37	36	33	28	24	21	18		
(44) All-Sky Solar Radiation	RadAvg		312	623	1052	1426	1555	1703	1560	1332	952	558	299	208		
	RadStd		31	50	72	67	142	159	136	108	107	52	34	20		

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days				
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	-0.85	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page