

IKA, Russian Federation

WMO: 300280

Lat: 59.311N

Lon: 106.347E

Elev: 1153

StdP: 14.09

Time Zone: 8.00 (E08)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -53.9	(c) -48.8	(d) -57.9	(e) 0.2	(f) -53.9	(g) -53.1	(h) 0.2	(i) -48.6	(j) 16.4	(k) 5.5	(l) 14.8	(m) 4.2	(n) 0.8	(o) 180	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 24.8	(c) 83.5	(d) 64.1	(e) 79.8	(f) 62.8	(g) 76.2	(h) 61.2	(i) 66.2	(j) 78.3	(k) 64.4	(l) 76.7	(m) 62.7	(n) 73.4	(o) 5.4	(p) 50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.0	86.8	70.4	60.1	80.9	68.4	58.1	75.2	66.9	31.7	78.0	30.2	76.8	28.9	73.7	77.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.2	14.1	12.1	-59.3	89.0	3.1	2.5	-61.5	90.8	-63.4	92.3	-65.1	93.7	-67.4	95.5
			-59.3	69.9	3.1	2.9	-61.5	72.0	-63.4	73.7	-65.1	75.3	-67.4	77.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.5	-18.2	-10.7	7.5	25.7	40.9	57.1	60.5	55.1	41.5	22.7	-1.3	-13.5		
	DBStd	30.52	17.43	16.50	13.87	10.97	7.69	7.56	5.68	5.91	7.70	11.57	18.05	18.32		
	HDD50	10830	2114	1700	1319	730	298	23	1	21	273	845	1538	1968		
	HDD65	15568	2579	2120	1784	1180	748	250	161	309	706	1310	1988	2433		
	CDD50	777	0	0	0	0	16	238	326	179	18	0	0	0		
	CDD65	37	0	0	0	0	0	14	21	2	0	0	0	0		
	CDH74	1203	0	0	0	0	13	544	509	131	6	0	0	0		
	CDH80	287	0	0	0	0	0	148	116	23	0	0	0	0		
(14) Wind	WSAvg	4.3	3.1	3.5	4.8	5.7	5.7	4.8	4.1	3.9	4.0	4.5	4.0	3.6		
(15) Precipitation	PrecAvg	11.3	0.4	0.3	0.3	0.6	1.1	1.8	2.3	1.8	1.1	0.9	0.6	0.4		
	PrecMax	15.5	0.9	0.6	1.0	1.4	2.5	3.3	6.0	3.6	2.5	1.7	1.0	0.9		
	PrecMin	7.4	0.1	0.0	0.1	0.2	0.3	0.4	0.4	0.4	0.4	0.2	0.3	0.1		
	PrecStd	2.3	0.2	0.2	0.2	0.3	0.5	0.8	1.6	0.8	0.5	0.4	0.2	0.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.2	29.5	45.5	57.6	76.0	88.1	87.0	83.9	73.6	50.8	40.4	29.0		
		MCWB	23.2	26.2	36.6	43.5	54.7	65.4	65.4	64.2	58.4	41.2	37.5	26.4		
	2%	DB	18.7	25.1	39.2	52.7	68.4	84.4	83.0	77.5	66.0	45.2	33.4	24.1		
		MCWB	17.0	22.6	33.0	41.6	51.7	63.7	64.7	61.8	53.5	39.0	31.2	22.4		
	5%	DB	13.8	20.2	33.9	47.7	63.3	80.6	79.7	73.7	59.9	40.6	29.0	19.8		
		MCWB	12.5	18.2	29.4	38.1	49.5	62.4	63.9	60.3	50.7	36.0	26.7	18.5		
	10%	DB	8.6	14.9	29.6	43.0	57.9	76.8	76.1	69.5	55.5	36.8	25.3	14.8		
		MCWB	7.5	13.3	25.9	35.4	46.2	60.5	62.1	58.5	48.3	33.6	23.4	13.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.2	26.5	37.6	44.9	56.8	67.9	69.0	66.7	60.1	42.5	37.8	27.1		
		MCDB	24.6	29.1	43.4	55.3	72.9	81.3	79.7	75.9	70.9	48.5	39.9	29.1		
	2%	WB	17.0	23.0	33.3	41.8	52.8	65.6	66.7	64.0	55.7	39.4	31.4	22.6		
		MCDB	18.6	25.3	38.7	51.7	66.5	80.4	78.0	74.2	63.6	44.6	33.2	24.2		
	5%	WB	12.5	18.2	29.7	38.9	50.0	63.7	65.1	62.2	52.1	36.0	26.8	18.5		
		MCDB	13.8	20.3	33.8	46.3	61.7	77.6	76.6	71.0	58.0	39.5	28.7	19.7		
	10%	WB	7.5	13.4	26.2	36.1	47.3	61.7	63.4	59.9	48.9	33.9	23.4	13.5		
		MCDB	8.7	15.0	29.7	42.6	56.9	74.7	74.0	67.6	54.6	36.8	25.4	14.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	21.1	28.2	31.5	24.8	22.8	27.1	24.8	24.7	21.5	17.1	19.2	18.8		
		MCDBR	23.4	25.9	30.5	29.3	33.4	37.1	33.6	34.1	31.1	21.8	15.1	18.7		
		MCWBR	22.4	23.5	24.6	19.4	18.8	18.3	16.8	19.0	19.4	15.8	14.5	17.9		
	5% WB	MCDBR	23.5	24.8	29.2	26.2	31.3	32.0	28.5	27.8	28.5	19.7	15.0	19.1		
		MCWBR	22.5	22.5	23.7	17.8	18.5	16.6	15.7	16.7	18.7	15.1	14.3	18.4		
(40) Clear-Sky Solar Irradiance	taub		0.256	0.292	0.314	0.346	0.376	0.409	0.479	0.425	0.339	0.308	0.258	0.233		
	taud		1.976	2.011	2.053	2.115	2.283	2.292	2.071	2.196	2.438	2.298	2.028	1.925		
	Ebn at Noon		160	219	255	269	270	261	237	242	252	219	158	122		
	Edh at Noon		17	28	36	41	37	38	46	38	25	21	15	12		
(44) All-Sky Solar Radiation	RadAvg		176	481	971	1461	1642	1817	1658	1307	804	387	202	102		
	RadStd		12	31	62	85	105	137	143	95	77	43	21	10		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page