

NIZHNEANGARSK, Russian FederationWMO: **304330**Lat: **55.791N**Lon: **109.581E**Elev: **1573**StdP: **13.88**Time Zone: **8.00 (E08)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.5	-20.1	-31.4	1.0	-22.1	-27.2	1.3	-18.5	17.4	-1.5	15.0	3.6	1.6	10	0.655

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.2	79.5	62.9	76.1	61.7	73.0	60.6	65.6	74.8	64.1	72.3	62.4	70.0	6.6	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.7	90.4	69.0	61.0	85.0	67.4	59.2	79.7	66.0	31.5	75.3	30.2	72.3	29.0	70.1	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.2	13.0	11.1	DB	-29.4	85.8	6.5	2.6	-34.0	87.6	-37.8	89.2	-41.4	90.6	-46.1	92.5	(4)
(5)			WB	-29.6	68.7	6.4	1.0	-34.2	69.4	-37.9	70.0	-41.5	70.6	-46.1	71.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	29.2	-5.8	-2.5	11.4	29.1	42.4	55.9	63.8	60.4	47.7	31.5	13.1	1.5	(6)	
	DBStd	25.53	9.18	10.08	10.20	7.68	6.53	7.16	6.10	5.82	6.68	8.29	11.42	9.99	(7)	
	HDD50	8601	1730	1470	1195	626	250	22	0	3	120	574	1107	1504	(8)	
	HDD65	13152	2195	1890	1660	1076	700	286	98	163	519	1039	1557	1969	(9)	
	CDD50	1017	0	0	0	0	16	198	427	325	51	0	0	0	(10)	
	CDD65	93	0	0	0	0	0	12	60	21	0	0	0	0	(11)	
	CDH74	528	0	0	0	0	1	99	340	87	1	0	0	0	(12)	
	CDH80	75	0	0	0	0	0	10	58	7	0	0	0	0	(13)	
	Wind	WSAvg	4.0	3.2	2.7	3.4	4.5	4.7	4.3	4.3	4.5	4.3	4.4	3.9	(14)	
	Precipitation	PrecAvg	14.7	0.6	0.6	0.5	0.8	1.1	1.7	2.4	2.6	1.7	1.3	0.9	0.6	(15)
(16)		PrecMax	20.0	2.5	1.1	1.5	2.0	2.8	3.4	6.1	4.4	3.4	3.3	2.2	1.6	(16)
(17)		PrecMin	9.6	0.1	0.2	0.0	0.1	0.2	0.5	0.6	0.9	0.2	0.0	0.2	0.2	(17)
(18)		PrecStd	2.8	0.5	0.2	0.4	0.5	0.6	0.9	1.5	0.9	0.7	0.8	0.6	0.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.3	24.0	39.1	53.8	68.3	81.5	85.7	80.5	71.2	51.6	39.1	30.8	(19)	
		MCWB	21.7	20.8	31.7	40.9	51.8	62.3	64.6	63.3	56.9	42.9	35.8	27.7	(20)	
	2%	DB	16.2	19.6	34.5	47.6	62.4	76.9	81.1	76.3	64.6	47.1	36.7	25.0	(21)	
		MCWB	14.2	17.3	28.9	37.9	47.9	60.1	64.1	61.2	54.3	41.0	33.8	22.0	(22)	
	5%	DB	11.1	15.8	30.6	43.6	58.1	72.9	77.8	73.1	60.9	44.5	34.1	20.6	(23)	
		MCWB	9.5	13.8	25.9	35.5	45.7	58.7	63.0	59.9	52.5	39.3	30.5	17.8	(24)	
	10%	DB	7.2	12.0	26.8	40.4	54.2	68.5	74.6	69.8	57.7	42.0	29.9	16.0	(25)	
		MCWB	6.0	10.4	23.2	33.5	43.6	57.2	62.3	59.5	50.0	37.0	26.6	13.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.9	21.4	32.7	42.6	53.1	65.5	68.1	66.2	59.8	45.7	37.2	28.4	(27)	
		MCDB	23.5	23.6	37.6	51.5	66.0	76.4	75.8	74.8	65.9	48.8	38.4	30.8	(28)	
	2%	WB	14.2	17.5	29.2	38.6	49.4	62.3	66.5	63.6	56.0	42.3	34.2	22.2	(29)	
		MCDB	16.2	19.6	34.0	45.7	59.7	72.2	75.6	71.0	63.0	46.2	36.4	25.1	(30)	
	5%	WB	9.6	13.8	26.1	36.2	46.9	60.2	65.3	62.1	53.2	39.8	30.6	17.8	(31)	
		MCDB	10.9	15.5	30.2	42.3	56.6	70.0	74.1	69.1	59.4	43.7	33.9	20.5	(32)	
	10%	WB	6.0	10.5	23.3	34.2	44.4	58.3	63.9	60.8	50.9	37.5	26.8	13.9	(33)	
		MCDB	7.2	11.9	26.6	39.5	52.8	66.7	72.0	67.6	56.5	41.1	29.7	16.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.4	12.4	16.3	14.1	15.2	16.0	14.2	12.8	11.8	9.9	9.9	9.6	(35)	
		MCDBR	12.1	13.6	18.0	18.0	22.1	23.2	19.8	18.4	16.2	12.4	10.0	12.7	(36)	
		MCWBR	11.1	11.9	13.4	10.8	12.1	11.0	9.5	9.0	9.0	9.3	9.2	11.4	(37)	
	5% WB	MCDBR	12.0	13.7	17.3	16.8	20.2	19.5	16.2	14.5	14.2	11.4	10.3	13.1	(38)	
		MCWBR	11.1	12.0	13.1	10.6	11.7	10.4	9.2	8.5	8.7	9.4	10.1	11.8	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.244	0.277	0.304	0.344	0.384	0.424	0.419	0.382	0.331	0.289	0.255	0.233	(40)	
	taud		2.091	2.084	2.101	2.158	2.179	2.245	2.306	2.390	2.463	2.355	2.120	2.044	(41)	
	Ebn at Noon		211	247	271	276	271	260	259	263	264	246	202	181	(42)	
	Edh at Noon		19	29	37	41	43	41	37	32	26	22	18	16	(43)	
(44) All-Sky Solar Radiation	RadAvg		271	581	1092	1523	1653	1799	1648	1367	907	507	277	190	(44)	
	RadStd		22	37	41	92	131	125	168	105	77	59	31	15	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page