

NAGORNY, Russian FederationWMO: **304930**Lat: **55.948N**Lon: **124.915E**Elev: **2824**StdP: **13.26**Time Zone: **9.00 (E09)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-42.5	-38.3	-46.2	0.4	-41.8	-42.5	0.5	-37.6	21.0	-19.1	18.3	-16.3	1.7	270	0.715

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.3	79.5	61.3	76.0	60.3	72.6	58.7	64.5	72.8	62.8	70.7	61.2	69.1	3.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.3	93.2	66.4	60.2	86.6	65.4	58.2	80.4	63.8	31.2	72.7	29.9	70.3	28.7	68.9	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.0	12.2	10.2	DB	-49.1	84.5	3.7	3.2	-51.8	86.8	-53.9	88.7	-56.0	90.5	-58.7	92.9	(4)
(5)			WB	-48.7	66.2	3.5	4.5	-51.2	69.4	-53.3	72.1	-55.2	74.6	-57.7	77.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.9	-18.9	-12.2	2.6	22.2	40.2	55.0	59.4	54.7	39.9	18.6	-6.0	-18.4
	DBStd	30.00	10.16	9.57	10.67	9.43	7.29	6.55	5.12	6.10	7.82	10.49	13.04	10.05
	HDD50	11632	2134	1741	1470	835	311	27	3	26	311	973	1681	2120
	HDD65	16462	2599	2161	1935	1285	768	304	183	321	752	1438	2131	2585
	CDD50	660	0	0	0	0	8	176	295	171	10	0	0	0
	CDD65	16	0	0	0	0	0	4	10	2	0	0	0	0
	CDH74	526	0	0	0	0	3	176	257	89	1	0	0	0
	CDH80	78	0	0	0	0	0	26	45	7	0	0	0	0
Wind	WSAvg	3.3	3.9	3.6	4.0	3.9	3.7	2.6	2.5	2.3	3.2	3.5	3.1	3.4
Precipitation	PrecAvg	22.4	0.3	0.2	0.4	1.2	1.6	4.0	5.3	4.6	2.9	1.0	0.6	0.4
	PrecMax	28.4	0.8	0.7	1.7	4.6	3.9	8.3	9.1	8.4	5.7	2.7	1.4	0.9
	PrecMin	14.6	0.0	0.0	0.0	0.4	0.1	0.6	1.0	1.3	0.2	0.2	0.1	0.1
	PrecStd	3.7	0.2	0.2	0.4	0.8	1.0	2.1	2.0	1.8	1.2	0.6	0.4	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	18.2	35.3	54.9	73.3	83.3	85.1	80.2	68.9	48.1	31.7	11.6
		MCWB	10.2	15.4	29.1	42.4	53.3	61.4	64.1	63.1	54.6	39.0	27.9	10.1
	2%	DB	4.9	12.5	29.6	47.0	66.1	78.9	80.0	76.5	63.3	41.5	24.4	6.3
		MCWB	3.6	10.4	25.1	37.0	49.6	59.8	62.2	61.4	51.5	35.0	21.6	5.0
	5%	DB	-0.2	7.6	25.2	41.6	60.7	75.0	76.5	72.5	58.4	36.8	19.4	1.7
		MCWB	-1.3	6.0	21.4	33.6	46.9	58.5	61.4	59.7	48.6	31.9	17.3	0.8
	10%	DB	-4.1	3.1	21.0	37.8	55.7	71.3	72.9	68.5	53.9	33.3	14.0	-3.1
		MCWB	-4.9	1.8	17.9	30.9	44.6	56.5	60.1	58.2	47.3	29.9	12.6	-3.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.4	15.5	29.5	42.9	54.6	65.3	67.8	66.7	57.1	39.5	28.3	10.1
		MCDB	12.5	18.1	34.2	53.7	69.2	74.7	78.1	74.0	65.6	46.7	31.9	11.4
	2%	WB	3.6	10.6	25.5	37.5	50.8	62.8	65.3	63.4	53.4	35.7	21.8	5.0
		MCDB	4.8	12.5	29.5	46.8	63.5	73.8	74.1	70.7	59.3	40.7	24.6	6.3
	5%	WB	-1.2	6.1	21.4	33.8	47.9	60.6	63.4	61.6	50.9	32.5	17.4	0.7
		MCDB	-0.3	7.6	25.1	40.6	58.3	70.9	71.1	69.2	56.4	36.2	19.4	1.6
	10%	WB	-4.8	1.8	17.9	31.5	45.5	58.1	62.0	59.6	47.9	30.0	12.6	-3.8
		MCDB	-4.0	3.0	21.0	37.1	54.5	68.4	69.1	66.7	53.2	33.3	13.8	-3.1
Mean Daily Temperature Range	5% DB	MDBR	15.4	19.5	22.0	22.0	20.9	24.8	21.3	22.5	19.2	17.7	17.7	14.6
		MCDBR	19.8	23.8	26.2	26.1	33.4	34.5	31.4	31.4	30.3	22.6	19.6	18.9
		MCWBR	18.8	21.5	21.9	17.7	19.2	16.8	15.4	17.3	19.1	16.2	17.1	17.8
	5% WB	MCDBR	19.6	23.2	25.2	23.9	28.8	27.8	22.9	24.4	25.2	19.6	19.2	18.8
		MCWBR	18.7	21.4	21.3	16.4	17.5	15.8	13.0	14.8	17.2	14.7	16.9	17.7
Clear-Sky Solar Irradiance	taub	0.227	0.257	0.293	0.391	0.444	0.420	0.432	0.378	0.326	0.291	0.241	0.219	
	taud	2.122	2.125	2.079	1.884	2.001	2.223	2.211	2.359	2.449	2.294	2.112	2.048	
	Ebn at Noon	221	258	274	258	252	261	255	264	265	242	208	188	
	Edh at Noon	18	28	37	54	51	42	41	33	26	23	18	15	
All-Sky Solar Radiation	RadAvg	303	656	1236	1761	1628	1744	1550	1295	925	592	362	213	
	RadStd	12	24	44	87	134	139	152	141	84	48	22	7	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page