

YEROFEY PAVLOVICH, Russian FederationWMO: **306830**Lat: **53.967N**Lon: **121.933E**Elev: **1712**StdP: **13.81**Time Zone: **9.00 (E09)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-35.3	-31.7	-39.7	0.6	-34.6	-36.3	0.7	-31.0	15.3	-4.1	12.7	-2.0	0.6	320	0.617

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.1	83.8	65.3	80.6	64.2	77.6	62.9	69.0	78.0	67.1	75.7	65.3	73.6	4.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.0	102.1	73.0	64.2	95.7	70.7	62.3	89.6	69.5	34.3	77.4	32.7	75.6	31.3	73.6	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.0	11.7	9.5	DB	-39.8	89.2	3.9	3.2	-42.6	91.5	-44.9	93.4	-47.0	95.2	-49.8	97.5	(4)
(5)			WB	-39.8	71.3	3.8	2.1	-42.6	72.8	-44.8	74.0	-47.0	75.2	-49.8	76.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.3	-12.2	-4.2	11.8	31.9	47.2	61.2	65.3	59.9	46.8	27.8	2.4	-12.0	(6)	
	DBStd	29.27	8.11	8.80	11.41	8.53	7.13	6.23	4.83	6.04	7.40	9.60	12.02	8.72	(7)	
	HDD50	9501	1927	1518	1184	544	138	4	0	5	145	687	1427	1922	(8)	
	HDD65	13860	2392	1938	1649	992	552	144	56	176	545	1152	1877	2387	(9)	
	CDD50	1230	0	0	0	2	51	340	475	312	50	0	0	0	(10)	
	CDD65	114	0	0	0	0	1	29	66	18	0	0	0	0	(11)	
	CDH74	1554	0	0	0	3	32	516	700	289	14	0	0	0	(12)	
	CDH80	331	0	0	0	0	4	123	161	42	1	0	0	0	(13)	
(14) Wind	WSAvg	2.8	1.9	2.2	3.1	4.1	4.3	3.4	2.9	2.7	3.0	2.8	1.9	1.7	(14)	
(15) Precipitation	PrecAvg	16.5	0.1	0.2	0.4	0.9	1.3	2.6	4.1	3.7	1.9	0.7	0.5	0.2	(15)	
	PrecMax	23.8	0.5	0.7	1.6	2.8	3.0	7.0	8.9	9.7	6.9	1.9	1.2	0.6	(16)	
	PrecMin	8.7	0.0	0.0	0.0	0.1	0.1	0.3	1.9	0.6	0.1	0.0	0.0	0.0	(17)	
	PrecStd	3.7	0.1	0.2	0.3	0.6	0.8	1.8	1.7	1.8	1.4	0.5	0.3	0.2	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.2	27.6	47.0	66.7	78.3	88.2	88.5	84.3	75.4	58.8	36.8	16.6	(19)	
		MCWB	11.2	22.0	36.0	46.8	56.1	66.0	66.3	66.1	59.3	45.6	30.4	14.5	(20)	
	2%	DB	9.2	20.9	40.3	58.3	72.4	83.4	84.4	80.6	69.9	52.3	29.5	11.3	(21)	
		MCWB	6.9	16.9	31.4	43.6	52.6	64.2	66.3	64.8	57.1	41.9	25.6	9.4	(22)	
	5%	DB	5.4	16.2	35.1	52.1	68.1	79.7	81.0	77.2	65.6	47.1	25.0	6.1	(23)	
		MCWB	3.7	13.4	28.2	39.8	51.0	62.1	65.4	63.3	53.9	38.7	22.6	4.5	(24)	
	10%	DB	1.7	11.9	30.4	47.1	63.6	76.3	77.9	73.6	61.3	42.8	20.6	1.8	(25)	
		MCWB	0.3	9.5	24.9	36.7	48.7	61.0	64.6	62.2	51.8	35.5	18.3	0.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.1	22.2	36.4	49.4	58.2	70.9	71.2	69.9	62.0	46.2	30.7	15.0	(27)	
		MCDB	13.6	27.2	46.6	65.2	73.0	81.2	80.2	77.7	72.5	56.8	36.2	16.6	(28)	
	2%	WB	7.0	17.0	31.7	44.1	54.9	66.8	69.6	67.4	58.6	42.6	26.1	9.4	(29)	
		MCDB	9.1	20.7	39.8	57.6	68.5	78.6	78.8	76.0	66.3	50.9	28.8	11.3	(30)	
	5%	WB	3.7	13.4	28.4	40.4	52.3	64.5	68.1	65.5	56.1	39.3	22.5	4.6	(31)	
		MCDB	5.4	16.3	34.5	50.7	64.5	75.6	76.4	73.5	62.7	46.4	25.0	6.0	(32)	
	10%	WB	0.4	9.5	25.2	37.5	49.9	62.6	66.4	63.5	53.4	36.0	18.3	0.6	(33)	
		MCDB	1.7	11.9	30.1	45.8	61.7	73.4	73.9	71.0	59.9	42.2	20.6	1.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	22.4	26.6	26.0	22.2	23.0	24.0	21.1	22.1	22.6	20.7	21.7	20.2	(35)	
		MCDBR	23.8	29.8	27.8	31.4	33.3	31.4	28.9	30.0	30.7	27.2	23.7	20.5	(36)	
	5% WB	MCWBR	21.8	26.2	20.2	18.7	17.2	14.4	13.6	15.4	17.7	17.8	19.5	18.9	(37)	
		MCWBR	23.7	29.6	26.5	28.7	28.0	26.2	21.5	23.7	25.1	25.5	23.4	20.2	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.244	0.273	0.315	0.428	0.514	0.464	0.445	0.402	0.349	0.316	0.272	0.248	(40)	
		taud	2.156	2.134	2.087	1.946	1.846	2.104	2.208	2.314	2.412	2.352	2.179	2.080	(41)	
	Ebn at Noon	Ebn at Noon	228	259	271	250	234	250	253	259	260	242	212	194	(42)	
		Edh at Noon	20	29	39	52	61	47	42	36	28	24	20	18	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	378	739	1283	1695	1640	1857	1641	1418	1071	702	420	279	(44)	
	RadStd	RadStd	15	20	45	104	121	145	134	148	87	38	19	13	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page