

IRKUTSK, Russian Federation

WMO: 307100

Lat: 52.2721N

Lon: 104.3080E

Elev: 469

StdP: 95.82

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-35.8	-32.1	-39.0	0.1	-35.5	-35.2	0.1	-31.9	9.8	-14.4	8.7	-14.3	1.8	90	0.675

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	29.1	17.9	27.2	17.5	25.7	16.9	20.0	25.8	19.1	24.5	18.2	23.3	3.4	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.1	13.8	21.9	17.1	12.9	21.2	16.1	12.1	20.4	59.6	25.9	56.3	24.4	53.3	22.9	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	9.9	8.5	7.3	DB	-37.7	32.3	4.0	1.4	-40.6	33.4	-42.9	34.2	-45.2	35.0	-48.1	36.1
(5)				WB	-37.8	22.0	4.0	1.3	-40.7	22.9	-43.0	23.7	-45.2	24.4	-48.1	25.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	0.6	-19.0	-15.3	-6.7	3.0	9.6	16.0	18.4	16.0	9.2	1.3	-9.4	-16.5	(6)
(7)		DBStd	14.04	6.72	6.31	6.30	4.50	4.24	3.67	2.74	3.15	3.92	4.93	7.14	6.79	(7)
(8)		HDD10.0	4142	900	709	519	213	61	3	0	1	61	272	582	821	(8)
(9)		HDD18.3	6529	1158	943	777	459	271	88	33	86	274	529	832	1079	(9)
(10)		CDD10.0	720	0	0	0	3	49	182	261	186	37	1	0	0	(10)
(11)		CDD18.3	65	0	0	0	0	1	17	36	12	0	0	0	0	(11)
(12)		CDH23.3	947	0	0	0	3	68	297	392	172	16	0	0	0	(12)
(13)		CDH26.7	218	0	0	0	0	14	78	94	29	2	0	0	0	(13)
(14)	Wind	WSAvg	3.0	2.4	2.6	3.1	3.8	3.9	3.2	2.8	2.9	3.0	3.0	2.8	2.3	(14)
(15)	Precipitation	PrecAvg	470	13	9	12	19	33	64	112	90	50	25	19	20	(15)
(16)		PrecMax	632	31	23	40	64	67	146	353	221	129	90	37	55	(16)
(17)		PrecMin	321	3	1	1	7	7	8	24	24	12	6	7	3	(17)
(18)		PrecStd	84	7	5	8	13	17	33	56	47	26	16	8	12	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-2.8	2.9	11.9	22.1	28.8	31.8	31.3	29.3	25.2	18.2	8.0	-0.2	(19)
(20)			MCWB	-4.1	-1.3	4.4	9.5	14.0	18.1	19.5	18.9	15.6	9.6	3.6	-2.1	(20)
(21)		2%	DB	-5.2	-1.3	7.7	18.0	25.1	29.0	29.2	27.1	22.2	14.2	4.4	-3.0	(21)
(22)			MCWB	-6.2	-4.0	2.2	7.8	12.6	17.0	18.9	18.3	14.2	7.5	1.4	-4.2	(22)
(23)		5%	DB	-7.8	-4.0	5.0	14.7	22.2	26.9	27.2	25.1	19.8	11.6	2.1	-5.1	(23)
(24)			MCWB	-8.7	-5.9	0.7	6.4	11.2	16.5	18.5	17.5	12.9	6.2	0.1	-5.9	(24)
(25)		10%	DB	-10.0	-6.2	2.8	11.8	19.5	24.8	25.5	23.2	17.1	9.0	0.1	-7.0	(25)
(26)			MCWB	-10.5	-7.8	-0.7	4.9	9.9	15.8	18.0	16.9	11.5	5.0	-1.2	-7.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-3.8	-1.4	4.7	10.6	15.2	20.1	21.9	20.5	16.9	10.1	3.9	-2.1	(27)
(28)			MCDWB	-2.9	2.4	11.3	20.8	26.7	27.4	27.8	26.4	22.9	17.0	7.6	-0.7	(28)
(29)		2%	WB	-6.4	-3.9	2.4	8.2	13.3	18.7	20.6	19.2	15.2	8.1	1.7	-4.3	(29)
(30)			MCDWB	-5.4	-1.7	7.0	16.7	23.0	25.5	26.4	24.9	20.4	13.3	4.0	-3.3	(30)
(31)		5%	WB	-8.6	-6.0	0.8	6.6	11.9	17.6	19.6	18.3	13.6	6.6	0.2	-6.0	(31)
(32)			MCDWB	-7.8	-4.2	4.4	14.0	20.4	24.2	24.9	23.7	18.8	10.8	1.8	-5.2	(32)
(33)		10%	WB	-10.6	-7.9	-0.6	5.1	10.4	16.6	18.7	17.3	12.1	5.2	-1.1	-7.6	(33)
(34)			MCDWB	-10.1	-6.4	2.3	11.1	18.1	22.9	23.6	22.1	16.2	8.7	0.2	-7.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.0	12.7	13.2	12.5	14.5	13.6	12.0	11.9	12.3	11.2	10.5	9.5	(35)
(36)			MCDBR	10.7	14.1	14.5	18.7	20.4	18.3	16.3	16.2	17.5	16.1	11.4	10.1	(36)
(37)			MCWBR	9.7	11.6	9.7	10.0	10.0	8.2	7.6	8.3	9.6	9.8	8.6	9.2	(37)
(38)		5% WB	MCDWB	10.5	13.9	13.5	17.2	18.0	15.0	13.1	14.0	15.5	15.0	10.7	9.9	(38)
(39)			MCWBR	9.6	11.6	9.1	9.6	9.2	7.1	6.8	7.5	8.8	9.4	8.3	9.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.276	0.302	0.338	0.385	0.445	0.439	0.429	0.395	0.342	0.322	0.299	0.279	(40)	
(41)		taud	2.085	2.068	2.111	2.214	2.064	2.193	2.266	2.343	2.445	2.395	2.201	2.071	(41)	
(42)		Ebn at Noon	693	790	840	846	807	817	819	830	842	780	666	607	(42)	
(43)		Edh at Noon	75	104	123	127	155	138	126	111	89	76	67	64	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.27	2.38	3.84	4.85	5.54	5.85	5.41	4.61	3.51	2.23	1.27	0.89	(44)	
(45)		RadStd	0.07	0.10	0.17	0.27	0.30	0.32	0.41	0.23	0.32	0.13	0.08	0.07	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page