

SRETENSK, Russian Federation

WMO: 307770

Lat: 52.233N

Lon: 117.700E

Elev: 525

StdP: 95.17

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-39.5	-37.2	-42.1	0.1	-39.3	-39.9	0.1	-37.0	9.7	-17.5	7.1	-16.9	1.2	240	0.631

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.2	30.8	18.0	28.6	17.6	26.6	17.0	20.1	26.1	19.2	25.0	18.3	24.0	2.7	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.3	14.0	22.6	17.4	13.2	21.4	16.4	12.5	20.5	60.5	26.1	57.2	24.7	54.3	24.0	23.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.2	6.8	5.8	-42.3	34.3	2.3	2.5	-44.0	36.1	-45.3	37.5	-46.6	38.9	-48.3	40.7
			-42.3	22.0	2.3	1.0	-44.0	22.7	-45.3	23.3	-46.6	23.9	-48.3	24.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.8	-26.9	-21.5	-9.8	2.0	10.3	17.3	19.7	17.1	9.9	-0.3	-14.5	-25.7
	DBStd	17.37	5.45	5.86	6.99	4.75	3.97	3.61	2.76	3.38	4.21	5.26	7.32	5.88
	HDD10.0	5147	1144	882	614	244	45	1	0	1	53	319	736	1108
	HDD18.3	7454	1403	1115	872	491	252	59	17	63	254	577	986	1366
	CDD10.0	849	0	0	0	3	53	220	302	221	49	1	0	0
	CDD18.3	115	0	0	0	0	1	28	61	25	1	0	0	0
	CDH23.3	1417	0	0	0	3	56	439	627	272	20	0	0	0
	CDH26.7	441	0	0	0	1	13	144	206	75	2	0	0	0
Wind	WSAvg	2.1	1.8	1.8	2.3	2.8	2.9	2.1	2.0	2.0	2.3	2.2	1.8	1.6
Precipitation	PrecAvg	353	4	4	5	15	29	54	95	87	38	10	8	6
	PrecMax	527	11	14	16	42	97	123	214	160	115	30	22	18
	PrecMin	204	0	0	0	2	4	4	33	19	3	1	0	1
	PrecStd	76	2	3	4	10	24	31	41	32	25	7	5	4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-10.3	-2.5	11.0	21.7	28.4	33.7	34.0	31.5	26.2	17.7	5.1	-6.6
		MCWB	-11.8	-5.2	3.7	8.8	13.9	19.0	18.7	18.8	15.0	8.4	0.7	-8.0
	2%	DB	-14.2	-6.1	6.6	17.2	24.5	30.3	31.1	28.7	22.5	13.2	1.0	-11.5
		MCWB	-15.1	-8.1	0.6	6.9	12.1	17.4	18.0	18.2	13.5	5.9	-2.0	-12.4
	5%	DB	-16.4	-9.1	3.6	13.9	22.1	27.9	28.8	26.3	20.1	10.1	-1.7	-14.8
		MCWB	-17.2	-10.6	-1.1	5.1	10.8	16.6	18.3	17.5	12.4	4.1	-3.9	-15.5
	10%	DB	-18.7	-12.0	0.8	11.0	19.5	25.7	26.8	24.0	17.7	7.7	-4.1	-17.4
		MCWB	-19.3	-13.1	-2.8	3.4	9.6	15.8	17.8	16.8	11.5	2.6	-5.8	-17.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-11.7	-5.2	3.4	9.2	15.1	20.9	21.8	20.9	16.5	8.8	1.0	-8.0
		MCDB	-10.5	-2.6	10.4	20.6	25.6	29.4	28.3	27.2	21.4	17.3	4.8	-6.7
	2%	WB	-15.1	-8.2	0.8	7.1	13.3	19.1	20.5	19.5	15.1	6.4	-1.7	-12.3
		MCDB	-14.2	-6.2	6.2	16.6	22.0	26.4	26.3	25.2	19.5	12.5	0.9	-11.6
	5%	WB	-17.1	-10.6	-0.9	5.3	11.7	17.9	19.6	18.6	13.8	4.5	-3.9	-15.4
		MCDB	-16.5	-9.2	3.4	13.3	20.4	25.0	25.2	23.9	18.6	9.2	-1.8	-14.8
	10%	WB	-19.3	-13.1	-2.7	3.7	10.2	16.9	18.7	17.7	12.4	3.0	-5.8	-17.9
		MCDB	-18.8	-12.0	0.8	10.5	18.4	23.4	24.2	22.6	16.9	7.3	-4.2	-17.5
Mean Daily Temperature Range	5% DB	MDBR	10.1	13.6	14.0	12.9	14.0	13.7	12.2	11.7	12.3	11.4	10.8	9.2
		MCDBR	10.7	14.2	14.8	18.8	19.5	18.6	16.9	16.1	16.8	15.0	12.1	10.2
		MCWBR	9.9	12.5	9.9	10.6	9.0	7.3	6.2	6.5	8.2	8.7	9.4	9.5
	5% WB	MCDBR	10.7	14.1	14.2	17.6	16.6	14.4	11.9	12.5	13.3	14.1	11.9	10.3
		MCWBR	9.9	12.4	9.7	10.2	8.2	6.2	5.5	5.7	6.9	8.4	9.3	9.6
Clear-Sky Solar Irradiance	taub	0.247	0.272	0.317	0.420	0.497	0.462	0.417	0.390	0.350	0.311	0.275	0.253	
	taud	2.219	2.191	2.151	2.027	1.881	2.102	2.298	2.351	2.393	2.405	2.287	2.174	
	Ebn at Noon	762	844	867	808	759	796	830	835	830	795	715	671	
	Edh at Noon	65	91	118	153	186	151	122	110	93	74	61	57	
All-Sky Solar Radiation	RadAvg	1.42	2.58	4.20	5.22	5.69	6.09	5.54	4.83	3.76	2.54	1.48	1.07	
	RadStd	0.03	0.05	0.17	0.29	0.41	0.52	0.41	0.31	0.29	0.17	0.07	0.03	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page