

AGINSKOE, Russian Federation

WMO: 308590

Lat: 51.100N

Lon: 114.517E

Elev: 2235

StdP: 13.55

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-31.3	-27.0	-36.2	0.8	-30.1	-32.3	1.0	-26.1	20.4	4.1	17.9	3.4	1.2	270	0.658

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.5	87.2	63.7	83.3	62.9	79.8	61.9	67.9	80.1	66.0	76.9	64.3	74.7	8.3	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.3	98.1	72.2	62.4	91.6	70.4	60.7	86.1	68.8	33.7	80.4	32.1	76.9	30.8	74.7	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.9	18.0	15.5		-37.6	94.3	6.4	4.8	-42.2	97.8	-46.0	100.6	-49.6	103.3	-54.3	106.8	
				-37.6	72.1	6.1	3.1	-42.0	74.3	-45.6	76.1	-49.0	77.8	-53.4	80.0	
				DB												
				WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	31.1	-7.0	-0.1	16.1	34.8	48.8	62.0	66.4	61.8	49.3	32.3	10.3	-3.7
	DBStd	27.39	9.33	9.77	11.41	8.49	7.40	6.51	4.76	5.78	7.12	8.47	11.80	10.18
	HDD50	8302	1766	1404	1051	460	111	4	0	2	98	551	1191	1664
	HDD65	12530	2231	1824	1516	906	502	128	38	130	471	1014	1641	2129
	CDD50	1398	0	0	0	4	75	364	508	369	77	1	0	0
	CDD65	152	0	0	0	0	1	38	81	32	0	0	0	0
	CDH74	2518	0	0	0	1	90	784	1113	477	53	0	0	0
	CDH80	763	0	0	0	0	19	244	362	130	8	0	0	0
Wind	WSAvg	6.1	4.7	5.1	6.3	8.2	8.7	6.3	5.6	5.6	6.2	6.4	5.2	4.5
Precipitation	PrecAvg	14.6	0.1	0.1	0.2	0.4	1.0	2.3	4.4	3.1	1.9	0.4	0.2	0.2
	PrecMax	24.5	0.4	0.6	0.8	1.4	3.5	7.4	12.0	6.7	7.6	1.1	0.5	0.6
	PrecMin	9.1	0.0	0.0	0.0	0.0	0.0	0.1	1.0	0.7	0.1	0.0	0.0	0.0
	PrecStd	3.7	0.1	0.2	0.2	0.4	1.0	1.6	2.2	1.6	1.4	0.3	0.2	0.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.5	32.3	53.1	70.0	83.4	93.3	93.7	88.9	80.5	64.3	44.3	26.9
		MCWB	19.7	25.3	39.2	49.4	57.1	65.0	66.5	65.4	59.0	48.5	35.0	22.7
	2%	DB	16.3	26.8	46.1	62.8	76.3	86.1	87.9	83.7	73.9	57.0	37.6	21.1
		MCWB	13.4	21.9	35.1	45.5	54.8	62.9	64.6	63.8	56.6	43.5	31.1	17.9
	5%	DB	11.6	21.5	40.1	57.5	71.1	82.1	83.7	79.1	69.0	51.6	32.9	16.2
		MCWB	9.5	17.7	31.1	42.4	52.1	61.4	64.1	62.6	54.4	40.3	27.7	13.9
	10%	DB	7.6	17.0	34.9	52.2	66.4	78.3	80.1	75.4	64.4	46.8	28.0	11.6
		MCWB	5.9	14.1	27.6	39.4	49.6	60.3	63.4	61.6	52.3	37.4	24.0	9.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.7	25.8	39.7	50.2	59.1	69.1	71.3	68.9	61.9	48.8	35.6	23.0
		MCDB	23.2	32.0	52.7	67.9	78.3	86.7	84.6	81.1	74.7	64.0	43.2	26.9
	2%	WB	13.5	22.0	35.1	46.2	56.0	65.7	68.8	66.5	58.7	43.9	31.2	18.1
		MCDB	16.1	27.0	45.4	61.1	72.9	79.7	79.9	76.7	69.1	55.6	37.1	20.9
	5%	WB	9.5	17.8	31.3	42.8	53.6	63.6	67.0	64.7	56.4	40.9	27.8	13.9
		MCDB	11.6	21.4	39.4	56.0	68.5	76.9	78.0	74.4	65.4	50.3	32.6	16.0
	10%	WB	5.9	14.2	27.9	39.9	50.8	61.8	65.2	63.2	53.7	38.1	24.1	9.8
		MCDB	7.6	17.0	34.7	51.7	64.9	74.3	75.3	72.8	63.3	45.9	27.9	11.6
Mean Daily Temperature Range	5% DB	MDBR	21.3	26.0	26.2	25.1	25.8	26.2	23.5	22.8	24.2	22.0	21.6	20.3
		MCDBR	24.1	29.2	30.6	35.9	36.7	35.1	32.8	31.7	33.8	30.4	24.6	22.9
		MCWBR	21.8	24.9	20.9	21.2	18.7	14.7	13.2	14.4	17.3	18.4	18.6	20.2
	5% WB	MCDBR	24.0	29.0	29.7	33.7	33.6	28.4	24.6	24.3	27.6	28.5	24.3	23.1
		MCWBR	21.8	24.9	20.5	20.6	18.0	13.3	12.2	12.1	14.6	17.7	18.7	20.4
Clear-Sky Solar Irradiance	taub	0.251	0.278	0.320	0.413	0.490	0.465	0.424	0.387	0.341	0.304	0.275	0.257	
	taud	2.234	2.198	2.175	2.034	1.870	2.059	2.246	2.333	2.401	2.413	2.300	2.192	
	Ebn at Noon	247	269	277	260	244	252	262	267	269	259	234	220	
	Edh at Noon	22	30	37	49	60	50	41	36	30	24	20	19	
All-Sky Solar Radiation	RadAvg	494	865	1361	1680	1903	2001	1841	1609	1280	860	500	372	
	RadStd	19	36	63	111	110	159	128	106	93	47	21	16	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (9 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page