

PRIARGUNSK, Russian Federation

WMO: 309750

Lat: 50.333N

Lon: 119.067E

Elev: 521

StdP: 95.22

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-40.9	-38.3	-43.1	0.1	-40.5	-40.7	0.1	-38.0	11.6	-20.5	9.6	-19.1	0.5	20	0.676

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.6	31.5	18.3	29.3	17.9	27.4	17.6	20.9	27.3	20.0	26.0	19.1	24.7	4.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.0	14.7	23.2	18.1	13.9	22.4	17.2	13.0	21.7	63.2	27.0	59.9	25.8	56.9	24.7	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.5	9.7	8.3	-44.0	35.2	3.1	2.8	-46.2	37.2	-48.0	38.9	-49.7	40.5	-52.0	42.6		
			-43.7	22.8	2.6	1.3	-45.6	23.8	-47.1	24.6	-48.6	25.4	-50.5	26.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.4	-28.0	-22.6	-10.6	2.8	11.1	17.9	20.5	17.9	10.9	0.7	-14.0	-25.2		
	DBStd	17.90	5.88	5.99	7.13	4.97	4.12	3.72	2.68	3.31	4.30	4.97	7.09	5.91		
	HDD10.0	5128	1177	913	639	222	36	1	0	1	39	290	720	1091		
	HDD18.3	7371	1435	1146	897	467	226	52	9	47	225	548	970	1349		
	CDD10.0	953	0	0	0	5	71	237	327	247	66	1	0	0		
	CDD18.3	155	0	0	0	0	3	38	78	34	2	0	0	0		
	CDH23.3	1810	0	0	0	3	94	541	737	377	58	1	0	0		
	CDH26.7	586	0	0	0	1	24	193	247	109	12	0	0	0		
	WSAvg	3.0	1.7	2.0	3.2	4.4	4.5	3.4	3.0	3.0	3.3	3.3	2.4	1.8		
	PrecAvg	340	4	4	6	11	24	56	95	72	34	17	6	6		
Precipitation	PrecMax	579	20	8	20	30	110	148	190	209	86	55	19	13		
	PrecMin	153	0	0	0	0	0	3	17	18	1	0	1	1		
	PrecStd	99	4	2	6	9	23	34	45	50	24	15	6	3		
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-10.1	-3.0	11.0	22.3	29.8	35.2	34.3	32.9	28.5	18.5	5.6	-6.8		
		MCWB	-11.4	-6.0	3.5	9.8	14.5	18.0	19.5	19.7	15.8	9.4	1.4	-8.3		
	2%	DB	-14.0	-7.0	6.1	18.5	26.0	31.1	31.5	29.6	24.7	14.6	1.6	-11.5		
		MCWB	-14.8	-8.7	0.8	7.9	12.9	17.0	19.1	18.8	14.8	7.0	-1.4	-12.3		
	5%	DB	-16.5	-10.1	3.0	15.1	23.2	28.7	29.3	27.3	21.9	11.8	-1.5	-13.8		
		MCWB	-17.2	-11.2	-1.1	6.2	11.8	16.5	19.1	18.1	13.2	5.4	-3.7	-14.5		
	10%	DB	-19.0	-12.7	0.3	12.2	20.7	26.4	27.4	25.2	19.3	9.1	-3.9	-16.2		
		MCWB	-19.5	-13.6	-2.7	4.6	10.5	16.2	18.9	17.2	12.2	4.0	-5.6	-16.8		
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-11.3	-5.6	3.7	10.6	15.7	20.5	22.5	21.7	17.3	9.6	1.7	-8.2		
		MCDB	-10.0	-3.3	10.4	21.1	26.4	29.2	28.3	28.3	24.2	17.9	5.3	-6.8		
	2%	WB	-14.8	-8.6	1.0	8.4	13.9	19.2	21.5	20.2	15.8	7.5	-1.4	-12.3		
		MCDB	-14.0	-7.1	5.6	17.3	23.6	26.8	27.6	26.4	22.2	13.4	1.3	-11.6		
	5%	WB	-17.2	-11.2	-0.9	6.4	12.5	18.2	20.5	19.3	14.4	5.9	-3.5	-14.5		
		MCDB	-16.6	-10.2	2.8	14.6	21.8	25.2	26.5	24.9	20.0	11.3	-1.6	-13.8		
	10%	WB	-19.4	-13.5	-2.7	4.7	11.1	17.2	19.7	18.4	12.9	4.3	-5.6	-16.8		
		MCDB	-18.9	-12.7	0.3	11.6	19.5	24.0	25.2	23.6	18.4	8.7	-3.9	-16.2		
Mean Daily Temperature Range	5% DB	MDBR	11.3	13.5	13.6	13.6	14.4	13.4	11.6	12.4	13.9	12.8	11.6	10.7		
		MCDBR	12.8	15.3	14.9	19.2	19.9	18.1	16.0	16.6	18.3	17.0	13.4	11.5		
		MCWBR	11.9	13.8	10.4	11.1	9.8	7.3	6.5	7.3	9.3	10.5	10.7	10.8		
	5% WB	MCDBR	12.6	15.1	14.5	18.2	17.4	13.8	12.6	13.0	14.8	15.7	13.0	11.4		
		MCWBR	11.9	13.7	10.5	10.8	9.1	6.4	6.1	6.3	8.0	10.1	10.5	10.7		
Clear-Sky Solar Irradiance	taub		0.257	0.282	0.334	0.428	0.498	0.475	0.429	0.400	0.352	0.325	0.287	0.265		
	taud		2.197	2.154	2.086	1.990	1.863	2.045	2.252	2.294	2.364	2.329	2.256	2.159		
	Ebn at Noon		776	847	857	807	765	789	825	831	838	791	728	693		
	Edh at Noon		72	99	129	161	191	161	129	118	98	84	69	65		
All-Sky Solar Radiation	RadAvg		1.61	2.81	4.38	5.30	5.97	6.26	5.78	5.22	4.09	2.75	1.62	1.19		
	RadStd		0.10	0.17	0.24	0.30	0.42	0.54	0.38	0.43	0.27	0.16	0.08	0.10		

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
				99% DB	99% DP	1% DB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	N/A	N/A	-2.60	N/A	N/A	N/A	+238	+246	N/A	N/A

Nomenclature: See separate page