

KAYLASTUY, Russian Federation

WMO: 309780

Lat: 49.833N

Lon: 118.383E

Elev: 1804

StdP: 13.76

Time Zone: 9.00 (E09)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-35.4	-31.0	-40.4	0.6	-35.0	-35.6	0.8	-30.6	23.6	3.8	20.8	2.2	1.7	70	0.636

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.9	88.6	65.8	85.0	64.5	81.8	63.6	69.1	81.4	67.6	78.7	66.2	76.5	8.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.6	100.9	72.9	64.0	95.3	72.2	62.3	89.8	71.6	34.5	81.4	33.3	78.9	32.0	76.4	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
24.3	20.8	18.0	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-37.9	94.6	7.4	5.8	-43.3	98.8	-47.6	102.2	-51.8	105.4	-57.2	109.6		
			-38.6	72.0	7.5	2.1	-44.0	73.5	-48.4	74.8	-52.7	75.9	-58.1	77.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	32.2	-13.2	-4.1	16.4	37.9	53.3	65.6	70.2	66.2	53.3	35.1	11.7	-7.6	(6)
(7)		DBStd	30.60	9.58	10.01	12.06	9.02	7.89	6.90	5.03	5.98	7.70	8.65	11.92	10.10	(7)
(8)		HDD50	8398	1959	1515	1043	377	54	1	0	0	52	463	1150	1784	(8)
(9)		HDD65	12327	2424	1935	1508	814	373	73	11	57	357	926	1600	2249	(9)
(10)		CDD50	1917	0	0	0	13	155	468	625	502	151	3	0	0	(10)
(11)		CDD65	371	0	0	0	0	9	90	171	94	7	0	0	0	(11)
(12)		CDH74	3470	0	0	0	5	178	1015	1398	772	101	1	0	0	(12)
(13)		CDH80	1094	0	0	0	0	48	352	451	222	21	0	0	0	(13)
(14)	Wind	WSAvg	7.1	4.5	5.5	7.9	10.1	9.9	7.6	6.7	6.6	7.3	7.4	6.5	4.9	(14)
(15)	Precipitation	PrecAvg	11.5	0.1	0.1	0.2	0.4	0.8	2.1	3.3	2.5	1.2	0.5	0.2	0.2	(15)
(16)		PrecMax	20.3	0.6	0.4	0.7	1.2	3.0	4.7	8.9	7.0	2.4	2.0	0.6	1.0	(16)
(17)		PrecMin	6.8	0.0	0.0	0.0	0.0	0.0	0.2	0.2	0.6	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	3.3	0.1	0.1	0.2	0.3	0.7	1.2	2.0	1.7	0.7	0.5	0.2	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.8	27.5	51.6	72.5	85.9	94.9	92.7	90.8	82.8	64.4	44.5	22.1	(19)
MCWB			14.2	23.2	38.7	52.3	59.8	64.5	67.9	68.0	61.4	48.6	35.9	19.2	(20)	
2%		DB	9.3	21.1	44.2	64.6	79.1	87.8	88.9	85.7	76.3	58.0	37.7	14.5	(21)	
		MCWB	7.9	18.1	34.1	47.5	57.1	63.5	67.1	66.2	58.2	44.7	31.1	12.3	(22)	
5%		DB	4.5	16.7	39.3	59.2	73.9	83.9	84.8	82.0	71.6	53.4	32.5	10.4	(23)	
		MCWB	3.1	14.3	31.3	44.1	54.6	62.7	65.7	64.6	55.9	42.4	27.7	8.9	(24)	
10%		DB	0.8	12.2	34.6	53.8	69.4	79.9	81.5	78.3	67.3	48.7	27.8	6.8	(25)	
		MCWB	-0.3	10.4	28.6	41.0	52.2	61.4	65.0	63.3	54.0	39.7	24.2	5.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.7	23.1	39.3	52.4	61.8	68.9	71.7	70.5	63.0	49.5	36.1	19.2	(27)
MCD B			15.8	26.9	50.4	70.7	81.5	85.8	84.8	84.9	76.4	62.1	43.9	22.0	(28)	
2%		WB	7.9	18.2	34.9	48.2	58.3	66.5	69.7	68.4	60.4	45.9	31.5	12.6	(29)	
		MCD B	9.3	21.1	43.5	64.0	76.5	80.2	81.9	80.1	71.6	56.0	36.9	14.3	(30)	
5%		WB	3.3	14.4	31.7	44.7	55.7	64.6	68.4	66.8	57.9	43.2	27.8	9.0	(31)	
		MCD B	4.5	16.7	38.7	58.1	71.8	78.2	79.4	77.1	68.8	52.3	32.1	10.4	(32)	
10%		WB	-0.2	10.5	28.6	41.5	53.1	63.0	67.0	65.2	55.3	40.4	24.4	5.6	(33)	
		MCD B	0.8	12.1	34.5	53.3	67.5	76.3	77.3	74.7	65.8	48.2	27.8	6.7	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	18.7	22.5	22.7	22.4	23.1	21.4	18.9	19.9	22.1	20.4	19.2	17.9	(35)
MCDBR			20.5	24.2	25.5	31.6	31.2	28.5	25.4	26.5	29.0	26.8	22.4	20.2	(36)	
MCWBR			19.2	21.5	17.6	18.6	15.6	11.4	9.6	11.2	14.5	16.3	16.4	18.4	(37)	
5% WB		MCD BR	20.2	24.3	24.2	30.1	28.4	22.7	19.7	20.6	24.3	24.6	21.6	19.9	(38)	
		MCWBR	19.0	21.6	17.3	18.4	14.9	10.7	8.9	9.6	12.5	15.8	16.2	18.2	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.258	0.281	0.331	0.419	0.494	0.476	0.428	0.398	0.348	0.321	0.287	0.266	(40)	
taud		2.219	2.175	2.118	2.013	1.864	2.034	2.248	2.299	2.371	2.340	2.264	2.179	(41)		
Ebn at Noon		250	272	274	259	244	251	262	265	268	254	234	224	(42)		
Edh at Noon		23	31	40	50	61	52	41	37	31	27	22	21	(43)		
(44)	All-Sky Solar Radiation	RadAvg	534	925	1420	1710	1929	2008	1859	1687	1330	902	540	391	(44)	
(45)		RadStd	37	50	70	101	123	155	128	130	83	48	29	43	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (7 neighbors)	N/A	-3.69	-4.95	N/A	N/A	N/A	+380	+360	N/A	N/A	

Nomenclature: See separate page