

TOMMOT, Russian Federation

WMO: 310050

Lat: 58.967N

Lon: 126.267E

Elev: 930

StdP: 14.21

Time Zone: 9.00 (E09)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-56.2	-52.7	-59.3	0.2	-56.0	-55.9	0.2	-52.6	9.4	-0.3	7.6	-4.9	0.4	180	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.6	85.5	64.8	81.4	63.3	77.7	62.0	68.3	79.4	66.2	77.5	64.3	74.1	4.7	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.5	93.9	72.3	62.5	87.5	70.0	60.4	81.3	69.2	33.3	80.0	31.6	77.6	30.0	74.1	74.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.6	8.0	7.1	-59.2	91.1	3.7	3.2	-61.9	93.3	-64.0	95.2	-66.1	97.0	-68.8	99.3		
(5)			-59.2	71.2	3.7	1.9	-61.9	72.6	-64.0	73.7	-66.1	74.8	-68.8	76.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.4	-29.1	-18.6	2.5	25.0	43.1	57.6	62.5	57.8	42.0	21.2	-9.6	-24.3
	DBStd	34.52	15.63	13.79	13.49	10.74	7.58	6.79	6.47	6.61	7.31	11.38	14.69	15.72
	HDD50	12101	2453	1921	1471	750	238	15	1	13	255	894	1787	2303
	HDD65	16732	2918	2341	1936	1200	680	236	128	238	691	1359	2237	2768
	CDD50	924	0	0	0	0	23	243	389	255	14	0	0	0
	CDD65	80	0	0	0	0	0	14	51	15	0	0	0	0
	CDH74	1599	0	0	0	0	19	427	824	328	1	0	0	0
	CDH80	466	0	0	0	0	2	101	277	86	0	0	0	0
Wind	WSAvg	2.6	1.5	2.1	2.7	3.6	3.8	3.3	2.7	2.6	2.7	2.7	2.2	1.8
Precipitation	PrecAvg	17.1	0.7	0.5	0.5	0.6	1.4	2.5	2.8	2.7	2.3	1.3	0.9	0.8
	PrecMax	23.1	1.3	0.9	1.4	1.5	3.1	5.0	5.6	5.8	4.8	3.0	1.7	1.6
	PrecMin	11.4	0.3	0.2	0.1	0.0	0.2	0.4	0.7	0.6	0.7	0.4	0.2	0.3
	PrecStd	3.0	0.2	0.2	0.2	0.4	0.7	1.0	1.1	1.4	1.0	0.6	0.3	0.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.4	21.9	44.0	59.0	77.6	87.5	91.7	88.0	71.1	51.3	39.6	24.3
		MCWB	10.1	20.0	34.5	44.7	55.3	62.9	67.9	66.5	56.1	42.4	34.3	22.1
	2%	DB	6.1	17.0	35.8	52.6	71.2	82.9	87.5	81.7	65.3	44.0	25.5	16.7
		MCWB	5.1	15.4	30.0	39.9	52.0	61.2	66.4	65.3	52.9	38.7	23.5	15.7
	5%	DB	1.6	9.4	31.4	48.3	65.6	79.6	82.8	77.2	60.6	39.4	17.1	8.1
		MCWB	1.0	8.1	27.4	37.4	49.1	60.0	65.4	62.6	50.7	35.6	15.5	7.2
	10%	DB	-5.1	3.9	27.0	43.7	60.8	75.9	78.6	73.1	55.8	35.6	11.7	-0.6
		MCWB	-5.5	2.8	24.0	35.0	47.2	59.0	64.0	61.3	48.6	32.4	10.7	-1.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.2	20.2	35.6	44.3	56.3	67.3	71.1	69.9	58.2	43.0	34.2	22.1
		MCDB	11.2	21.8	42.9	57.2	74.5	77.5	82.3	80.3	68.3	49.3	39.1	24.4
	2%	WB	5.2	15.5	30.6	40.3	53.4	64.6	69.1	67.2	54.8	39.7	23.8	15.7
		MCDB	5.8	17.1	35.0	50.6	68.2	76.7	80.5	78.3	62.1	43.6	25.3	16.8
	5%	WB	1.1	8.1	27.5	37.8	50.8	62.6	67.4	64.7	52.1	35.6	15.6	7.1
		MCDB	1.8	9.3	31.1	46.9	62.5	74.9	78.4	74.1	58.3	38.4	16.9	7.9
	10%	WB	-5.6	2.9	23.9	35.2	48.1	60.6	65.7	62.8	49.4	32.9	10.6	-1.0
		MCDB	-5.2	4.0	27.2	42.7	59.6	72.3	76.7	71.6	55.0	35.4	11.7	-0.7
Mean Daily Temperature Range	5% DB	MDBR	17.3	26.0	33.8	27.8	24.1	26.6	24.6	25.6	21.4	17.4	19.4	16.6
		MCDBR	19.2	29.0	31.3	31.6	35.7	36.8	35.6	34.6	33.1	19.5	21.8	22.3
		MCWBR	18.4	27.6	25.9	19.4	19.4	17.0	16.8	18.6	20.9	13.6	20.0	21.8
	5% WB	MCDBR	19.0	28.4	29.1	28.2	30.9	30.3	27.8	28.6	27.4	17.6	21.0	22.4
		MCWBR	18.4	27.1	24.3	17.5	17.5	15.4	14.4	15.9	18.1	12.7	19.4	21.6
Clear-Sky Solar Irradiance	taub	0.249	0.283	0.317	0.390	0.466	0.437	0.494	0.438	0.350	0.305	0.255	0.230	
	taud	1.986	2.018	2.015	1.928	1.978	2.208	2.054	2.200	2.403	2.245	2.013	1.928	
	Ebn at Noon	169	226	254	252	241	253	233	239	248	220	163	129	
	Edh at Noon	17	28	38	49	51	41	47	38	26	22	16	12	
All-Sky Solar Radiation	RadAvg	198	534	1090	1645	1591	1767	1604	1257	803	426	251	120	
	RadStd	13	26	42	71	129	136	139	95	62	43	21	6	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	+1.51	N/A	N/A	N/A

Nomenclature: See separate page