

OKHOTSK, Russian Federation

WMO: 310880

Lat: 59.364N

Lon: 143.208E

Elev: 18

StdP: 14.69

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-22.4	-19.5	-31.3	0.9	-21.2	-28.5	1.1	-18.0	27.9	21.3	21.4	11.3	8.6	0	0.803

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.9	66.3	58.1	63.5	58.2	61.5	57.5	61.0	64.1	59.5	62.1	58.2	60.6	7.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.6	76.2	62.2	58.2	72.4	60.8	57.0	69.2	59.6	27.1	64.2	26.1	62.4	25.3	60.8	69.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.6	19.2	15.9	DB	-26.2	75.9	4.3	5.1	-29.2	79.5	-31.8	82.5	-34.2	85.3	-37.3	89.0	(4)
(5)			WB	-26.5	63.8	4.2	2.4	-29.5	65.5	-31.9	66.9	-34.3	68.2	-37.3	70.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.1	-3.7	-1.5	11.0	24.5	36.7	46.8	55.3	56.8	47.9	29.7	9.4	-2.0
	DBStd	23.29	10.62	9.58	9.08	7.29	4.83	5.04	3.63	3.23	5.88	8.74	10.70	10.30
	HDD50	9185	1666	1442	1210	764	413	121	2	1	107	629	1218	1612
	HDD65	14217	2131	1862	1675	1214	878	547	303	255	513	1094	1668	2077
	CDD50	445	0	0	0	0	0	24	166	212	43	0	0	0
	CDD65	2	0	0	0	0	0	0	1	1	0	0	0	0
	CDH74	15	0	0	0	0	0	0	4	11	0	0	0	0
	CDH80	2	0	0	0	0	0	0	0	2	0	0	0	0
Wind	WSAvg	7.8	8.9	7.7	6.8	7.1	7.2	7.3	7.3	6.7	7.5	8.0	9.2	9.6
Precipitation	PrecAvg	19.9	0.5	0.4	0.5	1.0	1.7	2.1	3.1	3.5	3.3	2.3	1.1	0.6
	PrecMax	32.0	3.1	3.7	2.5	2.6	5.7	6.1	8.9	10.6	10.4	8.8	6.5	3.3
	PrecMin	9.9	0.0	0.0	0.0	0.0	0.1	0.0	0.2	0.5	0.7	0.2	0.0	0.0
	PrecStd	4.9	0.6	0.6	0.6	0.7	0.9	1.4	2.1	2.4	2.0	1.6	1.1	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.1	28.8	34.3	44.1	58.0	64.4	70.6	74.3	65.8	50.1	37.6	30.8
		MCWB	27.4	26.6	28.6	35.5	44.8	53.1	61.2	60.3	52.0	44.8	35.1	28.2
	2%	DB	24.4	23.9	30.6	39.5	51.0	59.2	65.7	67.1	60.9	46.6	34.5	24.9
		MCWB	22.4	21.8	27.3	33.9	43.0	54.2	60.2	58.4	53.4	41.4	32.8	22.6
	5%	DB	18.8	17.4	28.2	36.2	46.7	56.6	63.1	64.1	58.4	43.7	30.8	19.1
		MCWB	17.3	14.9	25.5	32.0	41.3	53.0	58.9	58.8	53.7	39.8	29.4	17.3
	10%	DB	12.8	12.4	25.4	33.7	43.8	54.2	61.0	62.0	56.8	41.4	26.3	12.7
		MCWB	11.3	10.6	22.5	30.7	39.9	51.2	57.7	58.3	53.2	37.7	24.6	11.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.3	27.1	30.5	36.7	46.7	57.1	63.3	62.9	58.4	47.1	36.0	27.9
		MCDB	29.6	28.3	32.1	42.1	53.8	60.7	67.1	68.0	59.7	48.5	37.1	29.8
	2%	WB	22.5	21.9	28.0	34.4	43.9	55.0	61.1	61.2	56.7	42.9	32.9	22.7
		MCDB	23.8	23.9	30.2	38.2	49.5	57.9	64.6	64.5	58.3	44.8	34.2	24.4
	5%	WB	17.2	15.2	25.5	32.8	42.0	53.1	59.4	60.0	55.3	40.6	29.5	17.2
		MCDB	18.8	17.0	28.2	35.5	45.9	55.8	62.3	62.6	57.3	42.8	30.8	19.1
	10%	WB	11.3	10.5	22.6	31.2	40.3	51.5	57.9	58.9	53.8	38.4	24.8	11.1
		MCDB	12.8	12.3	25.2	33.3	43.3	53.9	60.4	61.2	56.1	40.8	26.4	12.6
Mean Daily Temperature Range	5% DB	MDBR	8.7	12.6	18.1	12.8	8.7	7.4	6.7	8.9	12.0	11.3	8.5	7.3
		MCDBR	13.6	13.0	16.6	14.9	16.6	13.5	12.8	14.9	14.5	13.5	8.7	13.1
		MCWBR	12.7	11.8	13.6	10.4	9.7	8.2	8.0	8.8	9.5	9.8	7.8	12.4
	5% WB	MCDBR	13.5	12.5	15.2	12.5	14.4	11.0	11.0	11.5	9.4	11.9	7.9	13.1
		MCWBR	12.8	11.4	12.8	9.0	9.0	7.5	7.5	7.9	7.4	9.9	7.4	12.6
Clear-Sky Solar Irradiance	taub		0.228	0.266	0.322	0.430	0.453	0.425	0.479	0.425	0.348	0.318	0.258	0.214
	taud		2.095	2.134	2.016	1.791	1.961	2.231	2.105	2.266	2.448	2.296	2.141	2.027
	Ebn at Noon		185	237	251	237	244	256	237	243	248	214	166	141
	Edh at Noon		14	24	37	57	52	40	45	36	25	21	14	10
All-Sky Solar Radiation	RadAvg		169	502	1061	1533	1557	1639	1408	1187	874	512	216	89
	RadStd		11	24	52	141	170	148	238	146	120	52	24	7

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page