

NEL' KAN, Russian Federation

WMO: 311520

Lat: 57.650N

Lon: 136.150E

Elev: 318

StdP: 97.56

Time Zone: 10.00 (E10)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-45.4	-43.2	-47.8	0.0	-45.1	-45.6	0.0	-43.0	4.1	-23.3	3.5	-28.0	0.5	180	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	29.7	18.8	27.4	17.5	25.5	16.8	20.1	27.7	18.9	25.6	17.7	23.8	1.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.3	12.8	23.8	16.0	11.8	22.4	15.0	11.1	21.1	59.3	27.6	55.1	25.6	51.3	23.7	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.1	3.4	3.1	-47.6	32.5	2.9	1.9	-49.6	33.9	-51.3	35.0	-52.9	36.0	-55.0	37.4		
(5)			-47.6	22.1	2.8	1.7	-49.6	23.4	-51.3	24.4	-52.9	25.3	-55.0	26.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-6.1	-33.1	-28.4	-15.4	-2.3	8.4	15.3	18.4	15.7	7.2	-4.8	-22.7	-33.2	(6)
(7)		DBStd	19.58	6.02	5.57	6.57	5.56	4.04	3.65	3.53	3.60	4.49	5.44	7.59	6.47	(7)
(8)		HDD10.0	6534	1334	1075	787	368	80	3	0	3	106	457	981	1338	(8)
(9)		HDD18.3	8995	1593	1308	1046	618	308	104	43	98	334	716	1231	1597	(9)
(10)		CDD10.0	654	0	0	0	0	31	162	261	179	22	0	0	0	(10)
(11)		CDD18.3	73	0	0	0	0	0	12	46	16	0	0	0	0	(11)
(12)		CDH23.3	957	0	0	0	0	13	199	556	186	3	0	0	0	(12)
(13)		CDH26.7	267	0	0	0	0	1	38	185	43	0	0	0	0	(13)
(14)	Wind	WSAvg	1.3	1.3	1.2	1.3	1.4	1.7	1.4	1.2	1.3	1.3	1.4	1.3	1.3	(14)
(15)	Precipitation	PrecAvg	407	16	14	7	16	39	48	72	69	49	33	22	17	(15)
(16)		PrecMax	635	39	36	28	49	86	135	242	164	133	118	90	48	(16)
(17)		PrecMin	267	0	1	1	0	11	1	9	7	13	4	0	4	(17)
(18)		PrecStd	87	10	8	7	11	18	29	47	37	29	24	19	12	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-8.2	-10.8	4.0	13.1	24.9	30.2	33.5	30.2	23.1	9.7	0.4	-7.8	(19)
(20)			MCWB	-9.6	-12.1	-0.5	6.4	14.0	17.4	21.2	19.9	14.7	5.1	-2.0	-9.0	(20)
(21)		2%	DB	-21.2	-14.3	0.5	10.7	22.1	27.5	31.1	27.5	19.5	6.7	-3.2	-17.4	(21)
(22)			MCWB	-21.7	-15.2	-3.0	4.6	12.1	15.7	20.1	18.3	13.2	4.1	-4.2	-17.8	(22)
(23)		5%	DB	-23.4	-16.8	-2.2	8.6	19.7	25.6	28.7	25.3	16.6	4.6	-8.1	-21.3	(23)
(24)			MCWB	-23.7	-17.4	-4.7	3.4	10.9	15.7	18.7	17.6	11.3	2.6	-9.1	-21.6	(24)
(25)		10%	DB	-25.2	-19.9	-4.6	6.5	16.9	23.8	26.5	23.0	14.2	2.4	-11.8	-24.5	(25)
(26)			MCWB	-25.5	-20.5	-6.6	1.9	9.5	14.7	17.5	16.3	10.0	0.4	-12.6	-24.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-9.6	-12.0	-0.4	6.8	15.3	19.2	22.3	20.7	15.4	6.4	-1.6	-9.0	(27)
(28)			MCDWB	-8.3	-11.0	3.9	12.1	23.3	25.9	31.2	28.1	21.4	8.6	0.2	-7.8	(28)
(29)		2%	WB	-21.5	-15.1	-2.8	5.2	13.0	17.7	20.9	19.3	13.7	4.5	-4.3	-17.8	(29)
(30)			MCDWB	-21.2	-14.4	0.3	10.1	20.6	24.4	29.4	26.1	18.9	6.5	-3.2	-17.3	(30)
(31)		5%	WB	-23.8	-17.4	-4.6	3.6	11.3	16.7	19.6	18.0	12.0	2.7	-8.9	-21.6	(31)
(32)			MCDWB	-23.5	-16.8	-2.2	8.2	18.5	23.9	27.0	24.2	16.2	4.5	-8.0	-21.2	(32)
(33)		10%	WB	-25.5	-20.4	-6.6	2.1	9.9	15.6	18.5	16.7	10.7	0.6	-12.6	-24.7	(33)
(34)			MCDWB	-25.2	-19.9	-4.5	6.1	16.4	22.1	25.1	21.7	13.6	2.2	-11.8	-24.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.6	10.5	12.7	11.7	11.6	12.6	12.0	11.3	9.6	6.4	7.6	5.6	(35)
(36)			MCDBR	7.0	12.3	14.2	13.6	16.8	16.9	16.7	15.8	14.6	8.1	9.4	6.9	(36)
(37)			MCWBR	6.7	11.6	11.4	8.7	9.0	7.5	7.5	7.5	8.4	5.9	8.6	6.5	(37)
(38)		5% WB	MCDBR	7.0	12.3	13.8	12.8	15.8	13.9	15.0	14.2	13.1	7.3	9.2	6.9	(38)
(39)			MCWBR	6.7	11.6	11.0	8.4	9.2	6.9	7.7	7.5	8.0	5.6	8.5	6.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.237	0.267	0.316	0.403	0.449	0.440	0.486	0.421	0.353	0.312	0.252	0.220	(40)	
(41)		taud	2.056	2.091	2.011	1.858	2.012	2.181	2.054	2.248	2.388	2.246	2.062	2.000	(41)	
(42)		Ebn at Noon	615	767	815	788	782	799	746	777	788	705	576	510	(42)	
(43)		Edh at Noon	55	85	123	171	157	135	150	116	86	73	54	42	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.75	1.86	3.64	5.37	5.17	5.70	5.24	4.11	2.69	1.43	0.92	0.49	(44)	
(45)		RadStd	0.03	0.06	0.12	0.25	0.54	0.56	0.47	0.39	0.22	0.18	0.08	0.02	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page