

MAGDAGACHI, Russian Federation

WMO: 312950

Lat: 53.467N

Lon: 125.817E

Elev: 1191

StdP: 14.07

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -31.6	(c) -27.8	(d) -36.1	(e) 0.7	(f) -30.6	(g) -32.6	(h) 0.9	(i) -26.9	(j) 20.4	(k) -2.1	(l) 18.2	(m) -0.2	(n) 1.9	(o) 270	(p) 0.620

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 19.4	(c) 86.2	(d) 68.1	(e) 82.9	(f) 66.8	(g) 79.8	(h) 65.4	(i) 71.2	(j) 80.7	(k) 69.3	(l) 78.4	(m) 67.5	(n) 76.2	(o) 5.8	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.3	108.5	75.6	66.3	101.1	73.6	64.5	94.8	72.0	35.9	80.5	34.3	78.6	32.8	76.0	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 21.0	(b) 17.3	(c) 14.4	(e) -36.5	(f) 91.9	(g) 5.2	(h) 3.1	(i) -40.3	(j) 94.2	(k) -43.3	(l) 96.0	(m) -46.3	(n) 97.7	(o) -50.0	(p) 100.0		
(4) 21.0	(5) 17.3	(6) 14.4	(7) -36.6	(8) 75.4	(9) 5.1	(10) 3.3	(11) -40.3	(12) 77.8	(13) -43.3	(14) 79.7	(15) -46.2	(16) 81.5	(17) -50.0	(18) 83.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	30.2	-9.7	-1.5	14.4	35.2	50.7	63.4	68.0	63.4	49.7	30.7	5.3	-9.6	(6)
(7)		DBStd	29.41	8.92	8.75	10.48	8.57	7.37	6.33	5.18	5.96	7.71	9.48	11.32	8.83	(7)
(8)		HDD50	8822	1850	1443	1104	452	81	2	0	1	99	599	1342	1849	(8)
(9)		HDD65	12950	2315	1863	1569	895	446	103	28	102	461	1062	1792	2314	(9)
(10)		CDD50	1577	0	0	0	7	102	402	559	416	89	2	0	0	(10)
(11)		CDD65	230	0	0	0	0	2	53	122	52	1	0	0	0	(11)
(12)		CDH74	2414	0	0	0	3	71	706	1100	511	23	0	0	0	(12)
(13)		CDH80	636	0	0	0	0	11	192	325	107	1	0	0	0	(13)
(14)	Wind	WSAvg	5.9	5.0	5.8	6.9	7.6	7.3	5.3	4.8	4.9	6.1	6.4	5.4	5.1	(14)
(15)	Precipitation	PrecAvg	19.1	0.3	0.2	0.2	0.7	2.0	3.0	4.7	4.0	2.1	1.0	0.6	0.4	(15)
(16)		PrecMax	36.3	0.6	0.6	0.6	2.1	4.2	5.4	14.0	8.0	4.4	3.1	1.5	0.7	(16)
(17)		PrecMin	14.4	0.0	0.0	0.0	0.0	0.1	0.9	2.2	1.0	0.8	0.1	0.0	0.1	(17)
(18)		PrecStd	4.3	0.2	0.2	0.2	0.5	1.1	1.3	2.6	1.8	1.0	0.7	0.4	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.6	27.4	46.6	70.5	81.4	89.4	91.8	86.8	77.2	62.0	34.9	20.1	(19)
(20)			MCWB	13.8	22.7	36.5	51.9	61.6	67.2	70.6	69.0	62.8	49.2	29.6	17.1	(20)
(21)		2%	DB	11.4	21.3	40.7	61.5	75.3	85.4	87.1	83.0	72.4	54.8	29.6	14.1	(21)
(22)			MCWB	9.1	17.9	32.6	46.5	56.7	66.0	69.9	67.1	60.0	45.5	26.2	11.9	(22)
(23)		5%	DB	7.5	16.8	35.5	55.4	70.6	81.7	83.5	79.8	68.2	49.3	26.3	7.5	(23)
(24)			MCWB	5.7	14.0	28.8	42.8	54.5	64.4	68.4	66.2	57.1	41.3	23.8	5.8	(24)
(25)		10%	DB	3.9	12.6	31.2	50.1	66.3	78.0	80.3	76.3	63.7	44.6	22.0	3.1	(25)
(26)			MCWB	2.4	10.0	25.7	39.7	52.0	63.0	66.9	64.8	54.4	37.9	19.7	1.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.0	22.8	36.9	52.3	62.3	71.3	75.5	72.4	65.1	51.0	30.1	17.1	(27)
(28)			MCDWB	16.1	27.4	45.9	69.3	79.6	82.9	85.8	81.7	74.1	60.4	33.5	20.0	(28)
(29)		2%	WB	9.1	17.8	32.8	47.2	58.5	68.3	72.2	70.0	61.6	45.7	26.6	12.0	(29)
(30)			MCDWB	11.1	21.2	40.5	60.5	72.0	80.6	82.1	78.4	69.8	54.2	29.0	14.1	(30)
(31)		5%	WB	5.7	14.0	29.1	43.3	55.7	66.3	70.3	68.2	58.7	41.8	23.7	5.8	(31)
(32)			MCDWB	7.4	16.8	35.0	54.9	67.7	78.3	79.6	75.9	65.5	48.6	26.4	7.4	(32)
(33)		10%	WB	2.5	10.1	25.9	40.0	53.1	64.2	68.5	66.2	55.9	38.3	19.7	1.8	(33)
(34)			MCDWB	3.9	12.6	31.0	49.5	64.1	75.4	77.2	73.9	62.4	44.1	22.0	3.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	18.2	21.6	21.6	20.6	22.4	22.2	19.4	20.8	21.5	18.1	17.6	16.3	(35)
(36)			MCDBR	18.8	24.3	23.4	29.6	31.1	28.6	26.3	26.8	28.3	24.7	19.5	17.2	(36)
(37)			MCWBR	17.0	21.1	17.3	18.5	17.4	13.4	12.8	13.2	16.6	16.7	15.8	15.6	(37)
(38)		5% WB	MCDWR	18.6	24.2	22.9	27.9	27.3	24.5	21.1	20.9	23.2	23.7	19.0	17.1	(38)
(39)			MCWBR	16.9	21.0	17.1	18.1	16.3	13.4	12.2	12.2	15.0	16.6	15.7	15.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.248	0.279	0.337	0.501	0.547	0.501	0.471	0.408	0.374	0.349	0.285	0.250	(40)	
(41)		taud	2.152	2.110	2.010	1.759	1.766	1.984	2.128	2.297	2.317	2.211	2.141	2.091	(41)	
(42)		Ebn at Noon	230	257	262	228	226	240	246	257	251	226	207	199	(42)	
(43)		Edh at Noon	21	30	42	63	66	54	46	36	31	28	21	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	399	769	1326	1672	1673	1934	1675	1474	1123	720	437	301	(44)	
(45)		RadStd	17	21	49	146	112	174	170	123	90	47	25	15	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	(47) Regional (5 neighbors)	(d) +0.72	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A

Nomenclature: See separate page