

SELEMDZA, Russian Federation

WMO: 313380

Lat: 53.133N

Lon: 133.967E

Elev: 2238

StdP: 13.55

Time Zone: 9.00 (E09)

Period: 82-94

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-56.8	-53.4	-59.4	0.2	-56.9	-56.4	0.2	-53.5	12.5	1.8	6.7	9.1	0.0	N/A	0.707

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.0	80.7	62.8	77.4	61.9	74.0	60.3	66.3	75.6	64.4	73.1	62.6	70.3	3.1	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.3	94.4	69.4	61.2	87.8	67.5	59.5	82.4	66.0	32.3	75.5	30.9	73.1	29.4	70.5	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.2	9.8	7.5	DB	-59.5	85.7	5.4	2.5	-63.3	87.5	-66.5	88.9	-69.5	90.3	-73.4	92.1	(4)
(5)			WB	-59.5	72.0	5.4	3.1	-63.3	74.2	-66.5	76.1	-69.5	77.8	-73.4	80.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.2	-29.7	-16.0	1.9	25.1	40.7	54.0	60.4	56.2	42.9	23.5	-5.6	-25.2	(6)	
	DBStd	32.86	11.39	11.20	10.59	10.04	7.47	6.62	5.25	5.09	7.07	10.00	12.18	11.55	(7)	
	HDD50	11961	2472	1849	1490	748	304	34	3	6	235	820	1668	2332	(8)	
	HDD65	16738	2937	2269	1955	1198	755	332	156	274	662	1285	2118	2797	(9)	
	CDD50	716	0	0	0	0	14	155	324	200	23	0	0	0	(10)	
	CDD65	17	0	0	0	0	0	3	12	2	0	0	0	0	(11)	
	CDH74	692	0	0	0	0	14	240	346	92	0	0	0	0	(12)	
	CDH80	102	0	0	0	0	2	42	51	7	0	0	0	0	(13)	
	WSAvg	1.4	0.3	0.9	1.6	2.5	2.6	2.0	1.4	1.3	1.6	1.6	0.8	0.2	(14)	
	PrecAvg	29.4	0.7	0.5	0.9	1.6	3.0	3.6	5.0	4.8	3.6	2.9	1.7	1.1	(15)	
(16) Precipitation	PrecMax	35.4	1.9	1.9	2.5	3.0	5.0	6.4	9.3	9.3	6.0	5.2	3.3	3.0	(16)	
	PrecMin	21.9	0.1	0.0	0.2	0.5	1.2	1.3	1.5	1.9	1.1	0.9	0.6	0.3	(17)	
	PrecStd	3.5	0.5	0.4	0.6	0.6	1.1	1.0	2.0	1.6	1.2	1.1	0.8	0.7	(18)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.7	25.7	42.7	57.6	75.9	84.5	84.7	80.3	70.5	53.3	29.5	15.0	(19)	
		MCWB	14.5	22.2	34.5	45.1	56.1	63.8	65.9	63.9	56.6	42.4	27.1	13.1	(20)	
	2%	DB	3.8	17.8	34.5	51.0	70.3	80.5	81.3	76.4	65.8	47.1	23.6	8.3	(21)	
		MCWB	2.6	14.9	28.6	39.6	52.1	61.2	64.1	63.0	54.9	38.8	21.3	7.3	(22)	
	5%	DB	-4.7	10.5	29.2	46.5	64.3	76.7	78.2	72.5	61.5	42.0	20.2	1.2	(23)	
		MCWB	-5.5	8.4	24.5	36.9	49.6	59.5	62.8	60.9	53.1	36.0	17.9	0.6	(24)	
	10%	DB	-10.9	4.9	24.6	42.3	58.4	72.2	74.9	69.1	57.4	38.3	15.5	-5.3	(25)	
		MCWB	-11.4	3.3	20.6	34.3	46.5	56.9	62.3	59.7	50.7	34.4	13.8	-5.8	(26)	
	0.4%	WB	14.5	22.4	34.7	46.0	57.2	67.1	69.4	68.2	59.4	43.6	27.3	12.5	(27)	
		MCDB	16.9	25.8	41.7	55.3	74.0	80.3	77.4	74.9	65.3	51.8	29.3	14.0	(28)	
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	2.8	15.1	28.7	40.7	54.2	63.5	67.0	65.3	57.1	39.7	21.8	7.0	(29)	
		MCDB	3.9	17.9	33.8	48.9	65.9	75.6	76.5	72.1	62.7	45.0	23.6	8.2	(30)	
	5%	WB	-5.4	8.3	24.7	37.6	51.0	61.2	65.4	62.9	54.2	37.2	17.8	0.5	(31)	
		MCDB	-4.7	10.5	29.1	45.4	61.9	71.3	74.6	69.4	60.8	41.2	20.0	1.1	(32)	
	10%	WB	-11.4	3.4	20.7	34.8	47.6	59.0	63.8	61.0	51.2	34.5	13.9	-5.9	(33)	
		MCDB	-10.8	4.9	24.7	41.7	57.4	68.7	71.9	67.2	56.4	38.0	15.5	-5.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	30.4	38.3	39.4	28.2	26.5	30.0	26.0	24.3	24.3	24.5	28.0	26.5	(35)	
		MCDBR	27.3	37.1	39.4	33.0	41.1	40.7	35.0	33.0	31.3	30.3	26.0	24.8	(36)	
		MCWBR	26.4	34.0	32.8	22.2	24.2	22.2	19.2	20.2	19.9	22.1	23.9	24.5	(37)	
		MCDBR	27.1	36.6	37.5	30.6	36.0	31.3	27.5	26.7	24.8	29.1	24.6	24.9	(38)	
	5% WB	MCWBR	26.1	33.6	31.0	20.9	21.7	18.5	16.7	17.4	16.4	21.5	22.6	24.2	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.237	0.270	0.327	0.438	0.487	0.455	0.445	0.392	0.351	0.344	0.276	0.234	(40)	
	taud		2.164	2.106	1.968	1.779	1.896	2.115	2.194	2.350	2.395	2.158	2.083	2.104	(41)	
	Ebn at Noon		239	263	266	247	242	254	254	263	261	228	210	212	(42)	
	Edh at Noon		21	30	44	62	58	47	43	35	29	30	23	18	(43)	
(44) All-Sky Solar Radiation	RadAvg		422	792	1319	1679	1571	1710	1555	1309	984	617	422	316	(44)	
	RadStd		12	25	53	112	177	170	147	129	99	56	34	11	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page