

BURUKAN, Russian Federation

WMO: 313480

Lat: **53.050N**Lon: **136.033E**Elev: **502**StdP: **14.43**Time Zone: **10.00 (E10)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-46.3	-42.4	-50.0	0.3	-45.1	-46.2	0.4	-41.5	13.2	12.4	11.2	10.8	0.3	350	0.655

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.5	83.9	68.1	80.2	66.2	76.5	64.2	70.9	80.3	68.5	77.0	66.1	73.7	3.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.6	103.3	75.6	65.3	95.4	73.0	63.0	87.7	70.7	35.2	79.3	33.1	77.0	31.2	74.0	80.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.9	8.6	7.2	DB	-49.3	90.6	4.1	3.1	-52.3	92.9	-54.7	94.7	-57.0	96.5	-60.0	98.8	(4)
(5)			WB	-49.1	74.6	3.6	2.3	-51.7	76.3	-53.8	77.7	-55.8	79.0	-58.3	80.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.3	-16.4	-9.1	8.6	29.7	43.7	55.2	61.3	60.2	48.6	31.1	4.3	-15.3	(6)	
	DBStd	29.84	11.99	10.19	10.81	8.51	7.18	7.12	5.72	5.39	6.45	8.36	14.13	11.83	(7)	
	HDD50	9943	2058	1656	1283	610	222	28	2	2	101	586	1372	2023	(8)	
	HDD65	14538	2523	2076	1748	1060	662	304	145	166	493	1051	1822	2488	(9)	
	CDD50	940	0	0	0	1	26	184	351	320	58	0	0	0	(10)	
	CDD65	57	0	0	0	0	0	10	29	18	0	0	0	0	(11)	
	CDH74	1296	0	0	0	1	51	382	539	304	19	0	0	0	(12)	
	CDH80	309	0	0	0	0	10	103	145	50	1	0	0	0	(13)	
(14) Wind	WSAvg	2.1	1.5	1.6	2.4	2.9	3.0	2.7	2.2	2.1	2.0	2.1	1.7	1.4	(14)	
(15) Precipitation	PrecAvg	25.3	0.5	0.4	0.7	1.9	2.4	3.0	4.3	4.5	3.7	2.2	1.0	0.8	(15)	
	PrecMax	36.7	2.0	1.4	1.8	4.3	5.0	7.1	8.7	10.3	6.7	6.8	4.0	3.5	(16)	
	PrecMin	15.2	0.0	0.0	0.0	0.0	0.4	0.8	0.8	1.0	0.8	0.3	0.0	0.0	(17)	
	PrecStd	5.0	0.6	0.4	0.5	1.0	1.1	1.4	2.3	2.4	1.5	1.3	0.9	0.8	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.7	24.8	44.0	66.7	81.6	88.0	89.8	85.1	76.4	60.3	36.6	27.0	(19)	
		MCWB	23.0	20.9	34.8	49.3	59.4	69.5	71.2	70.5	64.1	49.0	31.7	26.7	(20)	
	2%	DB	17.6	18.6	37.3	56.5	73.3	82.9	84.5	80.8	70.9	52.9	32.0	18.2	(21)	
		MCWB	16.9	15.6	30.0	43.7	54.9	65.5	69.3	68.1	59.9	43.7	29.7	17.2	(22)	
	5%	DB	11.2	14.4	32.4	50.6	68.2	78.4	80.4	77.3	66.8	48.4	29.3	11.3	(23)	
		MCWB	10.3	12.3	27.1	40.4	53.4	63.3	67.2	66.6	57.7	41.6	27.2	10.4	(24)	
	10%	DB	5.1	10.3	28.6	45.4	62.1	74.0	76.2	73.8	62.6	44.8	26.3	5.3	(25)	
		MCWB	4.1	8.7	24.4	36.9	50.1	61.0	65.5	64.2	54.8	39.4	24.4	4.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.2	21.2	35.4	50.8	61.6	72.6	74.2	73.0	66.0	50.4	33.1	26.9	(27)	
		MCDB	23.9	24.6	43.6	63.8	76.1	84.3	84.1	80.3	74.2	58.8	34.9	27.0	(28)	
	2%	WB	16.8	15.8	30.6	45.1	56.9	68.2	71.1	70.3	61.9	45.8	30.1	16.8	(29)	
		MCDB	17.5	18.5	36.1	55.8	69.9	79.3	81.1	78.5	68.2	50.2	31.8	17.6	(30)	
	5%	WB	10.3	12.3	27.7	40.9	53.6	64.9	68.9	68.0	58.9	42.7	27.5	10.1	(31)	
		MCDB	11.1	14.2	32.0	50.0	66.5	75.8	77.9	75.1	64.5	47.6	29.1	11.0	(32)	
	10%	WB	4.2	8.6	24.7	37.3	50.5	61.8	66.5	65.6	56.2	39.8	24.4	4.3	(33)	
		MCDB	5.1	10.3	28.4	44.6	61.3	71.8	74.3	71.6	61.4	44.2	26.4	5.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	27.5	34.2	33.1	24.7	24.5	26.2	21.5	22.1	26.1	22.6	25.1	25.5	(35)	
		MCDBR	20.8	33.7	36.2	35.0	40.9	40.1	34.9	32.2	35.1	28.7	21.3	19.7	(36)	
	5% WB	MCWBR	19.8	30.7	29.4	22.9	24.3	23.6	20.3	20.2	23.3	19.8	17.9	18.7	(37)	
		MCWBR	19.5	32.8	33.4	33.3	38.1	34.9	29.4	27.4	29.8	25.9	18.9	19.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.255	0.287	0.352	0.461	0.532	0.493	0.498	0.425	0.368	0.360	0.295	0.255	(40)	
		taud	2.135	2.088	1.937	1.781	1.807	2.034	2.063	2.287	2.385	2.193	2.109	2.082	(41)	
	Ebn at Noon		228	255	256	240	230	243	239	252	256	223	203	199	(42)	
		Edh at Noon	22	31	46	62	63	51	49	37	30	29	22	19	(43)	
(44) All-Sky Solar Radiation	RadAvg		407	774	1271	1621	1561	1714	1535	1303	1017	633	405	302	(44)	
	RadStd		17	31	69	101	180	168	167	143	94	54	34	17	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page