

NORSK, Russian Federation

WMO: 313880

Lat: 52.3345N

Lon: 129.9000E

Elev: 681

StdP: 14.34

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-42.7	-39.1	-47.5	0.3	-41.9	-43.9	0.4	-38.5	11.3	8.4	9.1	-0.2	0.0	350	0.564

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.3	85.5	67.8	82.6	66.8	79.7	65.4	72.0	79.9	70.2	77.8	68.4	75.3	2.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
69.7	112.1	75.2	67.9	105.0	73.3	66.0	98.3	71.9	36.3	79.8	34.8	77.7	33.2	75.5	79.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.2	9.9	8.1	-45.9	90.1	4.5	2.7	-49.1	92.0	-51.8	93.6	-54.3	95.2	-57.6	97.2		
			-45.9	75.0	4.0	2.7	-48.8	76.9	-51.1	78.4	-53.3	79.9	-56.2	81.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.5	-17.9	-7.7	11.2	35.2	51.3	62.9	68.6	63.8	50.6	32.6	4.9	-16.1		
	DBStd	32.18	10.04	9.73	12.22	8.91	6.96	5.75	4.66	5.89	7.79	9.09	13.33	10.88		
	HDD50	9474	2105	1614	1204	450	66	1	0	1	88	542	1353	2050		
	HDD65	13569	2570	2034	1669	896	427	105	20	93	433	1004	1803	2515		
	CDD50	1613	0	0	0	5	107	387	577	428	106	3	0	0		
	CDD65	232	0	0	0	0	3	41	132	55	1	0	0	0		
	CDH74	2363	0	0	0	6	115	588	1135	496	23	0	0	0		
	CDH80	575	0	0	0	0	19	146	317	92	1	0	0	0		
	WSAvg	2.4	1.1	1.6	3.0	4.2	3.8	2.5	2.1	2.1	2.5	2.9	1.9	1.1		
	PrecAvg	22.0	0.2	0.2	0.4	1.4	2.0	2.7	5.0	4.8	3.0	1.1	0.7	0.4		
	PrecMax	29.3	0.6	0.7	1.1	4.3	4.3	5.4	9.7	9.4	7.1	2.2	1.7	1.2		
(15) Precipitation	PrecMin	16.5	0.0	0.0	0.1	0.1	0.5	0.6	1.3	1.6	0.7	0.2	0.4	0.0		
	PrecStd	3.7	0.2	0.2	0.2	0.9	1.0	1.4	2.5	2.1	1.7	0.6	0.4	0.3		
	DB	18.6	27.2	46.1	72.0	83.0	88.9	90.6	85.9	76.8	66.5	39.9	23.9			
	MCWB	15.8	22.7	36.2	52.1	60.0	70.5	70.6	68.9	62.7	51.0	34.8	20.1			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	10.9	21.7	40.3	62.0	77.3	84.1	86.3	82.6	72.8	56.7	33.0	14.2			
	2% MCWB	8.7	18.2	32.0	46.8	57.1	65.8	68.5	68.4	60.4	45.2	29.9	12.5			
	5% DB	4.6	15.5	35.9	56.4	72.5	80.6	83.6	79.3	68.9	51.6	29.3	7.8			
	5% MCWB	3.3	12.8	29.3	42.9	54.4	63.3	67.9	66.8	57.7	42.4	26.4	6.4			
	10% DB	-1.0	10.5	31.8	51.1	67.9	77.1	80.5	76.1	64.8	46.9	24.5	1.2			
	10% MCWB	-2.0	8.3	26.7	39.7	52.0	62.5	67.2	65.3	55.7	39.5	22.2	0.2			
	0.4% WB	16.2	22.8	36.3	53.5	62.1	73.5	74.7	73.5	65.4	51.5	35.0	20.2			
	0.4% MCDB	18.3	26.4	44.5	69.8	78.3	82.6	82.6	80.7	73.1	62.7	39.1	23.3			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	8.9	17.9	32.7	47.7	58.6	69.1	72.6	71.1	62.5	47.1	30.4	12.5			
	2% MCDB	10.8	21.4	38.6	59.6	72.2	79.7	80.7	77.7	69.2	54.8	32.8	13.8			
	5% WB	3.4	12.9	30.0	43.7	56.3	66.6	71.0	69.1	60.2	43.4	26.4	6.5			
	5% MCDB	4.8	15.6	35.8	54.6	69.2	75.7	78.8	75.2	66.7	50.5	29.2	7.9			
	10% WB	-2.0	8.3	26.5	40.5	53.8	64.4	69.5	67.2	57.6	40.2	22.3	0.3			
	10% MCDB	-1.0	10.5	31.8	50.6	64.4	73.4	76.8	73.4	63.1	46.0	24.5	1.2			
	MDBR	25.1	30.7	29.5	22.9	24.4	23.1	20.3	21.0	22.8	20.4	21.8	22.0			
	5% DB	25.5	31.5	27.5	32.1	34.4	30.1	26.3	25.7	28.3	28.5	20.7	20.9			
(36) Mean Daily Temperature Range	MCWBR	23.6	28.2	20.1	17.8	16.1	13.3	10.9	12.5	15.3	17.6	16.9	19.4			
	MCDBR	25.4	31.0	25.4	29.7	29.9	24.9	20.6	20.4	23.2	25.6	20.1	20.6			
	MCWBR	23.5	27.7	18.6	17.3	15.0	12.5	10.8	11.5	13.8	16.9	16.6	19.0			
	MCDBR	25.5	31.5	27.5	32.1	34.4	30.1	26.3	25.7	28.3	28.5	20.7	20.9			
(40) Clear-Sky Solar Irradiance	taub	0.258	0.293	0.359	0.543	0.592	0.503	0.478	0.422	0.395	0.418	0.324	0.259			
	taud	2.134	2.063	1.938	1.681	1.678	1.993	2.117	2.269	2.250	1.984	2.051	2.085			
	Ebn at Noon	231	254	256	218	216	241	246	254	246	199	192	203			
	Edh at Noon	23	33	46	69	72	53	46	38	34	36	25	20			
(44) All-Sky Solar Radiation	RadAvg	452	831	1368	1626	1680	1897	1721	1490	1120	727	468	347			
	RadStd	16	23	59	154	132	188	150	100	94	54	27	15			

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page