

NORSK, Russian Federation

WMO: 313880

Lat: 52.3345N

Lon: 129.9000E

Elev: 208

StdP: 98.86

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-41.5	-39.5	-44.2	0.0	-41.1	-42.2	0.1	-39.2	5.1	-13.1	4.1	-17.9	0.0	350	0.564

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	29.7	19.9	28.1	19.3	26.5	18.6	22.2	26.6	21.2	25.4	20.2	24.1	1.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	16.0	24.0	19.9	15.0	23.0	18.9	14.0	22.2	66.6	26.6	63.1	25.4	59.4	24.2	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.4	4.4	3.6	DB	-43.3	32.3	2.5	1.5	-45.1	33.4	-46.6	34.2	-48.0	35.1	-49.8	36.2	(4)
			WB	-43.3	23.9	2.2	1.5	-44.9	24.9	-46.2	25.8	-47.4	26.6	-49.0	27.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-2.0	-27.7	-22.0	-11.6	1.8	10.7	17.2	20.3	17.7	10.3	0.3	-15.1	-26.7
	DBStd	17.88	5.58	5.41	6.79	4.95	3.87	3.19	2.59	3.27	4.33	5.05	7.41	6.04
	HDD10.0	5263	1169	897	669	250	37	1	0	1	49	301	752	1139
	HDD18.3	7538	1428	1130	927	498	237	58	11	52	241	558	1002	1397
	CDD10.0	896	0	0	0	3	59	215	321	238	59	2	0	0
	CDD18.3	129	0	0	0	0	2	23	73	31	1	0	0	0
	CDH23.3	1313	0	0	0	3	64	327	631	276	13	0	0	0
	CDH26.7	319	0	0	0	0	11	81	176	51	1	0	0	0
Wind	WSAvg	1.1	0.5	0.7	1.3	1.9	1.7	1.1	0.9	0.9	1.1	1.3	0.9	0.5
Precipitation	PrecAvg	559	5	5	11	36	51	69	127	123	77	27	18	11
	PrecMax	745	16	19	28	108	109	136	247	240	180	57	42	30
	PrecMin	420	0	0	2	3	13	14	32	40	18	6	9	1
	PrecStd	93	4	5	6	24	26	35	64	54	44	15	9	8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-7.4	-2.7	7.8	22.2	28.3	31.6	32.6	30.0	24.9	19.2	4.4	-4.5
		MCWB	-9.0	-5.1	2.3	11.2	15.6	21.4	21.4	20.5	17.0	10.6	1.5	-6.6
	2%	DB	-11.7	-5.7	4.6	16.7	25.1	28.9	30.2	28.1	22.7	13.7	0.5	-9.9
		MCWB	-12.9	-7.7	0.0	8.2	13.9	18.8	20.3	20.2	15.8	7.4	-1.2	-10.9
	5%	DB	-15.2	-9.2	2.2	13.5	22.5	27.0	28.7	26.3	20.5	10.9	-1.5	-13.4
		MCWB	-16.0	-10.7	-1.5	6.0	12.5	17.4	20.0	19.3	14.3	5.8	-3.1	-14.2
	10%	DB	-18.3	-12.0	-0.1	10.6	20.0	25.1	26.9	24.5	18.2	8.3	-4.2	-17.1
		MCWB	-18.9	-13.2	-2.9	4.3	11.1	17.0	19.6	18.5	13.2	4.2	-5.4	-17.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-8.8	-5.1	2.4	11.9	16.7	23.0	23.7	23.0	18.6	10.8	1.7	-6.5
		MCDB	-7.6	-3.1	7.0	21.0	25.7	28.1	28.1	27.0	22.8	17.1	4.0	-4.8
	2%	WB	-12.9	-7.9	0.4	8.7	14.8	20.6	22.6	21.7	16.9	8.4	-0.9	-10.8
		MCDB	-11.8	-5.9	3.7	15.4	22.4	26.5	27.1	25.4	20.7	12.7	0.5	-10.1
	5%	WB	-15.9	-10.6	-1.1	6.5	13.5	19.2	21.7	20.6	15.7	6.3	-3.1	-14.2
		MCDB	-15.1	-9.1	2.1	12.5	20.7	24.3	26.0	24.0	19.3	10.3	-1.5	-13.4
	10%	WB	-18.9	-13.2	-3.0	4.7	12.1	18.0	20.8	19.5	14.2	4.6	-5.4	-17.6
		MCDB	-18.3	-12.0	-0.1	10.3	18.0	23.0	24.9	23.0	17.3	7.8	-4.1	-17.1
Mean Daily Temperature Range	5% DB	MDBR	14.0	17.0	16.4	12.7	13.6	12.8	11.3	11.7	12.7	11.4	12.1	12.2
		MCDBR	14.2	17.5	15.3	17.8	19.1	16.7	14.6	14.3	15.7	15.8	11.5	11.6
		MCWBR	13.1	15.7	11.1	9.9	9.0	7.4	6.1	6.9	8.5	9.8	9.4	10.8
	5% WB	MCDBR	14.1	17.2	14.1	16.5	16.6	13.8	11.5	11.4	12.9	14.2	11.2	11.4
		MCWBR	13.1	15.4	10.3	9.6	8.3	7.0	6.0	6.4	7.7	9.4	9.2	10.6
Clear-Sky Solar Irradiance	taub	0.258	0.293	0.359	0.543	0.592	0.503	0.478	0.422	0.395	0.418	0.324	0.259	
	taud	2.134	2.063	1.938	1.681	1.678	1.993	2.117	2.269	2.250	1.984	2.051	2.085	
	Ebn at Noon	729	801	806	688	680	760	774	802	774	627	606	641	
	Edh at Noon	71	104	146	217	228	168	146	119	108	114	78	62	
All-Sky Solar Radiation	RadAvg	1.43	2.62	4.31	5.12	5.30	5.98	5.42	4.70	3.53	2.29	1.48	1.09	
	RadStd	0.05	0.07	0.19	0.49	0.42	0.59	0.47	0.31	0.30	0.17	0.09	0.05	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page