

IM POLINY OSIPENKO, Russian Federation

WMO: 314160

Lat: 52.4207N

Lon: 136.4799E

Elev: 70

StdP: 100.48

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -39.9	(c) -37.3	(d) -42.2	(e) 0.1	(f) -39.5	(g) -39.8	(h) 0.1	(i) -37.1	(j) 9.7	(k) -11.0	(l) 7.5	(m) -11.5	(n) 0.2	(o) 0	(p) 0.599

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 10.4	(c) 29.6	(d) 21.1	(e) 27.7	(f) 20.1	(g) 25.9	(h) 19.0	(i) 22.5	(j) 27.8	(k) 21.2	(l) 26.1	(m) 20.1	(n) 24.5	(o) 1.9	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.7	15.5	25.5	19.5	14.3	24.2	18.3	13.3	22.9	67.0	27.7	62.3	26.1	58.2	24.6	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 6.9	(b) 5.7	(c) 4.9	(e) -42.5	(f) 32.7	(g) 2.8	(h) 2.0	(i) -44.5	(j) 34.2	(k) -46.2	(l) 35.3	(m) -47.8	(n) 36.4	(o) -49.8	(p) 37.9		
(a) 6.9	(b) 5.7	(c) 4.9	(e) -42.5	(f) 24.3	(g) 2.7	(h) 1.6	(i) -44.4	(j) 25.5	(k) -45.9	(l) 26.4	(m) -47.4	(n) 27.3	(o) -49.4	(p) 28.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.3	-25.0	-20.3	-10.4	0.8	8.8	15.4	18.9	17.7	11.6	2.0	-12.2	-23.6		
	DBStd	16.53	6.45	5.62	5.57	4.55	4.63	4.56	3.86	3.26	3.83	4.28	7.15	6.63		
	HDD10.0	4916	1086	849	632	277	79	7	0	0	27	251	666	1043		
	HDD18.3	7271	1344	1082	890	525	296	111	40	52	204	508	916	1302		
	CDD10.0	803	0	0	0	2	43	168	276	239	73	1	0	0		
	CDD18.3	117	0	0	0	0	2	23	58	32	2	0	0	0		
	CDH23.3	1092	0	0	0	1	38	267	527	246	14	0	0	0		
	CDH26.7	286	0	0	0	0	9	68	166	44	0	0	0	0		
	WSAvg	1.7	1.1	1.4	1.9	2.3	2.5	1.9	1.8	1.6	1.5	1.8	1.6	1.3		
	PrecAvg	488	11	7	13	28	48	59	84	90	66	45	22	16		
(15) Precipitation	PrecMax	681	54	33	40	84	120	146	210	235	144	143	59	60		
	PrecMin	250	0	0	0	4	5	11	4	28	5	0	1	0		
	PrecStd	97	10	7	10	19	25	30	47	47	35	31	16	15		
	PrecStd	97	10	7	10	19	25	30	47	47	35	31	16	15		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-4.9	-3.6	6.2	19.1	27.8	31.1	33.1	30.0	25.2	17.0	4.2	-2.1		
		MCWB	-5.7	-5.2	1.7	10.8	15.6	20.9	23.7	22.2	17.9	10.9	0.8	-2.9		
	2%	DB	-8.6	-6.8	3.1	14.8	23.5	28.6	30.4	27.9	22.5	12.9	1.3	-6.4		
		MCWB	-9.3	-8.2	-0.7	7.8	13.7	19.3	21.9	20.9	16.4	7.8	-0.7	-7.2		
	5%	DB	-11.5	-9.1	0.7	11.7	21.0	26.4	28.4	26.1	20.4	10.5	-0.4	-10.0		
		MCWB	-12.1	-10.3	-2.3	5.8	12.2	18.1	21.0	19.9	14.9	6.3	-1.8	-10.8		
	10%	DB	-14.6	-11.2	-1.5	8.7	18.3	24.1	26.3	24.3	18.3	8.5	-2.0	-13.4		
		MCWB	-15.2	-12.2	-3.9	3.6	11.0	16.8	19.9	18.7	13.7	5.1	-3.3	-14.0		
	0.4%	WB	-5.7	-5.1	2.0	11.7	16.7	22.8	25.2	23.4	18.7	11.3	1.4	-2.7		
		MCDB	-5.0	-4.0	5.8	18.0	25.7	29.3	30.3	28.1	23.9	15.8	3.2	-2.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	-9.1	-8.2	-0.4	8.3	14.6	20.5	23.0	22.0	17.2	8.8	-0.3	-7.1		
		MCDB	-8.5	-6.9	2.8	14.4	22.5	26.7	28.9	26.5	21.4	11.9	0.9	-6.3		
	5%	WB	-12.1	-10.3	-2.1	5.9	13.0	19.0	21.8	20.7	15.8	6.9	-1.7	-10.7		
		MCDB	-11.5	-9.2	0.4	11.5	19.8	24.6	26.9	24.7	19.2	9.6	-0.4	-10.0		
	10%	WB	-15.1	-12.2	-3.7	3.8	11.3	17.7	20.6	19.6	14.4	5.4	-3.3	-14.0		
		MCDB	-14.6	-11.2	-1.6	8.4	17.3	23.0	25.3	23.2	17.5	8.1	-2.0	-13.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.7	13.6	13.1	10.5	11.8	11.9	10.4	9.7	10.9	9.3	9.5	10.6		
		MCDBR	8.7	12.9	14.3	15.4	17.6	15.5	14.0	13.0	14.0	12.8	8.9	8.4		
		MCWBR	8.2	11.5	10.8	9.3	9.0	7.1	6.5	6.7	7.8	7.9	7.0	8.0		
		MCDBR	8.5	12.1	13.4	15.1	16.8	14.0	12.6	11.2	12.2	11.3	8.1	8.3		
	5% WB	MCWBR	8.1	10.9	10.2	9.4	9.2	7.1	6.6	6.3	7.1	7.4	6.5	7.9		
		MCWBR	8.1	10.9	10.2	9.4	9.2	7.1	6.6	6.3	7.1	7.4	6.5	7.9		
(40) Clear-Sky Solar Irradiance	taub		0.262	0.293	0.361	0.473	0.550	0.502	0.507	0.428	0.374	0.376	0.309	0.263		
	taud		2.118	2.069	1.919	1.798	1.791	2.014	2.043	2.285	2.367	2.155	2.097	2.077		
	Ebn at Noon		718	800	802	750	714	761	748	797	802	689	632	631		
	Edh at Noon		72	103	149	192	204	165	158	117	96	96	74	63		
(44) All-Sky Solar Radiation	RadAvg		1.36	2.54	4.07	5.09	5.08	5.66	5.07	4.33	3.42	2.13	1.31	1.02		
	RadStd		0.07	0.10	0.22	0.31	0.52	0.53	0.56	0.46	0.29	0.17	0.10	0.08		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	-2.29	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page