

AMGUN', Russian Federation

WMO: 314840

Lat: 51.417N

Lon: 135.083E

Elev: 882

StdP: 14.23

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -29.0	(c) -24.7	(d) -34.1	(e) 0.8	(f) -27.8	(g) -30.2	(h) 1.0	(i) -23.6	(j) 16.7	(k) -5.5	(l) 13.9	(m) -7.5	(n) 1.1	(o) 270	(p) 0.582

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 19.0	(c) 86.0	(d) 68.3	(e) 82.4	(f) 66.7	(g) 78.7	(h) 65.1	(i) 71.1	(j) 81.1	(k) 69.2	(l) 78.4	(m) 67.3	(n) 75.5	(o) 4.1	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.0	106.1	75.6	66.1	99.3	73.5	64.3	93.1	71.6	35.7	81.0	33.9	78.9	32.4	75.7	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 13.3	(b) 11.2	(c) 9.4	(e) -37.0	(f) 93.0	(g) 6.7	(h) 3.3	(i) -41.9	(j) 95.5	(k) -45.8	(l) 97.4	(m) -49.6	(n) 99.3	(o) -54.5	(p) 101.7		
(4) 13.3	(5) 11.2	(6) 9.4	(7) -37.1	(8) 75.8	(9) 6.7	(10) 2.6	(11) -42.0	(12) 77.7	(13) -45.9	(14) 79.2	(15) -49.6	(16) 80.7	(17) -54.5	(18) 82.5		

Monthly Climatic Design Conditions

			Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
			(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	32.4	-5.4	1.4	16.1	34.6	48.8	60.1	66.4	64.2	52.5	36.3	14.2	-2.6	(6)
(7)		DBStd	26.85	9.25	8.60	9.41	7.98	8.16	7.41	6.19	5.83	6.84	7.60	10.44	9.49	(7)
(8)		HDD50	7916	1717	1362	1050	469	125	5	0	1	51	430	1075	1631	(8)
(9)		HDD65	12112	2182	1782	1515	913	505	185	57	86	375	891	1525	2096	(9)
(10)		CDD50	1480	0	0	0	5	87	308	509	440	127	4	0	0	(10)
(11)		CDD65	203	0	0	0	0	2	38	101	60	2	0	0	0	(11)
(12)		CDH74	2067	0	0	0	4	91	516	922	493	40	1	0	0	(12)
(13)		CDH80	609	0	0	0	0	19	160	313	114	3	0	0	0	(13)
(14)	Wind	WSAvg	3.1	3.2	3.0	3.0	3.2	2.9	2.5	2.2	2.4	2.9	3.5	4.1	3.9	(14)
(15)	Precipitation	PrecAvg	24.4	0.7	0.4	0.7	1.5	3.1	3.3	4.7	4.2	2.6	1.6	0.8	0.8	(15)
(16)		PrecMax	31.4	2.3	1.6	2.4	3.9	5.5	6.8	9.5	10.4	5.1	4.6	2.0	3.3	(16)
(17)		PrecMin	14.1	0.0	0.0	0.1	0.4	1.1	0.9	0.2	1.3	0.8	0.3	0.0	0.0	(17)
(18)		PrecStd	4.6	0.6	0.4	0.6	0.9	1.3	1.3	2.0	2.2	1.3	1.1	0.6	0.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.0	30.3	48.0	70.1	83.2	89.7	93.0	87.7	78.4	66.8	44.2	26.1	(19)
(20)			MCWB	20.7	23.9	36.6	49.9	58.8	67.0	71.4	70.6	63.0	51.3	36.0	23.7	(20)
(21)		2%	DB	17.1	24.7	40.7	62.4	76.1	84.7	86.9	83.2	73.8	58.5	37.7	19.7	(21)
(22)			MCWB	15.0	20.2	31.9	46.6	55.5	65.1	69.7	68.5	60.3	46.2	31.4	17.6	(22)
(23)		5%	DB	12.9	20.1	36.1	55.1	71.1	79.8	83.2	79.4	69.7	52.6	32.5	15.4	(23)
(24)			MCWB	11.1	16.5	29.0	42.0	53.5	63.1	68.6	66.9	57.9	42.4	28.5	13.5	(24)
(25)		10%	DB	9.1	16.1	32.0	49.3	66.1	75.4	79.0	75.8	65.3	48.0	29.2	11.7	(25)
(26)			MCWB	7.5	13.3	26.4	39.0	51.4	62.0	67.3	65.2	55.7	40.0	26.1	9.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.7	24.3	36.7	52.1	60.5	70.8	74.7	73.6	65.4	51.9	36.7	24.2	(27)
(28)			MCDWB	22.7	29.8	47.3	66.2	78.1	81.7	86.4	84.4	75.0	65.0	43.3	26.3	(28)
(29)		2%	WB	15.1	20.4	32.3	47.2	57.5	67.4	71.9	70.5	62.0	47.4	32.0	17.8	(29)
(30)			MCDWB	16.9	24.5	39.8	61.7	71.9	79.8	82.1	79.7	70.7	55.9	35.8	19.6	(30)
(31)		5%	WB	11.2	16.7	29.5	42.8	55.2	65.2	70.0	68.5	59.6	43.9	29.1	13.7	(31)
(32)			MCDWB	12.8	20.0	35.6	54.6	67.2	76.6	80.0	76.1	66.9	51.0	32.4	15.4	(32)
(33)		10%	WB	7.5	13.3	26.7	39.2	52.6	63.0	68.3	66.5	57.1	40.9	26.0	9.9	(33)
(34)			MCDWB	9.0	16.0	31.5	48.7	64.1	72.8	77.0	73.6	63.2	47.0	29.3	11.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	21.4	25.2	24.2	20.8	22.0	21.5	19.0	19.0	21.4	18.1	16.3	17.0	(35)
(36)			MCDBR	21.4	26.9	26.7	31.5	33.6	31.3	28.4	26.0	29.4	27.2	18.1	16.7	(36)
(37)			MCWBR	19.1	22.6	18.8	18.0	16.2	14.2	13.1	12.9	16.2	16.0	13.3	14.7	(37)
(38)		5% WB	MCDWR	20.7	26.4	25.1	30.2	29.5	27.1	23.8	22.3	25.7	25.7	17.1	16.3	(38)
(39)			MCWBR	18.5	22.2	18.0	17.8	15.3	13.5	12.2	12.0	15.6	15.9	12.9	14.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.261	0.295	0.367	0.475	0.550	0.496	0.490	0.416	0.372	0.374	0.307	0.260	(40)	
(41)		taud	2.129	2.057	1.890	1.768	1.774	2.029	2.099	2.323	2.369	2.145	2.096	2.102	(41)	
(42)		Ebn at Noon	235	257	254	239	228	244	243	258	257	223	208	211	(42)	
(43)		Edh at Noon	23	34	49	63	66	52	48	36	31	31	24	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	486	863	1369	1632	1540	1669	1535	1363	1069	679	466	374	(44)	
(45)		RadStd	14	25	53	139	170	194	150	135	102	56	31	16	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page