

BELOGORSK, Russian Federation

WMO: 315130

Lat: 50.917N

Lon: 128.467E

Elev: 178

StdP: 99.21

Time Zone: 9.00 (E09)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -33.8	(c) -31.8	(d) -35.7	(e) 0.1	(f) -33.4	(g) -34.0	(h) 0.2	(i) -31.5	(j) 4.9	(k) -16.9	(l) 4.3	(m) -17.4	(n) 0.6	(o) 320	(p) 0.529

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 9.1	(c) 30.8	(d) 20.9	(e) 29.0	(f) 20.6	(g) 27.4	(h) 20.0	(i) 23.0	(j) 27.9	(k) 22.1	(l) 26.8	(m) 21.3	(n) 25.8	(o) 2.5	(p) 200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.4	16.4	25.4	20.6	15.6	24.6	19.7	14.8	23.9	69.3	28.3	66.0	26.7	63.0	25.8	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 6.7	(b) 5.4	(c) 4.7	(e) -35.9	(f) 34.3	(g) 3.2	(h) 2.7	(i) -38.2	(j) 36.2	(k) -40.0	(l) 37.8	(m) -41.8	(n) 39.3	(o) -44.1	(p) 41.3		
(a) 6.7	(b) 5.4	(c) 4.7	(e) -36.0	(f) 25.3	(g) 3.1	(h) 1.9	(i) -38.2	(j) 26.7	(k) -40.0	(l) 27.8	(m) -41.8	(n) 28.9	(o) -44.1	(p) 30.3		

Monthly Climatic Design Conditions

		Annual													
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.8	-23.1	-18.3	-8.4	3.7	12.6	19.2	21.9	19.8	12.5	2.2	-11.5	-22.2	(6)
	DBStd	16.83	4.54	4.55	6.28	4.89	4.19	3.72	2.59	3.11	4.53	5.04	6.61	4.87	(7)
	HDD10.0	4522	1025	794	569	196	21	0	0	1	26	247	646	997	(8)
	HDD18.3	6648	1283	1027	828	438	184	32	3	21	179	501	896	1256	(9)
	CDD10.0	1164	0	0	0	8	101	277	369	303	102	3	0	0	(10)
	CDD18.3	248	0	0	0	0	6	58	114	64	5	0	0	0	(11)
	CDH23.3	1900	0	0	0	7	97	553	785	415	44	0	0	0	(12)
	CDH26.7	522	0	0	0	1	19	206	211	81	4	0	0	0	(13)
(14) Wind	WSAvg	1.9	1.4	1.6	2.2	2.8	2.6	1.9	1.8	1.8	2.0	2.0	1.8	1.6	(14)
(15) Precipitation	PrecAvg	547	8	7	11	24	56	79	123	114	65	31	16	12	(15)
	PrecMax	889	25	32	41	88	133	158	251	330	186	83	34	32	(16)
	PrecMin	361	1	0	0	0	7	20	44	24	17	10	0	1	(17)
	PrecStd	110	6	6	11	20	32	32	55	60	40	19	9	8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-9.6	-3.2	9.6	23.7	29.3	35.9	33.4	30.6	26.9	18.4	6.5	-6.5	(19)
		MCWB	-10.7	-4.4	3.7	11.7	15.9	22.9	21.7	22.1	18.7	10.6	3.8	-7.2	(20)
	2%	DB	-12.6	-5.8	6.5	18.0	26.2	31.2	30.7	28.8	24.5	14.5	3.3	-10.6	(21)
		MCWB	-13.4	-7.3	1.6	9.0	14.4	19.9	22.3	21.4	17.0	8.4	0.4	-11.4	(22)
	5%	DB	-14.6	-8.7	3.9	14.8	23.4	29.0	28.9	27.3	22.3	11.8	0.6	-12.8	(23)
		MCWB	-15.4	-9.9	-0.1	7.3	13.2	19.0	21.5	20.7	15.9	7.0	-1.4	-13.5	(24)
	10%	DB	-16.5	-11.2	1.2	12.1	20.9	26.4	27.3	25.7	20.0	9.8	-1.6	-14.9	(25)
		MCWB	-17.1	-12.3	-1.7	5.5	12.1	18.6	20.9	19.7	14.8	5.7	-3.4	-15.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-10.8	-4.3	3.9	12.6	16.8	22.9	24.2	23.9	19.7	11.7	3.5	-7.3	(27)
		MCDB	-9.7	-3.7	8.7	20.8	26.0	32.2	29.0	28.3	24.3	15.1	6.0	-6.6	(28)
	2%	WB	-13.3	-7.3	1.9	9.8	15.4	21.2	23.2	22.7	18.3	9.6	0.6	-11.3	(29)
		MCDB	-12.6	-5.9	5.9	17.4	23.4	28.7	27.9	27.0	22.6	12.9	2.9	-10.7	(30)
	5%	WB	-15.4	-9.8	0.0	7.7	14.1	20.3	22.5	21.6	16.9	7.6	-1.2	-13.5	(31)
		MCDB	-14.7	-8.7	3.5	14.0	21.3	27.2	27.1	25.7	20.9	11.3	0.6	-12.8	(32)
	10%	WB	-17.1	-12.2	-1.5	6.0	12.9	19.2	21.8	20.7	15.7	5.8	-3.5	-15.5	(33)
		MCDB	-16.5	-11.2	1.2	11.2	19.5	24.8	26.3	24.4	19.5	9.3	-1.8	-15.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.9	10.6	10.8	10.5	11.2	9.8	9.1	9.5	10.8	9.5	8.6	8.0	(35)
		MCDBR	9.3	10.4	11.6	15.0	15.3	14.1	11.5	11.8	13.6	12.9	9.2	8.5	(36)
		MCWBR	8.5	9.2	7.3	8.3	6.7	5.2	4.5	5.3	6.6	7.7	6.8	7.8	(37)
	5% WB	MCDBR	9.3	9.9	11.1	14.1	12.6	12.0	9.5	9.4	11.4	10.6	8.6	8.3	(38)
		MCWBR	8.5	8.8	7.2	7.9	6.1	5.3	4.4	4.8	5.8	7.2	6.5	7.6	(39)
(40) Clear-Sky Solar Irradiance	taub		0.268	0.301	0.380	0.543	0.599	0.498	0.482	0.429	0.396	0.397	0.323	0.272	(40)
	taud		2.134	2.060	1.893	1.692	1.657	2.003	2.099	2.238	2.242	2.063	2.096	2.085	(41)
	Ebn at Noon		740	807	791	696	680	768	774	801	782	676	644	656	(42)
	Edh at Noon		76	108	157	217	235	168	150	124	111	109	80	68	(43)
(44) All-Sky Solar Radiation	RadAvg		1.61	2.84	4.43	5.05	5.44	5.96	5.51	4.81	3.79	2.48	1.59	1.25	(44)
	RadStd		0.05	0.07	0.25	0.53	0.43	0.70	0.41	0.31	0.33	0.13	0.09	0.07	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page